

School	Location	Date Sampled	Pass	Fail
Adams ES	Ground Floor, Inside Lunch Room	2/26/13	< 1	
Adams ES	Ground Floor, Inside Lunch Room	2/26/13	< 1	
Adams ES	Ground Floor, Next to Staircase	2/26/13	< 1	
Adams ES	Ground Floor, Next to Staircase	2/26/13	< 1	
Adams ES	Ground Floor, Next to Main Office	2/26/13	< 1	
Adams ES	Ground Floor, Next to Main Office	2/26/13	< 1	
Adams ES	Ground Floor, Inside Teachers' Lounge	2/26/13	< 1	
Adams ES	Ground Floor, Inside Teachers' Lounge	2/26/13	< 1	
Adams ES	2nd Floor Corridor, Next to Room 312	2/26/13	< 1	
Adams ES	2nd Floor Corridor, Next to Room 312	2/26/13	< 1	
Adams ES	2nd Floor Corridor, Next to Room 316	2/26/13	< 1	
Adams ES	2nd Floor Corridor, Next to Room 316	2/26/13	< 1	
Adams ES	1st Floor Corridor, Next to Room 206	2/26/13	< 1	
Adams ES	1st Floor Corridor, Next to Room 206	2/26/13	< 1	
Adams ES	1st Floor Corridor, Next to Room 210	2/26/13	< 1	
Adams ES	1st Floor Corridor, Next to Room 210	2/26/13	< 1	
			Percentage of Passed Samples	
			Percentage of Failed Samples	
Aiton ES	4th Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	4th Floor Hallway, Opposite to Elevator	4/18/13	< 1	
	4th Floor Hallway, Opposite to Maintenance			
Aiton ES	Storage Room	4/18/13	< 1	
	4th Floor Hallway, Opposite to Maintenance			
Aiton ES	Storage Room	4/18/13	< 1	
Aiton ES	3rd Floor Hallway, Opposite to Storage Room	4/18/13	< 1	
Aiton ES	3rd Floor Hallway, Opposite to Storage Room	4/18/13	< 1	
Aiton ES	3rd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	3rd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	3rd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	2nd Floor Hallway, Opposite to Vault	4/18/13	< 1	
Aiton ES	2nd Floor Hallway, Opposite to Vault	4/18/13	< 1	
Aiton ES	2nd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	2nd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	2nd Floor Hallway, Opposite to Elevator	4/18/13	< 1	
Aiton ES	1st Floor, Inside Kindergarten #2	4/18/13	< 1	
Aiton ES	1st Floor, Inside Kindergarten #2	4/18/13	< 1	
Aiton ES	1st Floor, Inside Kindergarten #1	4/18/13	< 1	
Aiton ES	1st Floor, Inside Kindergarten #1	4/18/13	< 1	
Aiton ES	1st Floor Hallway, Opposite to Health Suite	4/18/13	< 1	
Aiton ES	1st Floor Hallway, Opposite to Health Suite	4/18/13	< 1	
Aiton ES	1st Floor Lobby, at Main Entrance	4/18/13	< 1	
Aiton ES	1st Floor Lobby, at Main Entrance	4/18/13	< 1	
			Percentage of Passed Samples	
			Percentage of Failed Samples	
Amidon ES	1st Floor Hallway, by Men's Restroom	3/14/13	< 1	
Amidon ES	1st Floor Hallway, by Men's Restroom	3/14/13	< 1	
Amidon ES	1st Floor Hallway, by Room B128 (High)	3/14/13	< 1	
Amidon ES	1st Floor Hallway, by Room B128 (High)	3/14/13	< 1	
Amidon ES	1st Floor Hallway, by Room B128 (Low)	3/14/13	< 1	
Amidon ES	1st Floor Hallway, by Room B128 (Low)	3/14/13	< 1	
Amidon ES	1st Floor Hallway, Leading to Gym	3/14/13	< 1	
Amidon ES	1st Floor Hallway, Leading to Gym	3/14/13	< 1	

Amidon ES	1st Floor, Inside Gym	3/14/13	< 1
Amidon ES	1st Floor, Inside Gym	3/14/13	< 1
Amidon ES	1st Floor, Inside Pre-Kindergarten	3/14/13	< 1
Amidon ES	1st Floor, Inside Pre-Kindergarten	3/14/13	< 1
Amidon ES	1st Floor, Inside Room B128	3/14/13	< 1
Amidon ES	1st Floor, Inside Room B128	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A103 (High)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A103 (High)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A106 (High)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A106 (High)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A105 (High)	3/14/13	1.3
Amidon ES	1st Floor, Inside Room A105 (High)	3/14/13	1.4
Amidon ES	1st Floor, Inside Room A105 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A105 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A107 (High)	3/14/13	4.1
Amidon ES	1st Floor, Inside Room A107 (High)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A107 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A107 (Low)	3/14/13	< 1
Amidon ES	1st Floor Hallway, Outside Health Suite	3/14/13	< 1
Amidon ES	1st Floor Hallway, Outside Health Suite	3/14/13	< 1
Amidon ES	1st Floor, Inside Health Suite	3/14/13	< 1
Amidon ES	1st Floor, Inside Health Suite	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A103 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A103 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A106 (Low)	3/14/13	< 1
Amidon ES	1st Floor, Inside Room A106 (Low)	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B223	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B223	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B230	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B230	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A208	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A208	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A212	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A212	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A202	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A202	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A213	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A213	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A209	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room A209	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B225	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B225	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B227	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B227	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B231	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B231	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B236	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B236	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B232	3/14/13	< 1
Amidon ES	2nd Floor, Inside Room B232	3/14/13	< 1
Amidon ES	2nd Floor Hallway, by Girls Restroom	3/14/13	
Amidon ES	2nd Floor Hallway, by Girls Restroom	3/14/13	10
Amidon ES	<i>2nd Floor Hallway, by Girls Restroom - Retest</i>	<i>4/1/13</i>	< 1

Amidon ES	2nd Floor Hallway, by Girls Restroom - Retest	4/1/13	< 1
		Percentage of Passed Samples	Percentage of Failed Samples
Anacostia SHS	1st Floor Hallway, Next to Room M103	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Next to Room M103	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Next to Room S103	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Next to Room S103	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room G102	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room G102	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room M115	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room M115	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room N110	6/6/13	< 1
Anacostia SHS	1st Floor Hallway, Across from Room N110	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room M320	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room M320	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room M303	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room M303	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room M220	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room M220	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room M202	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room M202	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room S204	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room S204	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room G204	6/6/13	< 1
Anacostia SHS	2nd Floor Hallway, Next to Room G204	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room G302	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room G302	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room N201	6/6/13	< 1
Anacostia SHS	3rd Floor Hallway, Next to Room N201	6/6/13	< 1
		Percentage of Passed Samples	Percentage of Failed Samples
Ballou SHS	3rd Floor Hallway, Opposite to Elevator	5/24/13	< 1
Ballou SHS	3rd Floor Hallway, Opposite to Elevator	5/24/13	< 1
Ballou SHS	3rd Floor Hallway, by Room 307	5/24/13	< 1
Ballou SHS	3rd Floor Hallway, by Room 307	5/24/13	< 1
Ballou SHS	3rd Floor Hallway, by Room 315	5/24/13	< 1
Ballou SHS	3rd Floor Hallway, by Room 315	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Room 215	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Room 215	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Room 209	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Room 209	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Men's Restroom	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, by Men's Restroom	5/24/13	< 1
Ballou SHS	1st Floor Hallway, Outside Gym	5/24/13	< 1
Ballou SHS	1st Floor Hallway, Outside Gym	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Music Room & Auditorium	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Music Room & Auditorium	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Elevator	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Elevator	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A129	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A129	5/24/13	< 1

Ballou SHS	1st Floor Hallway, by Room A121	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A121	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A114	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A114	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A104	5/24/13	< 1
Ballou SHS	1st Floor Hallway, by Room A104	5/24/13	< 1
Ballou SHS	1st Floor, Inside Cafeteria, Right Side	5/24/13	< 1
Ballou SHS	1st Floor, Inside Cafeteria, Right Side	5/24/13	< 1
	1st Floor, Inside Cafeteria, Close to Security		
Ballou SHS	Desk	5/24/13	< 1
	1st Floor, Inside Cafeteria, Close to Security		
Ballou SHS	Desk	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, Opposite to Room 206	5/24/13	< 1
Ballou SHS	2nd Floor Hallway, Opposite to Room 206	5/24/13	< 1
Ballou SHS	Basement Hallway, by Room A41	5/24/13	< 1
Ballou SHS	Basement Hallway, by Room A41	5/24/13	< 1
Ballou SHS	Basement Floor, Inside Armory	5/24/13	< 1
Ballou SHS	Basement Floor, Inside Armory	5/24/13	< 1
Ballou SHS	Basement Floor, Inside Girls Locker Room	5/24/13	< 1
Ballou SHS	Basement Floor, Inside Girls Locker Room	5/24/13	< 1

				Percentage of Passed Samples
				Percentage of Failed Samples

Bancroft ES	4th Floor, Next to Room 225	2/28/13	< 1
Bancroft ES	4th Floor, Next to Room 225	2/28/13	< 1
Bancroft ES	4th Floor, Next to Room 221	2/28/13	< 1
Bancroft ES	4th Floor, Next to Room 221	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 122	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 122	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 213	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 213	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 210	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 210	2/28/13	< 1
Bancroft ES	2nd Floor, Inside Health Suite	2/28/13	< 1
Bancroft ES	2nd Floor, Inside Health Suite	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 107	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 107	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 324	2/28/13	< 1
Bancroft ES	3rd Floor, Next to Room 324	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 309	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 309	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 314	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 314	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 313	2/28/13	< 1
Bancroft ES	2nd Floor, Next to Room 313	2/28/13	< 1
Bancroft ES	1st Floor, Next to Boys Restroom	2/28/13	< 1
Bancroft ES	1st Floor, Next to Boys Restroom	2/28/13	< 1
Bancroft ES	Basement Floor, Inside Lunch Room	2/28/13	< 1
Bancroft ES	Basement Floor, Inside Lunch Room	2/28/13	< 1
Bancroft ES	Open Space, by Boys Restroom	2/28/13	< 1
Bancroft ES	Open Space, by Boys Restroom	2/28/13	< 1
Bancroft ES	Open Space, by Girls Restroom	2/28/13	< 1
Bancroft ES	Open Space, by Girls Restroom	2/28/13	< 1
Bancroft ES	Open Space, Inside Library	2/28/13	< 1
Bancroft ES	Open Space, Inside Library	2/28/13	< 1

		Percentage of Passed Samples	Percentage of Failed Samples
Bannaker SHS	3rd Floor, Outside Room 306	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 306	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 304	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 304	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 315	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 315	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 321	4/24/13	< 1
Bannaker SHS	3rd Floor, Outside Room 321	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Mechanical Room	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Mechanical Room	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Library and Girls Restroom	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Library and Girls Restroom	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Library and Boys Restroom	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Library and Boys Restroom	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Mechanical Room, by Locker 754	4/24/13	< 1
Bannaker SHS	2nd Floor, Outside Mechanical Room, by Locker 754	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Room 113	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Room 113	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Gym Entrance	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Gym Entrance	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Principal's Office	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Principal's Office	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Men's Restroom	4/24/13	< 1
Bannaker SHS	1st Floor Hallway, by Men's Restroom	4/24/13	< 1
Bannaker SHS	Basement Hallway, by Custodian's Office	4/24/13	< 1
Bannaker SHS	Basement Hallway, by Custodian's Office	4/24/13	< 1
Bannaker SHS	Basement Hallway, by Maintenance Office	4/24/13	< 1
Bannaker SHS	Basement Hallway, by Maintenance Office	4/24/13	< 1
Bannaker SHS	Basement, Inside Cafeteria, by Boys Restroom	4/24/13	< 1
Bannaker SHS	Basement, Inside Cafeteria, by Boys Restroom	4/24/13	< 1
Bannaker SHS	Basement, Inside Cafeteria, by Girls Restroom	4/24/13	< 1
Bannaker SHS	Basement, Inside Cafeteria, by Girls Restroom	4/24/13	< 1
Bannaker SHS	Basement Hallway, Opposite to Room 006	4/24/13	< 1
Bannaker SHS	Basement Hallway, Opposite to Room 006	4/24/13	< 1
		Percentage of Passed Samples	Percentage of Failed Samples
Barnard ES	2nd Floor Hallway, by Room 239 (High)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 239 (High)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 239 (Low)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 239 (Low)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 206 (High)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 206 (High)	5/16/13	< 1

Barnard ES	2nd Floor Hallway, by Room 206 (Low)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 206 (Low)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 210 (High)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 210 (High)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 210 (Low)	5/16/13	< 1
Barnard ES	2nd Floor Hallway, by Room 210 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 109 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 109 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 109 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 109 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 106 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 106 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 106 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 106 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 121 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 121 (High)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 121 (Low)	5/16/13	< 1
Barnard ES	1st Floor Hallway, by Room 121 (Low)	5/16/13	< 1
Barnard ES	2nd Floor, Across from Room 219 (High)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 219 (High)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 219 (Low)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 219 (Low)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 215 (High)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 215 (High)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 215 (Low)	4/9/13	< 1
Barnard ES	2nd Floor, Across from Room 215 (Low)	4/9/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Beers ES	1st Floor, Inside Health Suite	3/26/13	< 1
Beers ES	1st Floor, Inside Health Suite	3/26/13	< 1
Beers ES	2nd Floor Hallway, Next to Teachers' Restroom	3/26/13	< 1
Beers ES	2nd Floor Hallway, Next to Teachers' Restroom	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Women/Men's Restroom (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Girls Restroom (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Girls Restroom (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Girls Restroom (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Next to Girls Restroom (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room B109	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room B109	3/26/13	< 1
Beers ES	2nd Floor Hallway, by Room B209	3/26/13	< 1
Beers ES	2nd Floor Hallway, by Room B209	3/26/13	< 1

Beers ES	2nd Floor Hallway, by Room B201	3/26/13	< 1
Beers ES	2nd Floor Hallway, by Room B201	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Teachers' Lounge	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Teachers' Lounge	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room D211 (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room D211 (High)	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room D211 (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Outside Room D211 (Low)	3/26/13	< 1
Beers ES	1st Floor Hallway, Opposite to Room C101	3/26/13	2.1
Beers ES	1st Floor Hallway, Opposite to Room C101	3/26/13	< 1
Beers ES	Ground Floor, Entrance to Lunch Room (High)	3/26/13	< 1
Beers ES	Ground Floor, Entrance to Lunch Room (High)	3/26/13	< 1
Beers ES	Ground Floor, Entrance to Lunch Room (Low)	3/26/13	< 1
Beers ES	Ground Floor, Entrance to Lunch Room (Low)	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D109 (High)	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D109 (High)	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D109 (Low)	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D109 (Low)	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D101	3/26/13	< 1
Beers ES	Ground Floor Hallway, by Room D101	3/26/13	< 1

Percentage of Passed Samples	
------------------------------	--

Percentage of Failed Samples	
------------------------------	--

Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (High)	6/3/13	< 1
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (High)	6/3/13	< 1
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (Low)	6/3/13	< 1
Bell-Lincoln EC	4th Floor Hallway, Next to Girls Restroom (Low)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Display)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Display)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Display)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Display)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Stairwell)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (High, Closer to Stairwell)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Stairwell)	6/3/13	< 1

Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Low, Closer to Stairwell)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, High, Closer to Gym)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, High, Closer to Gym)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, Low, Closer to Gym)	6/3/13	< 1
Bell-Lincoln EC	2nd Floor Hallway, Across from Stairs and Display Case (Other Bldg, Low, Closer to Gym)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (High)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (High)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (Low)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room C-135 (Low)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (High)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (High)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (Low)	6/3/13	< 1
Bell-Lincoln EC	1st Floor Hallway, Across from Room D-113 (Low)	6/3/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Brent ES	3rd Floor Hallway, Across from Room 310	4/1/13	< 1
Brent ES	3rd Floor Hallway, Across from Room 310	4/1/13	< 1
Brent ES	3rd Floor Hallway, Across from Room 304	4/1/13	< 1
Brent ES	3rd Floor Hallway, Across from Room 304	4/1/13	< 1
Brent ES	2nd Floor Hallway, Across from Room 204	4/1/13	< 1
Brent ES	2nd Floor Hallway, Across from Room 204	4/1/13	< 1
Brent ES	2nd Floor Hallway, Across from Room 210	4/1/13	< 1
Brent ES	2nd Floor Hallway, Across from Room 210	4/1/13	< 1
Brent ES	2nd Floor, Inside Room 202	4/1/13	< 1
Brent ES	2nd Floor, Inside Room 202	4/1/13	< 1
Brent ES	2nd Floor, Inside Room 204	4/1/13	< 1
Brent ES	2nd Floor, Inside Room 204	4/1/13	< 1
Brent ES	1st Floor, Inside Room 102	4/1/13	< 1
Brent ES	1st Floor, Inside Room 102	4/1/13	< 1
Brent ES	1st Floor, Inside Room 104	4/1/13	< 1
Brent ES	1st Floor, Inside Room 104	4/1/13	< 1
Brent ES	1st Floor, Inside Room 108	4/1/13	< 1
Brent ES	1st Floor, Inside Room 108	4/1/13	< 1
Brent ES	1st Floor, Inside Room 110	4/1/13	< 1
Brent ES	1st Floor, Inside Room 110	4/1/13	< 1
Brent ES	1st Floor, Inside Room 116	4/1/13	< 1
Brent ES	1st Floor, Inside Room 116	4/1/13	< 1

Brent ES	1st Floor, Inside Room 118	4/1/13	< 1
Brent ES	1st Floor, Inside Room 118	4/1/13	< 1
Brent ES	1st Floor Hallway Leading to Parking Lot	4/1/13	< 1
Brent ES	1st Floor Hallway Leading to Parking Lot	4/1/13	< 1
Brent ES	1st Floor, Inside Cafeteria	4/1/13	< 1
Brent ES	1st Floor, Inside Cafeteria	4/1/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Brightwood ES	3rd Floor, by Room 307 (High)	3/13/13	< 1
Brightwood ES	3rd Floor, by Room 307 (High)	3/13/13	< 1
Brightwood ES	3rd Floor, by Room 307 (Low)	3/13/13	< 1
Brightwood ES	3rd Floor, by Room 307 (Low)	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 309	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 309	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 308	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 308	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 310	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 310	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 312	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 312	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 314	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 314	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 316	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 316	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 321	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 321	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 325	3/13/13	< 1
Brightwood ES	3rd Floor, Inside Room 325	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 206	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 206	3/13/13	< 1
Brightwood ES	2nd Floor, by Room 211 (High)	3/13/13	< 1
Brightwood ES	2nd Floor, by Room 211 (High)	3/13/13	< 1
Brightwood ES	2nd Floor, by Room 211 (Low)	3/13/13	< 1
Brightwood ES	2nd Floor, by Room 211 (Low)	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 213	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 213	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 208	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 208	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 210	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 210	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 212	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 212	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 214	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 214	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 210	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 210	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 218	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 218	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 231	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 231	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 224	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 224	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 228	3/13/13	< 1
Brightwood ES	2nd Floor, Inside Room 228	3/13/13	< 1

Browne MS	1st Floor Hallway, Next to Room 1-124	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-119	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-119	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-111	5/13/13	2.5
Browne MS	1st Floor, Inside Room 1-111	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-099	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-099	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-112	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-112	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-128	5/13/13	< 1
Browne MS	1st Floor, Inside Room 1-128	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-108	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-108	5/13/13	< 1
Browne MS	1st Floor, Inside Room 108	5/13/13	< 1
Browne MS	1st Floor, Inside Room 108	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-157	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-157	5/13/13	< 1
Browne MS	1st Floor, Inside Room 137	5/13/13	2.5
Browne MS	1st Floor, Inside Room 137	5/13/13	4.8
Browne MS	1st Floor Hallway, Next to Room 1-179	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-179	5/13/13	2.6
Browne MS	1st Floor Hallway, Near Room 1-193	5/13/13	< 1
Browne MS	1st Floor Hallway, Near Room 1-193	5/13/13	< 1
Browne MS	1st Floor Hallway, Next to Room 1-207	5/13/13	1.6
Browne MS	1st Floor Hallway, Next to Room 1-207	5/13/13	3.7
Browne MS	Basement Floor, Inside Gym	5/13/13	1.7
Browne MS	Basement Floor, Inside Gym	5/13/13	3.4
Browne MS	Basement Floor, Inside Girls Locker Room	5/13/13	2
Browne MS	Basement Floor, Inside Girls Locker Room	5/13/13	2.2
Browne MS	Basement Floor, Inside Boys Locker Room	5/13/13	2.5
Browne MS	Basement Floor, Inside Boys Locker Room	5/13/13	3.4
Browne MS	Basement Floor, Next to Custodian's Closet	5/13/13	3
Browne MS	Basement Floor, Next to Custodian's Closet	5/13/13	4.1
Browne MS	Basement Floor, Inside Cafeteria, Near	5/13/13	3.1
Browne MS	Basement Floor, Inside Cafeteria, Near	5/13/13	3.3
Browne MS	Basement Floor, Inside Cafeteria, Near Stair H	5/13/13	3.5
Browne MS	Basement Floor, Inside Cafeteria, Near Stair H	5/13/13	2.4

		Percentage of Passed Samples	
		Percentage of Failed Samples	

Bunker Hill ES	2nd Floor Hallway, Near Room 205	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Room 205	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Teachers' Lounge	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Teachers' Lounge	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Southwest Stairs	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Southwest Stairs	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Northwest Stairs	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Northwest Stairs	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 105	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 105	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 106	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 106	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Room 103	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Room 103	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 107	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 107	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 103	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 103	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Auditorium	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near Auditorium	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Southeast Stairs	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Southeast Stairs	3/11/13	< 1
Bunker Hill ES	2nd Floor Hallway, Near Northeast Stairs	3/11/13	< 1

Bunker Hill ES	2nd Floor Hallway, Near Northeast Stairs	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near North Stairs	3/11/13	< 1
Bunker Hill ES	1st Floor Hallway, Near North Stairs	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 126	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 126	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 118	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 118	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 124	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 124	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 119	3/11/13	< 1
Bunker Hill ES	1st Floor, Inside Room 119	3/11/13	< 1
Bunker Hill ES	Basement Floor, Inside Lunch Room	3/11/13	< 1
Bunker Hill ES	Basement Floor, Inside Lunch Room	3/11/13	< 1

		Percentage of Passed Samples	Percentage of Failed Samples
--	--	------------------------------	------------------------------

Burrville ES	2nd Floor, by Library (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by Library (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by Library (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Library (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Gymnasium	4/23/13	< 1
Burrville ES	2nd Floor, by Gymnasium	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 241	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 241	4/23/13	< 1
Burrville ES	2nd Floor, Inside Teachers' Lounge	4/23/13	1.2
Burrville ES	2nd Floor, Inside Teachers' Lounge	4/23/13	2.6
Burrville ES	2nd Floor, by the Exit (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by the Exit (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by the Exit (High)	4/23/13	< 1
Burrville ES	2nd Floor, by the Exit (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Room 228 (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Room 228 (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Room 228 (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by Room 228 (Low)	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 228	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 228	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 227	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 227	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 224	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 224	4/23/13	< 1
Burrville ES	2nd Floor, Inside Art Room A	4/23/13	< 1
Burrville ES	2nd Floor, Inside Art Room A	4/23/13	< 1
Burrville ES	2nd Floor, Inside Art Room B	4/23/13	< 1
Burrville ES	2nd Floor, Inside Art Room B	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 221	4/23/13	< 1
Burrville ES	2nd Floor, Inside Room 221	4/23/13	< 1
Burrville ES	2nd Floor, by Boys Restroom (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Boys Restroom (High)	4/23/13	< 1
Burrville ES	2nd Floor, by Boys Restroom (Low)	4/23/13	< 1
Burrville ES	2nd Floor, by Boys Restroom (Low)	4/23/13	< 1
Burrville ES	2nd Floor, Inside Boys Locker Room	4/23/13	1.6
Burrville ES	2nd Floor, Inside Boys Locker Room	4/23/13	1
Burrville ES	2nd Floor, Inside Girls Locker Room	4/23/13	1.5
Burrville ES	2nd Floor, Inside Girls Locker Room	4/23/13	4.6
Burrville ES	2nd Floor, In the Main Lobby (High)	4/23/13	< 1
Burrville ES	2nd Floor, In the Main Lobby (High)	4/23/13	< 1
Burrville ES	2nd Floor, In the Main Lobby (Low)	4/23/13	2.8

Burrrville ES	2nd Floor, In the Main Lobby (Low)	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 114	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 114	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 113	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 113	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 111	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 111	4/23/13	< 1
Burrrville ES	1st Floor, by Room 111 (High)	4/23/13	< 1
Burrrville ES	1st Floor, by Room 111 (High)	4/23/13	< 1
Burrrville ES	1st Floor, by Room 111 (Low)	4/23/13	< 1
Burrrville ES	1st Floor, by Room 111 (Low)	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 110	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 110	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 115	4/23/13	< 1
Burrrville ES	1st Floor, Inside Room 115	4/23/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Burroughs ES	Basement Floor Hallway, Next to Room 19	3/19/13	< 1
Burroughs ES	Basement Floor Hallway, Next to Room 19	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 19	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 19	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 20	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 20	3/19/13	< 1
Burroughs ES	Basement Floor Hallway, Next to Room 20	3/19/13	< 1
Burroughs ES	Basement Floor Hallway, Next to Room 20	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 21	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 21	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 22	3/19/13	< 1
Burroughs ES	Basement Floor, Inside Room 22	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Across from Room 3	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Across from Room 3	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 8	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 8	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 9	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 9	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 14	3/19/13	< 1
Burroughs ES	1st Floor Hallway, Next to Room 14	3/19/13	< 1
Burroughs ES	1st Floor (new wing) Hallway, Across from Room 27	3/19/13	< 1
Burroughs ES	1st Floor (new wing) Hallway, Across from Room 27	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Sink Inside Room 34	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Sink Inside Room 34	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Inside Room 35	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Inside Room 35	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Inside Room 25	3/19/13	< 1
Burroughs ES	1st Floor (new wing), Inside Room 25	3/19/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

C.W. Harris ES	1st Floor Hallway, Across from Custodian's Office	3/22/13	< 1
C.W. Harris ES	1st Floor Hallway, Across from Custodian's Office	3/22/13	< 1
C.W. Harris ES	1st Floor, Inside Room 149	3/22/13	< 1

C.W. Harris ES	1st Floor, Inside Room 149	3/22/13	< 1
C.W. Harris ES	1st Floor, Inside Room 153	3/22/13	< 1
C.W. Harris ES	1st Floor, Inside Room 153	3/22/13	< 1
C.W. Harris ES	1st Floor, Inside Multi-Purpose Room	3/22/13	< 1
C.W. Harris ES	1st Floor, Inside Multi-Purpose Room	3/22/13	< 1
C.W. Harris ES	1st Floor Hallway, Across from Health Suite	3/22/13	< 1
C.W. Harris ES	1st Floor Hallway, Across from Health Suite	3/22/13	< 1
C.W. Harris ES	1st Floor Hallway, Inside Health Suite	3/22/13	< 1
C.W. Harris ES	1st Floor Hallway, Inside Health Suite	3/22/13	< 1
C.W. Harris ES	2nd Floor Hallway, Across from Room 218	3/22/13	< 1
C.W. Harris ES	2nd Floor Hallway, Across from Room 218	3/22/13	< 1
C.W. Harris ES	2nd Floor Hallway, Across from Room 246	3/22/13	< 1
C.W. Harris ES	2nd Floor Hallway, Across from Room 246	3/22/13	< 1

			Percentage of Passed Samples
			Percentage of Failed Samples

Cleveland ES	3rd Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	3rd Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	3rd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	3rd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 308	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 308	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 304	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 304	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 313	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 313	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 302	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 302	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 315	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 315	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 301	2/20/13	< 1
Cleveland ES	3rd Floor, Inside Room 301	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 218	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 218	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 203	2/20/13	2.3
Cleveland ES	2nd Floor, Inside Room 203	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 212	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 212	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 207	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 207	2/20/13	< 1
Cleveland ES	2nd Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	2nd Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	2nd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	2nd Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	1st Floor Hallway, Across from Elevator (High)	2/20/13	< 1

Cleveland ES	1st Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	1st Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	1st Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 111	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 111	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 106	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 106	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 103	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 103	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 115	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 115	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 117	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 117	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 120	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 120	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 101	2/20/13	< 1
Cleveland ES	1st Floor, Inside Room 101	2/20/13	< 1
Cleveland ES	Ground Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	Ground Floor Hallway, Across from Elevator (High)	2/20/13	< 1
Cleveland ES	Ground Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	Ground Floor Hallway, Across from Elevator (Low)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (1)	2/20/13	1.7
Cleveland ES	2nd Floor, Inside Room 216 (1)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (2)	2/20/13	2
Cleveland ES	2nd Floor, Inside Room 216 (2)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (3)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (3)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (4)	2/20/13	< 1
Cleveland ES	2nd Floor, Inside Room 216 (4)	2/20/13	< 1

Percentage of Passed Samples			
-------------------------------------	--	--	--

Percentage of Failed Samples			
-------------------------------------	--	--	--

Davis ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1
Davis ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1
Davis ES	1st Floor Hallway, Next to Room 118	1/25/13	< 1
Davis ES	1st Floor Hallway, Next to Room 118	1/25/13	< 1
Davis ES	1st Floor Entrance, Next to Security Desk	1/25/13	< 1
Davis ES	1st Floor Entrance, Next to Security Desk	1/25/13	< 1
Davis ES	1st Floor Hallway, Next to Room 104	1/25/13	< 1
Davis ES	1st Floor Hallway, Next to Room 104	1/25/13	< 1
Davis ES	Basement Floor, Cafeteria, Next to Fuse Box	1/25/13	< 1
Davis ES	Basement Floor, Cafeteria, Next to Fuse Box	1/25/13	< 1
Davis ES	Basement Floor, Cafeteria, Next to Storage Room 15	1/25/13	< 1
Davis ES	Basement Floor, Cafeteria, Next to Storage Room 15	1/25/13	< 1

Davis ES	1st Floor, Inside Room 101	1/25/13	< 1	
Davis ES	1st Floor, Inside Room 101	1/25/13	< 1	
Davis ES	1st Floor, Teachers' Lounge, Near Room 104	1/25/13	2.5	
Davis ES	1st Floor, Teachers' Lounge, Near Room 104	1/25/13		15
Davis ES	1st Floor, Teachers' Lounge, Near Room 104 - Retest	2/7/13	3	
Davis ES	1st Floor, Teachers' Lounge, Near Room 104 - Retest	2/7/13	2.3	
Davis ES	1st Floor, Inside Room 115 Kindergarten	1/25/13	< 1	
Davis ES	1st Floor, Inside Room 115 Kindergarten	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 218A	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 218A	1/25/13	< 1	
Davis ES	Basement Hallway, Next to Room 16A	1/25/13	< 1	
Davis ES	Basement Hallway, Next to Room 16A	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 212	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 212	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 204	1/25/13	< 1	
Davis ES	2nd Floor Hallway, Next to Room 204	1/25/13	< 1	
Davis ES	2nd Floor, Teachers' Lounge, Near Room 218A	1/25/13	< 1	
Davis ES	2nd Floor, Teachers' Lounge, Near Room 218A	1/25/13	< 1	
Davis ES	1st Floor, Inside Room 105	1/25/13	< 1	
Davis ES	1st Floor, Inside Room 105	1/25/13	< 1	
Davis ES	1st Floor, Inside Principal's Office	1/25/13	< 1	
Davis ES	1st Floor, Inside Principal's Office	1/25/13	< 1	
Davis ES	1st Floor, Inside Health Suite	1/25/13	< 1	
Davis ES	1st Floor, Inside Health Suite	1/25/13	< 1	
		Percentage of Passed Samples		
		Percentage of Failed Samples		
Deal MS	3rd Floor Hallway, Next to Room W300 (High)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room W300 (High)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room W300 (Low)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room W300 (Low)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room E300 (High)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room E300 (High)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room E300 (Low)	2/13/13	< 1	
Deal MS	3rd Floor Hallway, Next to Room E300 (Low)	2/13/13	< 1	
Deal MS	2nd Floor Hallway, Next to Room E200 (High)	2/13/13	< 1	
Deal MS	2nd Floor Hallway, Next to Room E200 (High)	2/13/13	< 1	
Deal MS	2nd Floor Hallway, Next to Room E200 (Low)	2/13/13	< 1	
Deal MS	2nd Floor Hallway, Next to Room E200 (Low)	2/13/13	< 1	

Deal MS	2nd Floor Hallway, Next to Room W200 (High)	2/13/13	< 1
Deal MS	2nd Floor Hallway, Next to Room W200 (High)	2/13/13	< 1
Deal MS	2nd Floor Hallway, Next to Room W200 (Low)	2/13/13	< 1
Deal MS	2nd Floor Hallway, Next to Room W200 (Low)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room W100 (High)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room W100 (High)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room W100 (Low)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room W100 (Low)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room E100 (High)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room E100 (High)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room E100 (Low)	2/13/13	< 1
Deal MS	1st Floor Hallway, Next to Room E100 (Low)	2/13/13	< 1
Deal MS	Basement Floor, Outside Cafeteria (High)	2/13/13	< 1
Deal MS	Basement Floor, Outside Cafeteria (High)	2/13/13	< 1
Deal MS	Basement Floor, Outside Cafeteria (Low)	2/13/13	< 1
Deal MS	Basement Floor, Outside Cafeteria (Low)	2/13/13	< 1
Deal MS	Basement Hallway, Next to Room CG42 (High)	2/13/13	< 1
Deal MS	Basement Hallway, Next to Room CG42 (High)	2/13/13	< 1
Deal MS	Basement Hallway, Next to Room CG42 (Low)	2/13/13	< 1
Deal MS	Basement Hallway, Next to Room CG42 (Low)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (High)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1
Deal MS	Basement Floor, Inside Gymnasium (Low)	2/13/13	< 1
Deal MS	Basement Hallway, Outside Coach's Office (High)	2/13/13	< 1
Deal MS	Basement Hallway, Outside Coach's Office (High)	2/13/13	< 1
Deal MS	Basement Hallway, Outside Coach's Office (Low)	2/13/13	< 1
Deal MS	Basement Hallway, Outside Coach's Office (Low)	2/13/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Drew ES	4th Floor Hallway, by Room 407 (High)	4/8/13	< 1
Drew ES	4th Floor Hallway, by Room 407 (High)	4/8/13	< 1

Drew ES	4th Floor Hallway, by Room 407 (Low)	4/8/13	< 1
Drew ES	4th Floor Hallway, by Room 407 (Low)	4/8/13	< 1
Drew ES	4th Floor Hallway, by Room 400	4/8/13	< 1
Drew ES	4th Floor Hallway, by Room 400	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 300 (High)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 300 (High)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 300 (Low)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 300 (Low)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 307 (High)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 307 (High)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 307 (Low)	4/8/13	< 1
Drew ES	3rd Floor Hallway, by Room 307 (Low)	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 205	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 205	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 207	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 207	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 207 (High)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 207 (High)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 207 (Low)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 207 (Low)	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 209	4/8/13	< 1
Drew ES	2nd Floor, Inside Room 209	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 200 (High)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 200 (High)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 200 (Low)	4/8/13	< 1
Drew ES	2nd Floor Hallway, by Room 200 (Low)	4/8/13	< 1
Drew ES	2nd Floor, Inside Teachers' Lounge	4/8/13	< 1
Drew ES	2nd Floor, Inside Teachers' Lounge	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite (High)	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite (High)	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite (Low)	4/8/13	< 1
Drew ES	1st Floor, Inside Health Suite (Low)	4/8/13	< 1
Drew ES	1st Floor, Inside Room 104	4/8/13	< 1
Drew ES	1st Floor, Inside Room 104	4/8/13	< 1
Drew ES	1st Floor, Inside Room 108	4/8/13	< 1
Drew ES	1st Floor, Inside Room 108	4/8/13	< 1
Drew ES	1st Floor, Inside Room 105	4/8/13	< 1
Drew ES	1st Floor, Inside Room 105	4/8/13	< 1
Drew ES	1st Floor Hallway, by Room 105 (High)	4/8/13	< 1
Drew ES	1st Floor Hallway, by Room 105 (High)	4/8/13	< 1
Drew ES	1st Floor Hallway, by Room 105 (Low)	4/8/13	< 1
Drew ES	1st Floor Hallway, by Room 105 (Low)	4/8/13	< 1
Drew ES	1st Floor, Inside Room 107	4/8/13	< 1
Drew ES	1st Floor, Inside Room 107	4/8/13	< 1
Drew ES	1st Floor, Inside Room 106	4/8/13	< 1
Drew ES	1st Floor, Inside Room 106	4/8/13	< 1
Drew ES	1st Floor, Inside Lunch Room	4/8/13	< 1
Drew ES	1st Floor, Inside Lunch Room	4/8/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Dunbar SHS	13th Floor, Next to West Stairwell	6/13/13	< 1
Dunbar SHS	13th Floor, Next to West Stairwell	6/13/13	< 1

Dunbar SHS	12th Floor, Next to East Stairwell	6/13/13	4.3
Dunbar SHS	12th Floor, Next to East Stairwell	6/13/13	3.5
Dunbar SHS	10th Floor, Next to East Stairwell	6/13/13	< 1
Dunbar SHS	10th Floor, Next to East Stairwell	6/13/13	< 1
Dunbar SHS	9th Floor, Next to West Stairwell	6/13/13	< 1
Dunbar SHS	9th Floor, Next to West Stairwell	6/13/13	< 1
Dunbar SHS	7th Floor, Next to West Stairwell	6/13/13	< 1
Dunbar SHS	7th Floor, Next to West Stairwell	6/13/13	< 1
Dunbar SHS	6th Floor, Next to East Stairwell	6/13/13	< 1
Dunbar SHS	6th Floor, Next to East Stairwell	6/13/13	< 1

Dunbar SHS	5th Floor, Next to West Stairwell in Cafeteria	6/13/13	< 1
------------	--	---------	-----

Dunbar SHS	5th Floor, Next to West Stairwell in Cafeteria	6/13/13	< 1
------------	--	---------	-----

Dunbar SHS	4th Floor, Next to East Stairwell in Media Center	6/13/13	< 1
------------	---	---------	-----

Dunbar SHS	4th Floor, Next to East Stairwell in Media Center	6/13/13	< 1
------------	---	---------	-----

Dunbar SHS	3rd Floor, Next to West Stairwell	6/13/13	< 1
------------	-----------------------------------	---------	-----

Dunbar SHS	3rd Floor, Next to West Stairwell	6/13/13	< 1
------------	-----------------------------------	---------	-----

Dunbar SHS	2nd Floor, Next to Main Entrance	6/13/13	< 1
------------	----------------------------------	---------	-----

Dunbar SHS	2nd Floor, Next to Main Entrance	6/13/13	< 1
------------	----------------------------------	---------	-----

Dunbar SHS	2nd Floor Hallway, Next to Instrumental Room	6/13/13	< 1
------------	--	---------	-----

Dunbar SHS	2nd Floor Hallway, Next to Instrumental Room	6/13/13	< 1
------------	--	---------	-----

Dunbar SHS	Inside Main Office	6/13/13	< 1
------------	--------------------	---------	-----

Dunbar SHS	Inside Main Office	6/13/13	< 1
------------	--------------------	---------	-----

Dunbar SHS	Inside Community Room	6/13/13	< 1
------------	-----------------------	---------	-----

Dunbar SHS	Inside Community Room	6/13/13	< 1
------------	-----------------------	---------	-----

Dunbar SHS	2nd Floor Hallway, Across from Room 206	6/13/13	< 1
------------	---	---------	-----

Dunbar SHS	2nd Floor Hallway, Across from Room 206	6/13/13	< 1
------------	---	---------	-----

Dunbar SHS	In Gym Hallway, Near Handicap Ramp	6/13/13	< 1
------------	------------------------------------	---------	-----

Dunbar SHS	In Gym Hallway, Near Handicap Ramp	6/13/13	< 1
------------	------------------------------------	---------	-----

Dunbar SHS	In Gym Hallway, Across from Gym Entrance	6/13/13	< 1
------------	--	---------	-----

Dunbar SHS	In Gym Hallway, Across from Gym Entrance	6/13/13	< 1
------------	--	---------	-----

		Percentage of Passed Samples	
		Percentage of Failed Samples	

Eastern SHS	Inside Cafeteria (High)	6/7/13	< 1
-------------	-------------------------	--------	-----

Eastern SHS	Inside Cafeteria (High)	6/7/13	< 1
-------------	-------------------------	--------	-----

Eastern SHS	Inside Cafeteria (Low)	6/7/13	< 1
-------------	------------------------	--------	-----

Eastern SHS	Inside Cafeteria (Low)	6/7/13	< 1
-------------	------------------------	--------	-----

Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1
-------------	---	--------	-----

Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1
-------------	---	--------	-----

Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1
-------------	--	--------	-----

Eastern SHS	4th Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1
-------------	--	--------	-----

Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1
-------------	---	--------	-----

Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (High)	6/7/13	< 1
-------------	---	--------	-----

Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1
Eastern SHS	3rd Floor Hallway, between Girls and Boys Restroom (Low)	6/7/13	< 1
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (High)	6/7/13	< 1
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (High)	6/7/13	< 1
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (Low)	6/7/13	< 1
Eastern SHS	4th Floor Hallway, Opposite to Room E415 (Low)	6/7/13	< 1
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (High)	6/7/13	< 1
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (High)	6/7/13	< 1
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (Low)	6/7/13	< 1
Eastern SHS	3rd Floor Hallway, Opposite to Room 316 (Low)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (High)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (High)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (Low)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room E218 (Low)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (High)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (High)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (Low)	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room W212 (Low)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (High)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (High)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (Low)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room W130 (Low)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room E124	6/7/13	< 1
Eastern SHS	1st Floor Hallway, Opposite to Room E124	6/7/13	< 1
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (High)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (High)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (Low)	6/7/13	< 1
Eastern SHS	1st Floor Hallway, by Room G106 and Gym (Low)	6/7/13	< 1

Eastern SHS	2nd Floor Hallway, Opposite to Room E227	6/7/13	< 1
Eastern SHS	2nd Floor Hallway, Opposite to Room E227	6/7/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Eaton ES	3rd Floor Hallway, by Room 313	2/1/13	< 1
Eaton ES	3rd Floor Hallway, by Room 313	2/1/13	< 1
Eaton ES	3rd Floor Hallway, by Room 303	2/1/13	< 1
Eaton ES	3rd Floor Hallway, by Room 303	2/1/13	< 1
Eaton ES	2nd Floor Hallway, by Room 208	2/1/13	< 1
Eaton ES	2nd Floor Hallway, by Room 208	2/1/13	< 1
Eaton ES	2nd Floor Hallway, by Room 218	2/1/13	< 1
Eaton ES	2nd Floor Hallway, by Room 218	2/1/13	< 1
Eaton ES	1st Floor Hallway, by Room 120	2/1/13	< 1
Eaton ES	1st Floor Hallway, by Room 120	2/1/13	< 1
Eaton ES	1st Floor, by Main Entrance (High)	2/1/13	< 1
Eaton ES	1st Floor, by Main Entrance (High)	2/1/13	< 1
Eaton ES	1st Floor, by Main Entrance (Low)	2/1/13	< 1
Eaton ES	1st Floor, by Main Entrance (Low)	2/1/13	< 1
Eaton ES	1st Floor, Inside Health Suite	2/1/13	< 1
Eaton ES	1st Floor, Inside Health Suite	2/1/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Eliot-Hine MS	1st Floor Hallway, Next to Main Office	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Next to Main Office	5/10/13	< 1
Eliot-Hine MS	1st Floor, Next to Room 1-166	5/10/13	< 1
Eliot-Hine MS	1st Floor, Next to Room 1-166	5/10/13	< 1
Eliot-Hine MS	1st Floor, at Entrance to Gym	5/10/13	< 1
Eliot-Hine MS	1st Floor, at Entrance to Gym	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Across from Room 1-100 (Custodian's Closet)	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Across from Room 1-100 (Custodian's Closet)	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Next to Army ROTC Office	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Next to Army ROTC Office	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Across from Ladies' Room	5/10/13	< 1
Eliot-Hine MS	1st Floor Hallway, Across from Ladies' Room	5/10/13	< 1
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-262	5/10/13	< 1
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-262	5/10/13	< 1
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-255	5/10/13	< 1
Eliot-Hine MS	3rd Floor Hallway, Next to Room 3-255	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-210	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-210	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-206	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-206	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-198	5/10/13	< 1
Eliot-Hine MS	2nd Floor Hallway, Next to Room 2-198	5/10/13	< 1
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Entrance	5/10/13	< 1
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Entrance	5/10/13	< 1

Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Exit to Stairwell	5/10/13	< 1
Eliot-Hine MS	Basement Floor, Inside Cafeteria, Near Exit to Stairwell	5/10/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Ellington SHS	3rd Floor Hallway, by Room 306	5/29/13	< 1
Ellington SHS	3rd Floor Hallway, by Room 306	5/29/13	< 1
Ellington SHS	2nd Floor Hallway, by Staff Lounge	5/29/13	< 1
Ellington SHS	2nd Floor Hallway, by Staff Lounge	5/29/13	< 1
Ellington SHS	2nd Floor Hallway, by Room 254A	5/29/13	< 1
Ellington SHS	2nd Floor Hallway, by Room 254A	5/29/13	< 1
Ellington SHS	1st Floor Hallway, by Office of Director of Admissions	5/29/13	< 1
Ellington SHS	1st Floor Hallway, by Office of Director of Admissions	5/29/13	< 1
Ellington SHS	1st Floor Hallway, by Stage Left & Rehearsal Hall Door	5/29/13	< 1
Ellington SHS	1st Floor Hallway, by Stage Left & Rehearsal Hall Door	5/29/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Evans MS	3rd Floor Hallway, by Room 329	5/28/13	< 1
Evans MS	3rd Floor Hallway, by Room 329	5/28/13	< 1
Evans MS	3rd Floor Hallway, by Room 317	5/28/13	< 1
Evans MS	3rd Floor Hallway, by Room 317	5/28/13	< 1
Evans MS	2nd Floor Hallway, by Room 211	5/28/13	< 1
Evans MS	2nd Floor Hallway, by Room 211	5/28/13	< 1
Evans MS	2nd Floor Hallway, by Staff Restroom	5/28/13	< 1
Evans MS	2nd Floor Hallway, by Staff Restroom	5/28/13	< 1
Evans MS	1st Floor Hallway, by Room 150	5/28/13	< 1
Evans MS	1st Floor Hallway, by Room 150	5/28/13	< 1
Evans MS	1st Floor Hallway, by Teachers' Lavatory	5/28/13	< 1
Evans MS	1st Floor Hallway, by Teachers' Lavatory	5/28/13	< 1
Evans MS	Basement Floor, Inside Gym	5/28/13	< 1
Evans MS	Basement Floor, Inside Gym	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Room 024	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Room 024	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Teachers' Lavatory	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Teachers' Lavatory	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Room 078	5/28/13	< 1
Evans MS	Basement Floor Hallway, by Room 078	5/28/13	< 1
Evans MS	Sub-Basement Floor, Inside Cafeteria	5/28/13	< 1
Evans MS	Sub-Basement Floor, Inside Cafeteria	5/28/13	< 1
Evans MS	Sub-Basement Floor, Inside Multi-Purpose Room	5/28/13	< 1
Evans MS	Sub-Basement Floor, Inside Multi-Purpose Room	5/28/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Ferebee Hope ES	4th Floor Hallway, Across from Room 406	5/8/13	< 1
Ferebee Hope ES	4th Floor Hallway, Across from Room 406	5/8/13	< 1

Ferebee Hope ES	4th Floor Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	4th Floor Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	4th Floor Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	4th Floor Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	4th Floor Hallway, Across from Room 402	5/8/13	2.2
Ferebee Hope ES	4th Floor Hallway, Across from Room 402	5/8/13	1.5
Ferebee Hope ES	3rd Floor Hallway, Across from Room 306	5/8/13	< 1
Ferebee Hope ES	3rd Floor Hallway, Across from Room 306	5/8/13	< 1
Ferebee Hope ES	3rd Floor Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	3rd Floor Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	3rd Floor Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	3rd Floor Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Across from Room 206	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Across from Room 206	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Women's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor (Main Bldg) Hallway, Next to Boy's Room	5/8/13	< 1
Ferebee Hope ES	1st Floor, at Entrance to Gym (Closer to Exit)	5/8/13	< 1
Ferebee Hope ES	1st Floor, at Entrance to Gym (Closer to Exit)	5/8/13	< 1
Ferebee Hope ES	1st Floor, at Entrance to Gym	5/8/13	< 1
Ferebee Hope ES	1st Floor, at Entrance to Gym	5/8/13	< 1
Ferebee Hope ES	1st Floor, Inside Boys Locker Room	5/8/13	< 1
Ferebee Hope ES	1st Floor, Inside Boys Locker Room	5/8/13	< 1
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Bldg D	5/8/13	< 1
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Bldg D	5/8/13	< 1
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Men's Room	5/8/13	< 1
Ferebee Hope ES	1st Floor "Yellow Hallway", Close to Men's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor, Building D, Next to Men's Room	5/8/13	< 1
Ferebee Hope ES	2nd Floor, Building D, Next to Men's Room	5/8/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Francis MS	3rd Floor, by Room 303	3/27/13	< 1
Francis MS	3rd Floor, by Room 303	3/27/13	< 1
Francis MS	3rd Floor, by Room 304	3/27/13	< 1
Francis MS	3rd Floor, by Room 304	3/27/13	< 1
Francis MS	2nd Floor, by Room 204	3/27/13	< 1
Francis MS	2nd Floor, by Room 204	3/27/13	< 1
Francis MS	1st Floor, by Main Office	3/27/13	< 1
Francis MS	1st Floor, by Main Office	3/27/13	< 1
Francis MS	1st Floor, Inside Room 108	3/27/13	< 1
Francis MS	1st Floor, Inside Room 108	3/27/13	< 1
Francis MS	1st Floor, Inside Room 110	3/27/13	< 1
Francis MS	1st Floor, Inside Room 110	3/27/13	< 1

Francis MS	1st Floor, Inside Room 107	3/27/13	< 1
Francis MS	1st Floor, Inside Room 107	3/27/13	< 1
Francis MS	1st Floor, Inside Room 105	3/27/13	< 1
Francis MS	1st Floor, Inside Room 105	3/27/13	< 1
Francis MS	1st Floor, Inside Room 103	3/27/13	< 1
Francis MS	1st Floor, Inside Room 103	3/27/13	< 1
Francis MS	1st Floor, Inside Room 100	3/27/13	< 1
Francis MS	1st Floor, Inside Room 100	3/27/13	< 1
Francis MS	1st Floor, Inside Teachers' Room	3/27/13	< 1
Francis MS	1st Floor, Inside Teachers' Room	3/27/13	< 1
Francis MS	1st Floor, Inside Lunch Room	3/27/13	< 1
Francis MS	1st Floor, Inside Lunch Room	3/27/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Garfield ES	2nd Floor Hallway, by Ladder to Roof	3/13/13	< 1
Garfield ES	2nd Floor Hallway, by Ladder to Roof	3/13/13	< 1
Garfield ES	2nd Floor Hallway, by Teachers' Lounge	3/13/13	6
Garfield ES	2nd Floor Hallway, by Teachers' Lounge	3/13/13	3
Garfield ES	2nd Floor Hallway, by Boys Restroom	3/13/13	< 1
Garfield ES	2nd Floor Hallway, by Boys Restroom	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Main Office	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Main Office	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Room 104	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Room 104	3/13/13	< 1
Garfield ES	1st Floor, Inside Nurse's Suite	3/13/13	< 1
Garfield ES	1st Floor, Inside Nurse's Suite	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Teachers' Lounge	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Teachers' Lounge	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Boys Restroom	3/13/13	< 1
Garfield ES	1st Floor Hallway, by Boys Restroom	3/13/13	< 1
Garfield ES	1st Floor, Inside Kindergarten, Room 102	3/13/13	< 1
Garfield ES	1st Floor, Inside Kindergarten, Room 102	3/13/13	< 1
Garfield ES	1st Floor, Inside Kindergarten, Room 110	3/13/13	< 1
Garfield ES	1st Floor, Inside Kindergarten, Room 110	3/13/13	< 1
Garfield ES	Basement Floor, Inside Lunch Room, by Restrooms	3/13/13	< 1
Garfield ES	Basement Floor, Inside Lunch Room, by Restrooms	3/13/13	< 1
Garfield ES	Basement Floor, Inside Lunch Room, by Restrooms	3/13/13	< 1
Garfield ES	Kitchen Wall	3/13/13	< 1
Garfield ES	Basement Floor, Inside Lunch Room, by Kitchen Wall	3/13/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Garnet-Patterson MS	Next to Exit, Inside Cafeteria	4/17/13	1.4
Garnet-Patterson MS	Next to Exit, Inside Cafeteria	4/17/13	< 1
Garnet-Patterson MS	Inside Cafeteria with Broken Knob	4/17/13	< 1
Garnet-Patterson MS	Inside Cafeteria with Broken Knob	4/17/13	< 1
Garnet-Patterson MS	1st Floor Hallway, Across from Room 106	4/17/13	< 1
Garnet-Patterson MS	1st Floor Hallway, Across from Room 106	4/17/13	< 1
Garnet-Patterson MS	1st Floor Hallway, Next to Room 110	4/17/13	< 1
Garnet-Patterson MS	1st Floor Hallway, Next to Room 110	4/17/13	< 1
Garnet-Patterson MS	2nd Floor Hallway, Next to Nurse's Suite	4/17/13	< 1
Garnet-Patterson MS	2nd Floor Hallway, Next to Nurse's Suite	4/17/13	< 1

Garnet-Patterson MS	2nd Floor Hallway, Next to Room 216	4/17/13	< 1
Garnet-Patterson MS	2nd Floor Hallway, Next to Room 216	4/17/13	< 1
Garnet-Patterson MS	3rd Floor Hallway, Across from Room 304	4/17/13	< 1
Garnet-Patterson MS	3rd Floor Hallway, Across from Room 304	4/17/13	< 1
Garnet-Patterson MS	3rd Floor Hallway, Next to Room 308	4/17/13	< 1
Garnet-Patterson MS	3rd Floor Hallway, Next to Room 308	4/17/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	

Garrison ES	2nd Floor, by Room 206	4/19/13	< 1
Garrison ES	2nd Floor, by Room 206	4/19/13	< 1
Garrison ES	2nd Floor, by Room 201	4/19/13	< 1
Garrison ES	2nd Floor, by Room 201	4/19/13	< 1
Garrison ES	1st Floor, Inside Health Suite	4/19/13	< 1
Garrison ES	1st Floor, Inside Health Suite	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 110	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 110	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 109	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 109	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 108	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 108	4/19/13	< 1
Garrison ES	1st Floor, by Main Office	4/19/13	< 1
Garrison ES	1st Floor, by Main Office	4/19/13	< 1
Garrison ES	1st Floor, Inside Lunch Room	4/19/13	< 1
Garrison ES	1st Floor, Inside Lunch Room	4/19/13	< 1
Garrison ES	2nd Floor, by Room 212	4/19/13	< 1
Garrison ES	2nd Floor, by Room 212	4/19/13	< 1
Garrison ES	2nd Floor, by Room 217	4/19/13	< 1
Garrison ES	2nd Floor, by Room 217	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 122	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 122	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 128	4/19/13	< 1
Garrison ES	1st Floor, Inside Room 128	4/19/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	

H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 302	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 302	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 303	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 303	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 304	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 304	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 305	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 305	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 310	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 310	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 311	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 311	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 312	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 312	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 313	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 313	6/6/13	< 1

H.D. Cooke ES	1st Floor, Inside Room 341	6/6/13	
H.D. Cooke ES	1st Floor, Inside Room 341	6/6/13	2.7
H.D. Cooke ES	<i>1st Floor, Inside Room 341 - Retest</i>	<i>6/20/13</i>	<i>1</i>
H.D. Cooke ES	<i>1st Floor, Inside Room 341 - Retest</i>	<i>6/20/13</i>	<i>< 1</i>
H.D. Cooke ES	1st Floor, Inside Room 314	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 314	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 202	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 202	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 203	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 203	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 204	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 204	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 205	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 205	6/6/13	< 1
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	2nd Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 210	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 210	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 211	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 211	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 212	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 212	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 213	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 213	6/6/13	< 1
H.D. Cooke ES	2nd Floor, Inside Room 241	6/6/13	3.1
H.D. Cooke ES	2nd Floor, Inside Room 241	6/6/13	2
H.D. Cooke ES	1st Floor, Inside Room 136	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 136	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 132	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 132	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 135	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 135	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 133	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Room 133	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	1st Floor Hallway, by Girls Restroom (Low)	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Gym (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Gym (High)	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Gym (Low)	6/6/13	< 1
H.D. Cooke ES	1st Floor, Inside Gym (Low)	6/6/13	< 1
Percentage of Passed Samples			
Percentage of Failed Samples			
Hamilton School	1st Floor Hallway, by Corner of Kitchen	5/30/13	< 1
Hamilton School	1st Floor Hallway, by Corner of Kitchen	5/30/13	1.2
Hamilton School	1st Floor Hallway, Between Rooms 1019 & 1021	5/30/13	2.5
Hamilton School	1st Floor Hallway, Between Rooms 1019 & 1021	5/30/13	5.4
Hamilton School	1st Floor Hallway, by Room 1014	5/30/13	< 1
Hamilton School	1st Floor Hallway, by Room 1014	5/30/13	< 1

Hamilton School	1st Floor Hallway, by Boys Restroom	5/30/13	2.8
Hamilton School	1st Floor Hallway, by Boys Restroom	5/30/13	2.8
Hamilton School	2nd Floor Hallway, by Room 204	5/30/13	< 1
Hamilton School	2nd Floor Hallway, by Room 204	5/30/13	< 1
Hamilton School	2nd Floor Hallway, by Room 2020	5/30/13	< 1
Hamilton School	2nd Floor Hallway, by Room 2020	5/30/13	< 1
Hamilton School	2nd Floor, Inside Gym, by Boys Restroom	5/30/13	< 1
Hamilton School	2nd Floor, Inside Gym, by Boys Restroom	5/30/13	< 1
Hamilton School	2nd Floor Hallway, by Room 231 & Security		
Hamilton School	Desk	5/30/13	< 1
Hamilton School	2nd Floor Hallway, by Room 231 & Security		
Hamilton School	Desk	5/30/13	< 1
Hamilton School	2nd Floor, by Girls Restroom	5/30/13	< 1
Hamilton School	2nd Floor, by Girls Restroom	5/30/13	< 1
Hamilton School	2nd Floor, by Boys Restroom	5/30/13	1.1
Hamilton School	2nd Floor, by Boys Restroom	5/30/13	1.3
Hamilton School	2nd Floor, by Storage Rooms	5/30/13	< 1
Hamilton School	2nd Floor, by Storage Rooms	5/30/13	< 1
Hamilton School	2nd Floor, Inside Main Office	5/30/13	1.4
Hamilton School	2nd Floor, Inside Main Office	5/30/13	1.6

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Hardy MS	3rd Floor Hallway, by Room 302 (High)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 302 (High)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 302 (Low)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 302 (Low)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 313 (High)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 313 (High)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 313 (Low)	5/2/13	< 1
Hardy MS	3rd Floor Hallway, by Room 313 (Low)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 205 (High)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 205 (High)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 205 (Low)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 205 (Low)	5/2/13	< 1
Hardy MS	2nd Floor, Inside Gymnasium (High)	5/2/13	< 1
Hardy MS	2nd Floor, Inside Gymnasium (High)	5/2/13	< 1
Hardy MS	2nd Floor, Inside Gymnasium (Low)	5/2/13	< 1
Hardy MS	2nd Floor, Inside Gymnasium (Low)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 212 (High)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 212 (High)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 212 (Low)	5/2/13	< 1
Hardy MS	2nd Floor Hallway, by Room 212 (Low)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 167 (High)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 167 (High)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 167 (Low)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 167 (Low)	5/2/13	< 1
Hardy MS	1st Floor, Inside Cafeteria (High)	5/2/13	< 1
Hardy MS	1st Floor, Inside Cafeteria (High)	5/2/13	< 1
Hardy MS	1st Floor, Inside Cafeteria (Low)	5/2/13	< 1
Hardy MS	1st Floor, Inside Cafeteria (Low)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 119 (High)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 119 (High)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 119 (Low)	5/2/13	< 1
Hardy MS	1st Floor Hallway, by Room 119 (Low)	5/2/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (High)	3/18/13	< 1
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (High)	3/18/13	< 1
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (Low)	3/18/13	< 1
Harrison ES	Second Floor Hallway, Opposite to Staff Restroom (Low)	3/18/13	< 1
Harrison ES	Second Floor, Inside Room 201	3/18/13	< 1
Harrison ES	Second Floor, Inside Room 201	3/18/13	< 1
Harrison ES	Second Floor, Inside Room 203	3/18/13	< 1
Harrison ES	Second Floor, Inside Room 203	3/18/13	< 1
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (High)	3/18/13	< 1
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (High)	3/18/13	< 1
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (Low)	3/18/13	< 1
Harrison ES	1st Floor Hallway, Outside Nurse's Suite (Low)	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 109	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 109	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 107	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 107	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 103	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 103	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 101	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 101	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 133 (Right)	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 133 (Right)	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 133 (Left)	3/18/13	< 1
Harrison ES	1st Floor, Inside Room 133 (Left)	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 22	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 22	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 23	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 23	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 26	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 26	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 27	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 27	3/18/13	< 1
Harrison ES	Basement Hallway, by Room 5 (High)	3/18/13	< 1
Harrison ES	Basement Hallway, by Room 5 (High)	3/18/13	< 1
Harrison ES	Basement Hallway, by Room 5 (Low)	3/18/13	< 1
Harrison ES	Basement Hallway, by Room 5 (Low)	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 5	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 5	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 1	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 1	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 3	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 3	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 6	3/18/13	< 1
Harrison ES	Basement Floor, Inside Room 6	3/18/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Hart MS	2nd Floor Hallway, by Room 226 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 226 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 226 (Low)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 226 (Low)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 232 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 232 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 232 (Low)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 232 (Low)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 243 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 243 (High)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 243 (Low)	5/22/13	< 1
Hart MS	2nd Floor Hallway, by Room 243 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 119 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 119 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 119 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 119 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 123 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 123 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 123 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 123 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 131 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 131 (High)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 131 (Low)	5/22/13	< 1
Hart MS	1st Floor Hallway, by Room 131 (Low)	5/22/13	< 1
Hart MS	1st Floor, Inside Gym, Boys Locker Room	5/22/13	< 1
Hart MS	1st Floor, Inside Gym, Boys Locker Room	5/22/13	< 1
Hart MS	1st Floor, Inside Gym, Girls Locker Room	5/22/13	< 1
Hart MS	1st Floor, Inside Gym, Girls Locker Room	5/22/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Hearst ES	2nd Floor, by Room 206	2/25/13	< 1
Hearst ES	2nd Floor, by Room 206	2/25/13	< 1
Hearst ES	2nd Floor, by Room 200	2/25/13	< 1
Hearst ES	2nd Floor, by Room 200	2/25/13	< 1
Hearst ES	1st Floor, by Girls Restroom	2/25/13	< 1
Hearst ES	1st Floor, by Girls Restroom	2/25/13	< 1
Hearst ES	1st Floor, by Boys Restroom	2/25/13	< 1
Hearst ES	1st Floor, by Boys Restroom	2/25/13	< 1
Hearst ES	1st Floor, New Building, by Girls Restroom	2/25/13	< 1
Hearst ES	1st Floor, New Building, by Girls Restroom	2/25/13	< 1
Hearst ES	1st Floor, New Building, by Boys Restroom	2/25/13	< 1
Hearst ES	1st Floor, New Building, by Boys Restroom	2/25/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Hendley ES	Ground Floor, Inside Cafeteria by Kitchen	3/12/13	< 1
Hendley ES	Ground Floor, Inside Cafeteria by Kitchen	3/12/13	< 1
Hendley ES	Ground Floor, by Boys Restroom	3/12/13	< 1
Hendley ES	Ground Floor, by Boys Restroom	3/12/13	< 1
Hendley ES	Ground Floor, by Teachers Restroom	3/12/13	< 1
Hendley ES	Ground Floor, by Teachers Restroom	3/12/13	< 1
Hendley ES	3rd Floor Hallway, Outside Teachers Restroom	3/12/13	< 1

Hendley ES	3rd Floor Hallway, Outside Teachers Restroom	3/12/13	< 1
Hendley ES	3rd Floor Hallway, by Room 306	3/12/13	< 1
Hendley ES	3rd Floor Hallway, by Room 306	3/12/13	< 1
Hendley ES	2nd Floor Hallway, by Room 206	3/12/13	< 1
Hendley ES	2nd Floor Hallway, by Room 206	3/12/13	< 1
Hendley ES	1st Floor, Inside Nurse's Suite	3/12/13	< 1
Hendley ES	1st Floor, Inside Nurse's Suite	3/12/13	< 1
Hendley ES	1st Floor Hallway, Outside Teachers' Lounge	3/12/13	< 1
Hendley ES	1st Floor Hallway, Outside Teachers' Lounge	3/12/13	< 1
Hendley ES	1st Floor Hallway, Outside Teachers Restroom	3/12/13	< 1
Hendley ES	1st Floor Hallway, Outside Teachers Restroom	3/12/13	< 1
Hendley ES	Ground Floor Annex Hallway, between Girls and Boys Restrooms	3/12/13	< 1
Hendley ES	Ground Floor Annex Hallway, between Girls and Boys Restrooms	3/12/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Houston ES	1st Floor, Inside Lunch Room	2/15/13	< 1
Houston ES	1st Floor, Inside Lunch Room	2/15/13	< 1
Houston ES	1st Floor, by Room 156	2/15/13	< 1
Houston ES	1st Floor, by Room 156	2/15/13	< 1
Houston ES	1st Floor, by Room 148	2/15/13	1.8
Houston ES	1st Floor, by Room 148	2/15/13	< 1
Houston ES	1st Floor, by Room 147	2/15/13	< 1
Houston ES	1st Floor, by Room 147	2/15/13	< 1
Houston ES	1st Floor, by Teachers' Lounge	2/15/13	< 1
Houston ES	1st Floor, by Teachers' Lounge	2/15/13	< 1
Houston ES	1st Floor, in Teachers' Lounge	2/15/13	3.4
Houston ES	1st Floor, in Teachers' Lounge	2/15/13	2.4
Houston ES	1st Floor, by Room 105	2/15/13	< 1
Houston ES	1st Floor, by Room 105	2/15/13	< 1
Houston ES	1st Floor, by Room 112	2/15/13	< 1
Houston ES	1st Floor, by Room 112	2/15/13	< 1
Houston ES	2nd Floor, by Room 212	2/15/13	< 1
Houston ES	2nd Floor, by Room 212	2/15/13	< 1
Houston ES	2nd Floor, by Library	2/15/13	< 1
Houston ES	2nd Floor, by Library	2/15/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Hyde/Addison ES	Hyde 1st Floor, Next to Main Office	3/6/13	< 1
Hyde/Addison ES	Hyde 1st Floor, Next to Main Office	3/6/13	< 1
Hyde/Addison ES	Hyde 2nd Floor, Next to Teachers' Lounge	3/6/13	< 1
Hyde/Addison ES	Hyde 2nd Floor, Next to Teachers' Lounge	3/6/13	< 1
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (High)	3/6/13	< 1

Hyde/Addison ES	Addison Basement Hallway, Next to Room B03 (High)	3/6/13	< 1
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (High)	3/6/13	< 1
Hyde/Addison ES	Addison 1st Floor Hallway, Next to Room 114 (High)	3/6/13	< 1
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (Low)	3/6/13	< 1
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (High)	3/6/13	< 1
Hyde/Addison ES	Addison 2nd Floor Hallway, Next to Closet 204 (High)	3/6/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	

J.O. Wilson ES	3rd Floor Hallway, Across from Room 301	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 301	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Next to Custodian's Closet (Room 312)	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Next to Custodian's Closet (Room 312)	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 309	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 309	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 329	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 329	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 328	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 328	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 321	5/20/13	< 1
J.O. Wilson ES	3rd Floor Hallway, Across from Room 321	5/20/13	< 1
J.O. Wilson ES	3rd Floor, Inside Room 322	5/20/13	< 1
J.O. Wilson ES	3rd Floor, Inside Room 322	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 201	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 201	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Next to Custodian's Closet (Room 214)	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Next to Custodian's Closet (Room 214)	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 223	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 223	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 222	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 222	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 221	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 221	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 220	5/20/13	< 1
J.O. Wilson ES	2nd Floor, Inside Room 220	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 220	5/20/13	< 1
J.O. Wilson ES	2nd Floor Hallway, Across from Room 220	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Room 121	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Room 121	5/20/13	< 1

J.O. Wilson ES	1st Floor, Inside Room 121	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 121	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 123	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 123	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Room 110	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Room 110	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 110	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 110	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 111	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 111	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 109	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 109	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 112	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Room 112	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Custodian's Closet (Room 114)	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Custodian's Closet (Room 114)	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Across from Main Office	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Across from Main Office	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Cafeteria	5/20/13	< 1
J.O. Wilson ES	1st Floor, Inside Cafeteria	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Cafeteria	5/20/13	< 1
J.O. Wilson ES	1st Floor Hallway, Next to Cafeteria	5/20/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Janney ES	1st Floor Hallway, Across from Office	2/11/13	< 1
Janney ES	1st Floor Hallway, Across from Office	2/11/13	< 1
Janney ES	1st Floor, Inside Health Suite	2/11/13	< 1
Janney ES	1st Floor, Inside Health Suite	2/11/13	< 1
Janney ES	1st Floor Hallway, Next to Room 107	2/11/13	< 1
Janney ES	1st Floor Hallway, Next to Room 107	2/11/13	< 1
Janney ES	1st Floor, Inside Room 106	2/11/13	< 1
Janney ES	1st Floor, Inside Room 106	2/11/13	< 1
Janney ES	1st Floor, Inside Room 107	2/11/13	< 1
Janney ES	1st Floor, Inside Room 107	2/11/13	< 1
Janney ES	1st Floor, Inside Room 108	2/11/13	1.6
Janney ES	1st Floor, Inside Room 108	2/11/13	1.2
Janney ES	1st Floor, Inside Room 109	2/11/13	< 1
Janney ES	1st Floor, Inside Room 109	2/11/13	< 1
Janney ES	1st Floor, New Wing, Inside Room 110 (High)	2/11/13	< 1
Janney ES	1st Floor, New Wing, Inside Room 110 (High)	2/11/13	< 1
Janney ES	1st Floor, New Wing, Inside Room 110 (Low)	2/11/13	< 1
Janney ES	1st Floor, New Wing, Inside Room 110 (Low)	2/11/13	< 1
Janney ES	1st Floor Hallway, Next to Room 110	2/11/13	< 1
Janney ES	1st Floor Hallway, Next to Room 110	2/11/13	< 1

Janney ES	1st Floor, New Wing, Inside Room 112	2/11/13	< 1
Janney ES	1st Floor, New Wing, Inside Room 112	2/11/13	< 1
Janney ES	Basement Floor Hallway, Across from Stairwell	2/11/13	< 1
Janney ES	Basement Floor Hallway, Across from Stairwell	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (1)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (1)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (2)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (2)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (3)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (3)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (4)	2/11/13	< 1
Janney ES	Basement Floor, Inside Room L10 (4)	2/11/13	< 1
Janney ES	1st Floor, Inside Room 113	2/11/13	< 1
Janney ES	1st Floor, Inside Room 113	2/11/13	< 1
Janney ES	1st Floor Hallway, Across from Gymnasium (High)	2/11/13	< 1
Janney ES	1st Floor Hallway, Across from Gymnasium (High)	2/11/13	< 1
Janney ES	1st Floor Hallway, Across from Gymnasium (Low)	2/11/13	< 1
Janney ES	1st Floor Hallway, Across from Gymnasium (Low)	2/11/13	< 1
Janney ES	1st Floor, Inside Room 115	2/11/13	< 1
Janney ES	1st Floor, Inside Room 115	2/11/13	< 1
Janney ES	1st Floor, Inside Room 117	2/11/13	< 1
Janney ES	1st Floor, Inside Room 117	2/11/13	< 1
Janney ES	2nd Floor, Inside Teachers' Lounge	2/11/13	< 1
Janney ES	2nd Floor, Inside Teachers' Lounge	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 212A	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 212A	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 210	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 210	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 209	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 209	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 208	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 208	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 206	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 206	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 207	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 207	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 207	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 207	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 202	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 202	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 203	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 203	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 203	2/11/13	< 1
Janney ES	2nd Floor Hallway, Next to Room 203	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 201	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 201	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 200	2/11/13	< 1
Janney ES	2nd Floor, Inside Room 200	2/11/13	< 1

Janney ES	3rd Floor, Inside Room 300	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 300	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 301	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 301	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 303	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 303	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 303	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 303	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 302	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 302	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 304	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 304	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 307	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 307	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 307	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 307	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 306	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 306	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 309	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 309	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 308	2/11/13	< 1
Janney ES	3rd Floor, Inside Room 308	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 310	2/11/13	< 1
Janney ES	3rd Floor Hallway, Next to Room 310	2/11/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Jefferson MS	1st Floor Hallway, Next to Teachers' Lounge	5/9/13	< 1
Jefferson MS	1st Floor Hallway, Next to Teachers' Lounge	5/9/13	< 1
Jefferson MS	1st Floor Hallway, Next to Girls Restroom	5/9/13	< 1
Jefferson MS	1st Floor Hallway, Next to Girls Restroom	5/9/13	< 1
Jefferson MS	1st Floor Hallway, Across from Students' Lounge	5/9/13	< 1
Jefferson MS	1st Floor Hallway, Across from Students' Lounge	5/9/13	< 1
Jefferson MS	1st Floor, Inside Girls Locker Room	5/9/13	< 1
Jefferson MS	1st Floor, Inside Girls Locker Room	5/9/13	< 1
Jefferson MS	1st Floor, Inside Boys Locker Room	5/9/13	< 1
Jefferson MS	1st Floor, Inside Boys Locker Room	5/9/13	< 1
Jefferson MS	2nd Floor Hallway, Across from Room 206	5/9/13	< 1
Jefferson MS	2nd Floor Hallway, Across from Room 206	5/9/13	< 1
Jefferson MS	2nd Floor Hallway, Across from Room 218	5/9/13	< 1
Jefferson MS	2nd Floor Hallway, Across from Room 218	5/9/13	< 1
Jefferson MS	3rd Floor Hallway, Next to Girls Restroom	5/9/13	< 1
Jefferson MS	3rd Floor Hallway, Next to Girls Restroom	5/9/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Johnson MS	4th Floor, Next to Elevator Area	1/24/13	< 1
Johnson MS	4th Floor, Next to Elevator Area	1/24/13	< 1
Johnson MS	4th Floor, by Girls Restroom	1/24/13	< 1
Johnson MS	4th Floor, by Girls Restroom	1/24/13	< 1
Johnson MS	3rd Floor, Next to Elevator Area	1/24/13	< 1
Johnson MS	3rd Floor, Next to Elevator Area	1/24/13	< 1
Johnson MS	3rd Floor, by Girls Restroom (High)	1/24/13	< 1
Johnson MS	3rd Floor, by Girls Restroom (High)	1/24/13	< 1

Johnson MS	3rd Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	3rd Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	2nd Floor, Next to Elevator Area	1/24/13	< 1	
Johnson MS	2nd Floor, Next to Elevator Area	1/24/13	< 1	
Johnson MS	2nd Floor, by Girls Restroom (High)	1/24/13	< 1	
Johnson MS	2nd Floor, by Girls Restroom (High)	1/24/13	< 1	
Johnson MS	2nd Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	2nd Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	1st Floor, Auditorium Hallway, by Exit Door	1/24/13	< 1	
Johnson MS	1st Floor, Auditorium Hallway, by Exit Door	1/24/13	< 1	
Johnson MS	1st Floor, by Girls Restroom (High)	1/24/13	< 1	
Johnson MS	1st Floor, by Girls Restroom (High)	1/24/13	< 1	
Johnson MS	1st Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	1st Floor, by Girls Restroom (Low)	1/24/13	< 1	
Johnson MS	1st Floor, Girls Locker Room Area	1/24/13	7.3	
Johnson MS	1st Floor, Girls Locker Room Area	1/24/13	7.3	
Johnson MS	Basement Floor, Cafeteria, by Weight Room Door	1/24/13	< 1	
Johnson MS	Basement Floor, Cafeteria, by Weight Room Door	1/24/13	< 1	
Johnson MS	1st Floor, Adjacent to Gym Entrance	1/24/13	< 1	
Johnson MS	1st Floor, Adjacent to Gym Entrance	1/24/13	< 1	
Johnson MS	Basement Floor, Cafeteria, Outside Kitchen Area	1/24/13	< 1	
Johnson MS	Basement Floor, Cafeteria, Outside Kitchen Area	1/24/13	6.4	
Johnson MS	Basement Floor, Inside Weight Room	1/24/13	< 1	35
Johnson MS	Basement Floor, Inside Weight Room	1/24/13	< 1	
Johnson MS	<i>Basement Floor, Inside Weight Room - Retest</i>	<i>2/7/13</i>	< 1	
Johnson MS	<i>Basement Floor, Inside Weight Room - Retest</i>	<i>2/7/13</i>	< 1	
Percentage of Passed Samples				
Percentage of Failed Samples				
K.C. Lewis ES	3rd Floor Hallway, Next to Utility Room 303	5/29/13	< 1	
K.C. Lewis ES	3rd Floor Hallway, Next to Utility Room 303	5/29/13	< 1	
K.C. Lewis ES	3rd Floor Hallway, Across from Room 315	5/29/13	< 1	
K.C. Lewis ES	3rd Floor Hallway, Across from Room 315	5/29/13	< 1	
K.C. Lewis ES	2nd Floor Hallway, Next to Room 211	5/29/13	< 1	
K.C. Lewis ES	2nd Floor Hallway, Next to Room 211	5/29/13	< 1	
K.C. Lewis ES	2nd Floor Hallway, Next to Boys Restroom	5/29/13	< 1	
K.C. Lewis ES	2nd Floor Hallway, Next to Boys Restroom	5/29/13	< 1	
K.C. Lewis ES	1st Floor Hallway, Near Storage Room 100	5/29/13	< 1	
K.C. Lewis ES	1st Floor Hallway, Near Storage Room 100	5/29/13	< 1	
K.C. Lewis ES	1st Floor Hallway, Next to Room 108 (Custodian's Closet)	5/29/13	< 1	
K.C. Lewis ES	1st Floor Hallway, Next to Room 108 (Custodian's Closet)	5/29/13	< 1	
K.C. Lewis ES	Inside Nurse's Office	5/29/13		200
K.C. Lewis ES	Inside Nurse's Office	5/29/13		70
Percentage of Passed Samples				
Percentage of Failed Samples				
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (High)	5/3/13	< 1	

Kelly Miller MS	3rd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	3rd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	3rd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (High)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (High)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	2nd Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Right of Elevator (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Right of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Left of Elevator (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Left of Elevator (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Left of Elevator (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor, Inside Room 135	5/3/13	2.8
Kelly Miller MS	1st Floor, Inside Room 135	5/3/13	1.4
Kelly Miller MS	1st Floor, Inside Gymnasium	5/3/13	< 1
Kelly Miller MS	1st Floor, Inside Gymnasium	5/3/13	< 1
Kelly Miller MS	1st Floor, Inside Cafeteria	5/3/13	< 1
Kelly Miller MS	1st Floor, Inside Cafeteria	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (High)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (Low)	5/3/13	< 1
Kelly Miller MS	1st Floor Hallway, Outside Cafeteria (Low)	5/3/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Kenilworth ES	1st Floor, Inside Kindergarten	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Kindergarten	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Pre-K, Room 129	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Pre-K, Room 129	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside All-Purpose Room	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside All-Purpose Room	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Cafeteria	2/19/13	4
Kenilworth ES	1st Floor, Inside Cafeteria	2/19/13	6.8
Kenilworth ES	1st Floor, Outside Teachers' Lounge	2/19/13	< 1
Kenilworth ES	1st Floor, Outside Teachers' Lounge	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside Room 100	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside Room 100	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside Room 108	2/19/13	< 1
Kenilworth ES	1st Floor Hallway, Outside Room 108	2/19/13	< 1
Kenilworth ES	2nd Floor Hallway, Outside Room 214	2/19/13	< 1
Kenilworth ES	2nd Floor Hallway, Outside Room 214	2/19/13	< 1
Kenilworth ES	2nd Floor Hallway, Outside Girls Restroom	2/19/13	< 1
Kenilworth ES	2nd Floor Hallway, Outside Girls Restroom	2/19/13	< 1

Kenilworth ES	2nd Floor Hallway, Outside Room 210	2/19/13	< 1
Kenilworth ES	2nd Floor Hallway, Outside Room 210	2/19/13	< 1
Kenilworth ES	3rd Floor Hallway, Outside Room 310	2/19/13	< 1
Kenilworth ES	3rd Floor Hallway, Outside Room 310	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Health Suite	2/19/13	< 1
Kenilworth ES	1st Floor, Inside Health Suite	2/19/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Ketcham ES	Inside Cafeteria	4/25/13	< 1
Ketcham ES	Inside Cafeteria	4/25/13	< 1
Ketcham ES	3rd Floor, Next to Boys Restroom	4/25/13	< 1
Ketcham ES	3rd Floor, Next to Boys Restroom	4/25/13	1.8
Ketcham ES	2nd Floor, Next to Boys Restroom	4/25/13	2.3
Ketcham ES	2nd Floor, Next to Boys Restroom	4/25/13	4.9
Ketcham ES	1st Floor, Inside Room B109	4/25/13	7.4
Ketcham ES	1st Floor, Inside Room B109	4/25/13	3.2
Ketcham ES	1st Floor Hallway, Next to Room A101	4/25/13	< 1
Ketcham ES	1st Floor Hallway, Next to Room A101	4/25/13	< 1
Ketcham ES	1st Floor, Inside Room A1010	4/25/13	1.7
Ketcham ES	1st Floor, Inside Room A1010	4/25/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Key ES	2nd Floor, Inside Room 201	3/8/13	< 1
Key ES	2nd Floor, Inside Room 201	3/8/13	< 1
Key ES	2nd Floor, Inside Room 202	3/8/13	< 1
Key ES	2nd Floor, Inside Room 202	3/8/13	< 1
Key ES	2nd Floor, Inside Room 203	3/8/13	< 1
Key ES	2nd Floor, Inside Room 203	3/8/13	< 1
Key ES	2nd Floor, by Room 204	3/8/13	< 1
Key ES	2nd Floor, by Room 204	3/8/13	< 1
Key ES	2nd Floor, Inside Room 204	3/8/13	< 1
Key ES	2nd Floor, Inside Room 204	3/8/13	< 1
Key ES	2nd Floor, Inside Room 206	3/8/13	< 1
Key ES	2nd Floor, Inside Room 206	3/8/13	< 1
Key ES	2nd Floor, Inside Room 205	3/8/13	< 1
Key ES	2nd Floor, Inside Room 205	3/8/13	< 1
Key ES	2nd Floor, Inside Room 207	3/8/13	< 1
Key ES	2nd Floor, Inside Room 207	3/8/13	< 1
Key ES	2nd Floor, Inside Room 208	3/8/13	< 1
Key ES	2nd Floor, Inside Room 208	3/8/13	< 1
Key ES	2nd Floor, by Room 207	3/8/13	< 1
Key ES	2nd Floor, by Room 207	3/8/13	< 1
Key ES	2nd Floor, Inside Room 210	3/8/13	< 1
Key ES	2nd Floor, Inside Room 210	3/8/13	< 1
Key ES	2nd Floor, Inside Room 209	3/8/13	< 1
Key ES	2nd Floor, Inside Room 209	3/8/13	< 1
Key ES	2nd Floor, Inside Room 212	3/8/13	< 1
Key ES	2nd Floor, Inside Room 212	3/8/13	< 1
Key ES	2nd Floor, Inside Room 211	3/8/13	< 1
Key ES	2nd Floor, Inside Room 211	3/8/13	< 1
Key ES	1st Floor, Inside Room 105	3/8/13	< 1
Key ES	1st Floor, Inside Room 105	3/8/13	< 1
Key ES	1st Floor, Inside Room 106	3/8/13	< 1
Key ES	1st Floor, Inside Room 106	3/8/13	< 1

Key ES	1st Floor, by Room 103	3/8/13	< 1
Key ES	1st Floor, by Room 103	3/8/13	< 1
Key ES	1st Floor, by Room 104	3/8/13	< 1
Key ES	1st Floor, by Room 104	3/8/13	< 1
Key ES	1st Floor, Inside Room 104	3/8/13	< 1
Key ES	1st Floor, Inside Room 104	3/8/13	< 1
Key ES	1st Floor, Inside Room 103	3/8/13	< 1
Key ES	1st Floor, Inside Room 103	3/8/13	< 1
Key ES	1st Floor, Inside Room 102	3/8/13	4.5
Key ES	1st Floor, Inside Room 102	3/8/13	1.9
Key ES	1st Floor, Inside Room 101	3/8/13	< 1
Key ES	1st Floor, Inside Room 101	3/8/13	< 1
Key ES	Basement Floor, Inside Boys Restroom	3/8/13	< 1
Key ES	Basement Floor, Inside Boys Restroom	3/8/13	< 1
Key ES	Basement Floor, on the Playground	3/8/13	< 1
Key ES	Basement Floor, on the Playground	3/8/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Kramer MS	3rd Floor Hallway, Next to Room 317	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Next to Room 317	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Near Stairwell C	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Near Stairwell C	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Next to Room 306	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Next to Room 306	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Next to Room 305	5/7/13	< 1
Kramer MS	3rd Floor Hallway, Next to Room 305	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Across from Girls Restroom	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Across from Girls Restroom	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Near Stairwell C	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Near Stairwell C	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Near Stairwell D	5/7/13	< 1
Kramer MS	2nd Floor Hallway, Near Stairwell D	5/7/13	< 1
Kramer MS	1st Floor Hallway, Next to Room 111A	5/7/13	< 1
Kramer MS	1st Floor Hallway, Next to Room 111A	5/7/13	< 1
Kramer MS	1st Floor Hallway, Across from Gym	5/7/13	< 1
Kramer MS	1st Floor Hallway, Across from Gym	5/7/13	< 1
Kramer MS	1st Floor Hallway, Across from Boys Restroom	5/7/13	< 1
Kramer MS	1st Floor Hallway, Across from Boys Restroom	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Across from Teachers' Dining Room	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Across from Teachers' Dining Room	5/7/13	< 1
Kramer MS	Inside Cafeteria at Exit, Near Boiler Room	5/7/13	< 1
Kramer MS	Inside Cafeteria at Exit, Near Boiler Room	5/7/13	< 1
Kramer MS	Inside Cafeteria, Other Side	5/7/13	< 1
Kramer MS	Inside Cafeteria, Other Side	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Across from Storage Room 15	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Across from Storage Room 15	5/7/13	< 1

Kramer MS	Basement Floor Hallway, Next to Storage Room 22	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Next to Storage Room 22	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Next to Custodian's Office	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Next to Custodian's Office	5/7/13	< 1
Kramer MS	Basement Floor Hallway, Next to Room 14	5/7/13	2.8
Kramer MS	Basement Floor Hallway, Next to Room 14	5/7/13	1.8
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Lafayette ES	1st Floor, East Learning Center, Behind Counter	4/22/13	< 1
Lafayette ES	1st Floor, East Learning Center, Behind Counter	4/22/13	< 1
Lafayette ES	1st Floor, Learning Center, Near Boys Restroom	4/22/13	< 1
Lafayette ES	1st Floor, Learning Center, Near Boys Restroom	4/22/13	< 1
Lafayette ES	1st Floor, Learning Center, Near Girls Restroom	4/22/13	< 1
Lafayette ES	1st Floor, Learning Center, Near Girls Restroom	4/22/13	< 1
Lafayette ES	1st Floor, West Learning Center, Behind Counter	4/22/13	< 1
Lafayette ES	1st Floor, West Learning Center, Behind Counter	4/22/13	< 1
Lafayette ES	1st Floor Hallway, Opposite to Pearls Paradise Caffee	4/22/13	< 1
Lafayette ES	1st Floor Hallway, Opposite to Pearls Paradise Caffee	4/22/13	< 1
Lafayette ES	1st Floor Hallway, Opposite to Music Room	4/22/13	< 1
Lafayette ES	1st Floor Hallway, Opposite to Music Room	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 2	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 2	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 3	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 3	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 1	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 1	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 4	4/22/13	< 1
Lafayette ES	1st Floor Hallway, by Stairwell 4	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 2	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 2	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 3	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 3	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 1	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 1	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 4	4/22/13	< 1
Lafayette ES	2nd Floor Hallway, by Stairwell 4	4/22/13	< 1
Lafayette ES	Basement Hallway, by Girls Restroom	4/22/13	< 1
Lafayette ES	Basement Hallway, by Girls Restroom	4/22/13	< 1
Lafayette ES	Basement Hallway, by Lobby (High)	4/22/13	< 1
Lafayette ES	Basement Hallway, by Lobby (High)	4/22/13	< 1

Lafayette ES	Basement Hallway, by Lobby (Low)	4/22/13	< 1
Lafayette ES	Basement Hallway, by Lobby (Low)	4/22/13	< 1
Lafayette ES	1st Floor, Inside Nurse's Suite	4/22/13	< 1
Lafayette ES	1st Floor, Inside Nurse's Suite	4/22/13	< 1
Lafayette ES	Trailer Grade 4 Hallway (High)	4/22/13	< 1
Lafayette ES	Trailer Grade 4 Hallway (High)	4/22/13	< 1
Lafayette ES	Trailer Grade 4 Hallway (Low)	4/22/13	< 1
Lafayette ES	Trailer Grade 4 Hallway (Low)	4/22/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Langdon ES	2nd Floor Hallway, by Teachers' and Boys' Restroom	4/12/13	< 1
Langdon ES	2nd Floor Hallway, by Teachers' and Boys' Restroom	4/12/13	< 1
Langdon ES	2nd Floor Hallway, by Teachers' and Girls' Restroom	4/12/13	< 1
Langdon ES	2nd Floor Hallway, by Teachers' and Girls' Restroom	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Room 117, Custodian's Closet	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Room 117, Custodian's Closet	4/12/13	< 1
Langdon ES	1st Floor Hallway, Between Boys and Girls Restroom	4/12/13	< 1
Langdon ES	1st Floor Hallway, Between Boys and Girls Restroom	4/12/13	< 1
Langdon ES	1st Floor, Inside Health Suite	4/12/13	< 1
Langdon ES	1st Floor, Inside Health Suite	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Teachers' Restroom	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Teachers' Restroom	4/12/13	< 1
Langdon ES	1st Floor, Inside Teachers' Lounge	4/12/13	< 1
Langdon ES	1st Floor, Inside Teachers' Lounge	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Boys Restroom	4/12/13	< 1
Langdon ES	1st Floor Hallway, by Boys Restroom	4/12/13	< 1
Langdon ES	Basement Floor, Inside Lunch Room	4/12/13	< 1
Langdon ES	Basement Floor, Inside Lunch Room	4/12/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Langley JHS	1st Floor Hallway, Across from Auditorium	1/22/13	< 1
Langley JHS	1st Floor Hallway, Across from Auditorium	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 149	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 149	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 143	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 143	1/22/13	< 1
Langley JHS	1st Floor, Inside Reading Class, Next to Room 133	1/22/13	< 1
Langley JHS	1st Floor, Inside Reading Class, Next to Room 133	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 133	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 133	1/22/13	< 1
Langley JHS	1st Floor, Teachers' Lounge	1/22/13	< 1
Langley JHS	1st Floor, Teachers' Lounge	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 125	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 125	1/22/13	< 1

Langley JHS	1st Floor, Inside Room 122	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 122	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 113	1/22/13	< 1
Langley JHS	1st Floor, Inside Room 113	1/22/13	< 1
Langley JHS	1st Floor Hallway, Near Room 106	1/22/13	< 1
Langley JHS	1st Floor Hallway, Near Room 106	1/22/13	< 1
Langley JHS	2nd Floor Hallway, Adjacent to Room 204	1/22/13	< 1
Langley JHS	2nd Floor Hallway, Adjacent to Room 204	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 208	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 208	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 211	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 211	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 217	1/22/13	< 1
Langley JHS	2nd Floor, Inside Room 217	1/22/13	< 1
Langley JHS	2nd Floor Hallway, Next to Room 201	1/22/13	< 1
Langley JHS	2nd Floor Hallway, Next to Room 201	1/22/13	< 1
Langley JHS	3rd Floor Hallway, Next to Room 301	1/22/13	< 1
Langley JHS	3rd Floor Hallway, Next to Room 301	1/22/13	< 1
Langley JHS	3rd Floor Hallway, Next to Room 304	1/22/13	< 1
Langley JHS	3rd Floor Hallway, Next to Room 304	1/22/13	< 1
Langley JHS	3rd Floor, Inside Teachers' Room	1/22/13	< 1
Langley JHS	3rd Floor, Inside Teachers' Room	1/22/13	< 1
Langley JHS	Basement Floor, Outside Girls Gym	1/22/13	< 1
Langley JHS	Basement Floor, Outside Girls Gym	1/22/13	< 1
Langley JHS	Basement Floor, Outside Boys Gym	1/22/13	< 1
Langley JHS	Basement Floor, Outside Boys Gym	1/22/13	< 1
Langley JHS	Sub-Basement Hallway, Stairwell 3, Outside Cafeteria	1/22/13	1.3
Langley JHS	Sub-Basement Hallway, Stairwell 3, Outside Cafeteria	1/22/13	1.3
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1
Langley JHS	Sub-Basement Hallway, Stairwell 4, Outside Cafeteria	1/22/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Lasalle ES	Ground Floor, Inside Cafeteria	4/25/13	< 1
Lasalle ES	Ground Floor, Inside Cafeteria	4/25/13	< 1
Lasalle ES	Ground Floor Hallway, Outside Custodial's Office	4/25/13	< 1
Lasalle ES	Ground Floor Hallway, Outside Custodial's Office	4/25/13	< 1
Lasalle ES	Office	4/25/13	< 1
Lasalle ES	3rd Floor, Outside Room 308	4/25/13	1.5
Lasalle ES	3rd Floor, Outside Room 308	4/25/13	1.4
Lasalle ES	3rd Floor, Outside Room 307	4/25/13	< 1
Lasalle ES	3rd Floor, Outside Room 307	4/25/13	< 1
Lasalle ES	2nd Floor, Outside Room 207	4/25/13	< 1
Lasalle ES	2nd Floor, Outside Room 207	4/25/13	< 1
Lasalle ES	2nd Floor, Outside Room 208	4/25/13	< 1
Lasalle ES	2nd Floor, Outside Room 208	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 109	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 109	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 105	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 105	4/25/13	< 1

Lasalle ES	1st Floor Hallway, Outside Room 113	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 113	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 120	4/25/13	< 1
Lasalle ES	1st Floor Hallway, Outside Room 120	4/25/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (Low)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (Low)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (High)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Teachers' Restroom (High)	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 111	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 111	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 113	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 113	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 125	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 125	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 116	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 116	2/22/13	< 1
Leckie ES	1st Floor, Inside Room 122	2/22/13	1.7
Leckie ES	1st Floor, Inside Room 122	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Room 122 (Low)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Room 122 (Low)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Room 122 (High)	2/22/13	< 1
Leckie ES	1st Floor Hallway, Next to Room 122 (High)	2/22/13	< 1
Leckie ES	Basement Floor, Inside Room 28	2/22/13	< 1
Leckie ES	Basement Floor, Inside Room 28	2/22/13	< 1
Leckie ES	Basement Floor, Inside Room 16	2/22/13	
Leckie ES	Basement Floor, Inside Room 16	2/22/13	1.3
Leckie ES	<i>Basement Floor, Inside Room 16</i>	3/13/13	< 1
Leckie ES	<i>Basement Floor, Inside Room 16</i>	3/13/13	< 1
Leckie ES	Basement Floor, Inside Room 14	2/22/13	2.3
Leckie ES	Basement Floor, Inside Room 14	2/22/13	< 1
Leckie ES	Basement Floor, Inside Room 12	2/22/13	2.7
Leckie ES	Basement Floor, Inside Room 12	2/22/13	1.6
Leckie ES	Basement Hallway, Next to Teachers' Restroom (Low)	2/22/13	< 1
Leckie ES	Basement Hallway, Next to Teachers' Restroom (Low)	2/22/13	< 1
Leckie ES	Basement Hallway, Next to Teachers' Restroom (High)	2/22/13	< 1
Leckie ES	Basement Hallway, Next to Teachers' Restroom (High)	2/22/13	< 1
Leckie ES	1st Floor, Inside Multi-Purpose Room	2/22/13	< 1
Leckie ES	1st Floor, Inside Multi-Purpose Room	2/22/13	< 1
Leckie ES	2nd Floor Hallway, Next to Room 212	2/22/13	< 1
Leckie ES	2nd Floor Hallway, Next to Room 212	2/22/13	< 1
Leckie ES	3rd Floor Hallway, Next to Room 309	2/22/13	< 1
Leckie ES	3rd Floor Hallway, Next to Room 309	2/22/13	< 1
Leckie ES	3rd Floor Hallway, Next to Teachers' Restroom	2/22/13	< 1

Leckie ES	3rd Floor Hallway, Next to Teachers' Restroom	2/22/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Logan ES	2nd Floor Hallway, Across from Room 211	5/21/13	< 1
Logan ES	2nd Floor Hallway, Across from Room 211	5/21/13	8.6
Logan ES	1st Floor Hallway, Next to Room 109	5/21/13	2.3
Logan ES	1st Floor Hallway, Next to Room 109	5/21/13	2.8
Logan ES	Inside Cafeteria	5/21/13	2.5
Logan ES	Inside Cafeteria	5/21/13	3.9
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Ludlow Taylor ES	1st Floor Hallway, Lobby by Stairs	4/10/13	< 1
Ludlow Taylor ES	1st Floor Hallway, Lobby by Stairs	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Health Suite	4/10/13	1.9
Ludlow Taylor ES	1st Floor, Inside Health Suite	4/10/13	2.4
Ludlow Taylor ES	1st Floor Hallway, by Room 101	4/10/13	< 1
Ludlow Taylor ES	1st Floor Hallway, by Room 101	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Room 101	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Room 101	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Room 100	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Room 100	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Multi-Service Center	4/10/13	< 1
Ludlow Taylor ES	1st Floor, Inside Multi-Service Center	4/10/13	< 1
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 304	4/10/13	< 1
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 304	4/10/13	< 1
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 313	4/10/13	< 1
Ludlow Taylor ES	3rd Floor Hallway, Opposite to Room 313	4/10/13	< 1
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 202	4/10/13	< 1
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 202	4/10/13	< 1
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 213	4/10/13	< 1
Ludlow Taylor ES	2nd Floor Hallway, Opposite to Room 213	4/10/13	< 1
Ludlow Taylor ES	1st Floor Hallway, Entrance to Multi-Purpose Room	4/10/13	< 1
Ludlow Taylor ES	1st Floor Hallway, Entrance to Multi-Purpose Room	4/10/13	< 1
Ludlow Taylor ES	Room	4/10/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Luke Moore Academy	2nd Floor Hallway, by Women's Restroom	5/17/13	< 1
Luke Moore Academy	2nd Floor Hallway, by Women's Restroom	5/17/13	< 1
Luke Moore Academy	2nd Floor Hallway, by Men's Restroom	5/17/13	< 1
Luke Moore Academy	2nd Floor Hallway, by Men's Restroom	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, (High)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, (High)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, (Down)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, (Down)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, by Room B22 (High)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, by Room B22 (High)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, by Room B22 (Low)	5/17/13	< 1
Luke Moore Academy	1st Floor Hallway, by Room B22 (Low)	5/17/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
M.C. Terrell ES	Upper Ground Floor, Inside Teachers' Lounge	4/30/13	< 1

M.C. Terrell ES	Upper Ground Floor, Inside Teachers' Lounge	4/30/13	< 1	
M.C. Terrell ES	Upper Ground Floor Hallway, by Storage Room	4/30/13	1.3	
M.C. Terrell ES	Upper Ground Floor Hallway, by Storage Room	4/30/13	1.2	
M.C. Terrell ES	3rd Floor Hallway, by Storage Room 317	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Storage Room 317	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Entrance to Learning Center	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Entrance to Learning Center	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Toilets	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Toilets	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Room 302	4/30/13	< 1	
M.C. Terrell ES	3rd Floor Hallway, by Room 302	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Stairs	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Stairs	4/30/13		15
M.C. Terrell ES	2nd Floor Hallway, by Room 201 - Retest	5/21/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Room 201 - Retest	5/21/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Room 201	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Room 201	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Restrooms	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Restrooms	4/30/13		16
M.C. Terrell ES	2nd Floor Hallway, by Restrooms - Retest	5/21/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Restrooms - Retest	5/21/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Learning Area 215	4/30/13	< 1	
M.C. Terrell ES	2nd Floor Hallway, by Learning Area 215	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Storage Room 117	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Storage Room 117	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Learning Area 101	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Learning Area 101	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Restrooms	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Restrooms	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Learning Center 115	4/30/13	< 1	
M.C. Terrell ES	1st Floor Hallway, by Learning Center 115	4/30/13	< 1	
M.C. Terrell ES	Upper Ground, Inside All Purpose Room	4/30/13	< 1	
M.C. Terrell ES	Upper Ground, Inside All Purpose Room	4/30/13	< 1	
M.C. Terrell ES	Upper Ground Gym, Inside Girls Locker Room	4/30/13	2.8	
M.C. Terrell ES	Upper Ground Gym, Inside Girls Locker Room	4/30/13	3.6	
M.C. Terrell ES	Upper Ground Gym, Inside Boys Locker Room	4/30/13	3.3	
M.C. Terrell ES	Upper Ground Gym, Inside Boys Locker Room	4/30/13	2.8	
M.C. Terrell ES	Upper Ground, Inside Room EC2	4/30/13	< 1	
M.C. Terrell ES	Upper Ground, Inside Room EC2	4/30/13	< 1	
M.C. Terrell ES	Upper Ground, Inside Room EC4	4/30/13	< 1	
M.C. Terrell ES	Upper Ground, Inside Room EC4	4/30/13	< 1	
M.C. Terrell ES	Lower Ground Hallway, by Restrooms	4/30/13	< 1	
M.C. Terrell ES	Lower Ground Hallway, by Restrooms	4/30/13	< 1	

Percentage of Passed Samples

Percentage of Failed Samples

M.L. King ES	1st Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	1st Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (Low)	2/12/13	< 1
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (Low)	2/12/13	< 1
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (High)	2/12/13	< 1
M.L. King ES	1st Floor Hallway, Next to Girls Restroom (High)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Room 208 (Low)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Room 208 (Low)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Room 208 (High)	2/12/13	< 1
M.L. King ES	2nd Floor Hallway, Next to Room 208 (High)	2/12/13	< 1
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (Low)	2/12/13	< 1
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1
M.L. King ES	3rd Floor Hallway, Next to Boys Restroom (High)	2/12/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
MacFarland MS	3rd Floor Hallway, by Room 302	5/2/13	< 1
MacFarland MS	3rd Floor Hallway, by Room 302	5/2/13	< 1
MacFarland MS	2nd Floor Hallway, by Room 252	5/2/13	< 1
MacFarland MS	2nd Floor Hallway, by Room 252	5/2/13	< 1
MacFarland MS	2nd Floor Hallway, by Room 203	5/2/13	< 1
MacFarland MS	2nd Floor Hallway, by Room 203	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Adult Restroom	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Adult Restroom	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Room 152	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Room 152	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Room 158	5/2/13	< 1
MacFarland MS	1st Floor Hallway, by Room 158	5/2/13	< 1
MacFarland MS	Basement Floor, Inside Cafeteria	5/2/13	< 1
MacFarland MS	Basement Floor, Inside Cafeteria	5/2/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Malcolm X ES	4th Floor, by Girls Restroom	4/15/13	< 1
Malcolm X ES	4th Floor, by Girls Restroom	4/15/13	< 1
Malcolm X ES	4th Floor, by Boys Restroom	4/15/13	< 1
Malcolm X ES	4th Floor, by Boys Restroom	4/15/13	< 1

Malcolm X ES	4th Floor, Inside Teachers' Lounge	4/15/13	7.5
Malcolm X ES	4th Floor, Inside Teachers' Lounge	4/15/13	7.1
Malcolm X ES	3rd Floor, by Girls Restoom	4/15/13	< 1
Malcolm X ES	3rd Floor, by Girls Restoom	4/15/13	< 1
Malcolm X ES	3rd Floor, by Boys Restoom	4/15/13	< 1
Malcolm X ES	3rd Floor, by Boys Restoom	4/15/13	< 1
Malcolm X ES	3rd Floor, Inside Teachers' Lounge	4/15/13	1.2
Malcolm X ES	3rd Floor, Inside Teachers' Lounge	4/15/13	< 1
Malcolm X ES	2nd Floor, by Girls Restoom	4/15/13	< 1
Malcolm X ES	2nd Floor, by Girls Restoom	4/15/13	< 1
Malcolm X ES	2nd Floor, by Boys Restoom	4/15/13	< 1
Malcolm X ES	2nd Floor, by Boys Restoom	4/15/13	< 1
Malcolm X ES	1st Floor, by Restroom	4/15/13	< 1
Malcolm X ES	1st Floor, by Restroom	4/15/13	< 1
Malcolm X ES	1st Floor, In Open Space	4/15/13	< 1
Malcolm X ES	1st Floor, In Open Space	4/15/13	< 1
Malcolm X ES	1st Floor, by Lunch Room	4/15/13	< 1
Malcolm X ES	1st Floor, by Lunch Room	4/15/13	< 1
Malcolm X ES	1st Floor, by Main Lobby	4/15/13	< 1
Malcolm X ES	1st Floor, by Main Lobby	4/15/13	< 1
Malcolm X ES	1st Floor, Inside Health Suite	4/15/13	< 1
Malcolm X ES	1st Floor, Inside Health Suite	4/15/13	< 1
Malcolm X ES	1st Floor, by Exit	4/15/13	< 1
Malcolm X ES	1st Floor, by Exit	4/15/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Mamie D Lee ES	1st Floor, Inside Room 11	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 11	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 13	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 13	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 10	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 10	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 12	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 12	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 15	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 15	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 17	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 17	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 14	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 14	1/16/13	< 1
Mamie D Lee ES	1st Floor, Teachers' Lounge	1/16/13	< 1
Mamie D Lee ES	1st Floor, Teachers' Lounge	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 28	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 28	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 29	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 29	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 26	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 26	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 24	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 24	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 27	1/16/13	1.8
Mamie D Lee ES	2nd Floor, Inside Room 27	1/16/13	1.7
Mamie D Lee ES	2nd Floor Hallway, Adjacent to Room 27	1/16/13	< 1
Mamie D Lee ES	2nd Floor Hallway, Adjacent to Room 27	1/16/13	< 1

Mamie D Lee ES	2nd Floor, Inside Room 22	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 22	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 23	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 23	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 20	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 20	1/16/13	< 1
Mamie D Lee ES	2nd Floor, Inside Room 21	1/16/13	2.3
Mamie D Lee ES	2nd Floor, Inside Room 21	1/16/13	2.1
Mamie D Lee ES	1st Floor, Inside Room 18	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 18	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 19	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Room 19	1/16/13	< 1
Mamie D Lee ES	1st Floor Hallway, Outside Cafeteria	1/16/13	1.7
Mamie D Lee ES	1st Floor Hallway, Outside Cafeteria	1/16/13	1.2
Mamie D Lee ES	1st Floor, Cafeteria Kitchen	1/16/13	< 1
Mamie D Lee ES	1st Floor, Cafeteria Kitchen	1/16/13	< 1
Mamie D Lee ES	1st Floor Hallway, Across from Room 15	1/16/13	1.3
Mamie D Lee ES	1st Floor Hallway, Across from Room 15	1/16/13	1.3
Mamie D Lee ES	1st Floor Cafeteria	1/16/13	< 1
Mamie D Lee ES	1st Floor Cafeteria	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Health Suite	1/16/13	< 1
Mamie D Lee ES	1st Floor, Inside Health Suite	1/16/13	< 1

Percentage of Passed Samples			
-------------------------------------	--	--	--

Percentage of Failed Samples			
-------------------------------------	--	--	--

Mann ES	1st Floor Hallway, Next to Room 101	2/14/13	< 1
Mann ES	1st Floor Hallway, Next to Room 101	2/14/13	< 1
Mann ES	1st Floor Hallway, Across from Room 100	2/14/13	< 1
Mann ES	1st Floor Hallway, Across from Room 100	2/14/13	< 1
Mann ES	2nd Floor Hallway, Across from Room 200	2/14/13	< 1
Mann ES	2nd Floor Hallway, Across from Room 200	2/14/13	2.2
Mann ES	2nd Floor Hallway, Next to Room 205	2/14/13	< 1
Mann ES	2nd Floor Hallway, Next to Room 205	2/14/13	< 1
Mann ES	Community Center, Lunch Room	2/14/13	< 1
Mann ES	Community Center, Lunch Room	2/14/13	< 1

Percentage of Passed Samples			
-------------------------------------	--	--	--

Percentage of Failed Samples			
-------------------------------------	--	--	--

Marie Reed ES	2nd Floor Hallway, by Stairs and Toilet	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Stairs and Toilet	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #6	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #6	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #5	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #5	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #8	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #8	5/21/13	2.8
Marie Reed ES	2nd Floor Hallway, by Arts & Science #3	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #3	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #1	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #1	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #2	5/21/13	< 1
Marie Reed ES	2nd Floor Hallway, by Arts & Science #2	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Storage #11	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Storage #11	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Girls Restroom	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Girls Restroom	5/21/13	< 1

Marie Reed ES	1st Floor Hallway, by Lunch Room	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Lunch Room	5/21/13	1.1
Marie Reed ES	1st Floor Hallway, by Men's Restroom and Stairs	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, by Men's Restroom and Stairs	5/21/13	< 1
Marie Reed ES	1st Floor, Inside Teachers' Lounge	5/21/13	2
Marie Reed ES	1st Floor, Inside Teachers' Lounge	5/21/13	2
Marie Reed ES	1st Floor Hallway, Outside Main Office	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, Outside Main Office	5/21/13	< 1
Marie Reed ES	1st Floor Hallway, Inside Main Office	5/21/13	1.2
Marie Reed ES	1st Floor Hallway, Inside Main Office	5/21/13	1.9
Marie Reed ES	1st Floor Halway, by Main Entrance	5/21/13	< 1
Marie Reed ES	1st Floor Halway, by Main Entrance	5/21/13	< 1
Marie Reed ES	Ground Floor, Inside Gym	5/21/13	< 1
Marie Reed ES	Ground Floor, Inside Gym	5/21/13	< 1
Marie Reed ES	Ground Floor Hallway, by Boys Restroom	5/21/13	4.6
Marie Reed ES	Ground Floor Hallway, by Boys Restroom	5/21/13	2.7
Marie Reed ES	Ground Floor, Gym Hallway, by Exit Door	5/21/13	< 1
Marie Reed ES	Ground Floor, Gym Hallway, by Exit Door	5/21/13	< 1
Marie Reed ES	Ground Floor Clinic Hallway, by Receptionist	5/21/13	< 1
Marie Reed ES	Ground Floor Clinic Hallway, by Receptionist	5/21/13	< 1
Marie Reed ES	Ground Floor Clinic Hallway, by Women's Restroom	5/21/13	2.6
Marie Reed ES	Ground Floor Clinic Hallway, by Women's Restroom	5/21/13	1.4
Marie Reed ES	Ground Floor Auditorium, by Stage	5/21/13	1.4
Marie Reed ES	Ground Floor Auditorium, by Stage	5/21/13	1.8

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Marshall ES	Mezzanine Level, Next to Women's Restroom	5/31/13	< 1
Marshall ES	Mezzanine Level, Next to Women's Restroom	5/31/13	< 1
Marshall ES	Mezzanine Level, Next to Stairs	5/31/13	< 1
Marshall ES	Mezzanine Level, Next to Stairs	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 1	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 1	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 2	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 2	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 5	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 5	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 4	5/31/13	< 1
Marshall ES	Above Plaza Level, Next to Stairwell 4	5/31/13	< 1
Marshall ES	Plaza Level, in Common Area (High)	5/31/13	< 1
Marshall ES	Plaza Level, in Common Area (High)	5/31/13	< 1
Marshall ES	Plaza Level, in Common Area (Low)	5/31/13	< 1
Marshall ES	Plaza Level, in Common Area (Low)	5/31/13	< 1
Marshall ES	Plaza Level, Inside Health Clinic, Next to Boys Restroom	5/31/13	< 1
Marshall ES	Plaza Level, Inside Health Clinic, Next to Boys Restroom	5/31/13	< 1

Marshall ES	Plaza Level, Stage 1, Next to Teacher's Restroom	5/31/13	< 1
Marshall ES	Plaza Level, Stage 1, Next to Teacher's Restroom	5/31/13	< 1
Marshall ES	Plaza Level, Stage 1, Next to Steps	5/31/13	< 1
Marshall ES	Plaza Level, Stage 1, Next to Steps	5/31/13	< 1
Marshall ES	Below Plaza Level, Next Boys Restroom (High)	5/31/13	< 1
Marshall ES	Below Plaza Level, Next Boys Restroom (High)	5/31/13	< 1
Marshall ES	Below Plaza Level, Next Boys Restroom (Low)	5/31/13	< 1
Marshall ES	Below Plaza Level, Next Boys Restroom (Low)	5/31/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Maury ES	1st Floor, Inside Cafeteria	1/30/13	< 1
Maury ES	1st Floor, Inside Cafeteria	1/30/13	< 1
Maury ES	1st Floor Main Hallway, Next to Room E125	1/30/13	< 1
Maury ES	1st Floor Main Hallway, Next to Room E125	1/30/13	< 1
Maury ES	1st Floor, Inside Room E125	1/30/13	< 1
Maury ES	1st Floor, Inside Room E125	1/30/13	< 1
Maury ES	1st Floor, Inside Room E140	1/30/13	< 1
Maury ES	1st Floor, Inside Room E140	1/30/13	< 1
Maury ES	1st Floor, Inside Room E135	1/30/13	< 1
Maury ES	1st Floor, Inside Room E135	1/30/13	< 1
Maury ES	2nd Floor, Inside Room E240	1/30/13	< 1
Maury ES	2nd Floor, Inside Room E240	1/30/13	< 1
Maury ES	2nd Floor, Inside Room E230	1/30/13	< 1
Maury ES	2nd Floor, Inside Room E230	1/30/13	< 1
Maury ES	2nd Floor Hallway, Across from Room E220 (Art Room)	1/30/13	< 1
Maury ES	2nd Floor Hallway, Across from Room E220 (Art Room)	1/30/13	< 1
Maury ES	2nd Floor, West Wing Hallway Stairwell	1/30/13	< 1
Maury ES	2nd Floor, West Wing Hallway Stairwell	1/30/13	< 1
Maury ES	1st Floor, West Wing Hallway Stairwell	1/30/13	< 1
Maury ES	1st Floor, West Wing Hallway Stairwell	1/30/13	< 1
Maury ES	Basement Floor, Inside Room W030 (West Wing)	1/30/13	< 1
Maury ES	Basement Floor, Inside Room W030 (West Wing)	1/30/13	< 1
Maury ES	Basement Floor, Inside Room W010 (West Wing)	1/30/13	< 1
Maury ES	Basement Floor, Inside Room W010 (West Wing)	1/30/13	< 1
Maury ES	Basement Hallway, Next to Room W022 (West Wing, High)	1/30/13	< 1
Maury ES	Basement Hallway, Next to Room W022 (West Wing, High)	1/30/13	< 1
Maury ES	Basement Hallway, Next to Room W022 (West Wing, Low)	1/30/13	< 1
Maury ES	Basement Hallway, Next to Room W022 (West Wing, Low)	1/30/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
McKinley SHS	3rd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1
McKinley SHS	3rd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1
McKinley SHS	3rd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	3rd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	2nd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1
McKinley SHS	2nd Floor Hallway, at Entrance to Girls Restroom	6/11/13	< 1
McKinley SHS	2nd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	2nd Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	1st Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	1st Floor Hallway, at Entrance to Boys Restroom	6/11/13	< 1
McKinley SHS	Inside Gym (Low)	6/11/13	< 1
McKinley SHS	Inside Gym (Low)	6/11/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Meyer ES	2nd Floor Hallway, Next to Room 225	1/30/13	< 1
Meyer ES	2nd Floor Hallway, Next to Room 225	1/30/13	< 1
Meyer ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	2nd Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	2nd Floor Hallway, Next to Room 215	1/30/13	< 1
Meyer ES	2nd Floor Hallway, Next to Room 215	1/30/13	< 1
Meyer ES	1st Floor Hallway, Next to Room 115	1/30/13	< 1
Meyer ES	1st Floor Hallway, Next to Room 115	1/30/13	< 1
Meyer ES	1st Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	1st Floor Hallway, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	1st Floor Hallway, Next to Health Suite	1/30/13	< 1
Meyer ES	1st Floor Hallway, Next to Health Suite	1/30/13	< 1
Meyer ES	Ground Floor, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	Ground Floor, Between Boys and Girls Restroom	1/30/13	< 1
Meyer ES	Ground Floor, Across from Room G13	1/30/13	< 1
Meyer ES	Ground Floor, Across from Room G13	1/30/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Miner ES	2nd Floor, by Boys Restroom (Low)	3/15/13	< 1
Miner ES	2nd Floor, by Boys Restroom (Low)	3/15/13	< 1
Miner ES	2nd Floor, by Boys Restroom (High)	3/15/13	< 1
Miner ES	2nd Floor, by Boys Restroom (High)	3/15/13	< 1

Miner ES	1st Floor, Inside Room 109	3/15/13	< 1
Miner ES	1st Floor, Inside Room 109	3/15/13	< 1
Miner ES	1st Floor, Inside Room 111	3/15/13	< 1
Miner ES	1st Floor, Inside Room 111	3/15/13	< 1
Miner ES	1st Floor, Inside Room 115	3/15/13	< 1
Miner ES	1st Floor, Inside Room 115	3/15/13	< 1
Miner ES	1st Floor, Inside Room 117	3/15/13	< 1
Miner ES	1st Floor, Inside Room 117	3/15/13	< 1
Miner ES	1st Floor, Inside Room 119	3/15/13	< 1
Miner ES	1st Floor, Inside Room 119	3/15/13	< 1
Miner ES	1st Floor, Inside Room 121	3/15/13	< 1
Miner ES	1st Floor, Inside Room 121	3/15/13	< 1
Miner ES	1st Floor, Inside Room 123	3/15/13	< 1
Miner ES	1st Floor, Inside Room 123	3/15/13	< 1
Miner ES	1st Floor, Inside Room 127	3/15/13	< 1
Miner ES	1st Floor, Inside Room 127	3/15/13	< 1
Miner ES	1st Floor, Inside Room 129	3/15/13	< 1
Miner ES	1st Floor, Inside Room 129	3/15/13	< 1
Miner ES	1st Floor, Inside Room 131	3/15/13	< 1
Miner ES	1st Floor, Inside Room 131	3/15/13	< 1
Miner ES	1st Floor, Inside Room 133	3/15/13	< 1
Miner ES	1st Floor, Inside Room 133	3/15/13	< 1
Miner ES	1st Floor, Inside Room 135	3/15/13	< 1
Miner ES	1st Floor, Inside Room 135	3/15/13	< 1
Miner ES	1st Floor, Inside Room 137	3/15/13	< 1
Miner ES	1st Floor, Inside Room 137	3/15/13	< 1
Miner ES	1st Floor, Inside Room 130	3/15/13	6.6
Miner ES	1st Floor, Inside Room 130	3/15/13	< 1
Miner ES	1st Floor, Inside Room 132	3/15/13	< 1
Miner ES	1st Floor, Inside Room 132	3/15/13	< 1
Miner ES	1st Floor, by Room 136 (Low)	3/15/13	< 1
Miner ES	1st Floor, by Room 136 (Low)	3/15/13	< 1
Miner ES	1st Floor, by Room 136 (High)	3/15/13	< 1
Miner ES	1st Floor, by Room 136 (High)	3/15/13	< 1
Miner ES	1st Floor, by Room 146 (Low)	3/15/13	< 1
Miner ES	1st Floor, by Room 146 (Low)	3/15/13	< 1
Miner ES	1st Floor, by Room 146 (High)	3/15/13	< 1
Miner ES	1st Floor, by Room 146 (High)	3/15/13	< 1

			Percentage of Passed Samples
			Percentage of Failed Samples

Moten ES	3rd Floor Hallway, by Room 327	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 327	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 317	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 317	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 314 (High)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 314 (High)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 314 (Low)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 314 (Low)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 301 (High)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 301 (High)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 301 (Low)	4/11/13	< 1
Moten ES	3rd Floor Hallway, by Room 301 (Low)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 202 (High)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 202 (High)	4/11/13	< 1

Moten ES	2nd Floor Hallway, by Room 202 (Low)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 202 (Low)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 211 (High)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 211 (High)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 211 (Low)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 211 (Low)	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 219	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 219	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 224B	4/11/13	< 1
Moten ES	2nd Floor Hallway, by Room 224B	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 134	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 134	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 124	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 124	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 129 (High)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 129 (High)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 129 (Low)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 129 (Low)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 103 (High)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 103 (High)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 103 (Low)	4/11/13	< 1
Moten ES	1st Floor Hallway, by Room 103 (Low)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G06 (High)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G06 (High)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G06 (Low)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G06 (Low)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G10 (High)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G10 (High)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G10 (Low)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G10 (Low)	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G25	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G25	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G31	4/11/13	< 1
Moten ES	Ground Floor Hallway, by Room G31	4/11/13	< 1
Moten ES	Basement Floor Hallway, by Room B10	4/11/13	< 1
Moten ES	Basement Floor Hallway, by Room B10	4/11/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Murch ES	1st Floor, Next to Room 104	2/8/13	< 1
Murch ES	1st Floor, Next to Room 104	2/8/13	< 1
Murch ES	1st Floor, Next to Room 102	2/8/13	< 1
Murch ES	1st Floor, Next to Room 102	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 200A	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 200A	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 208	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 208	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 205	2/8/13	< 1
Murch ES	2nd Floor Hallway, by Room 205	2/8/13	< 1
Murch ES	1st Floor Hallway, by Room 101	2/8/13	< 1
Murch ES	1st Floor Hallway, by Room 101	2/8/13	< 1
Murch ES	1st Floor, Inside Gymnasium	2/8/13	< 1
Murch ES	1st Floor, Inside Gymnasium	2/8/13	< 1
Murch ES	Annex Building, Next to Room K3	2/8/13	< 1
Murch ES	Annex Building, Next to Room K3	2/8/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Nalle ES	2nd Floor Hallway, Outside Room 214 (High)	3/25/13	< 1
Nalle ES	2nd Floor Hallway, Outside Room 214 (High)	3/25/13	< 1
Nalle ES	2nd Floor Hallway, Outside Room 214 (Low)	3/25/13	< 1
Nalle ES	2nd Floor Hallway, Outside Room 214 (Low)	3/25/13	< 1
Nalle ES	2nd Floor Hallway, by Boys Restroom	3/25/13	< 1
Nalle ES	2nd Floor Hallway, by Boys Restroom	3/25/13	< 1
Nalle ES	1st Floor Hallway, by Boys Restroom	3/25/13	< 1
Nalle ES	1st Floor Hallway, by Boys Restroom	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 130	3/25/13	3.2
Nalle ES	1st Floor, Inside Room 130	3/25/13	1.3
Nalle ES	1st Floor, Inside Room 132	3/25/13	2
Nalle ES	1st Floor, Inside Room 132	3/25/13	1.3
Nalle ES	1st Floor, Inside Room 123	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 123	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 104	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 104	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 107	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 107	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 110	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 110	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 106	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 106	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 112	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 112	3/25/13	< 1
Nalle ES	1st Floor Hallway, Opposite to Room 112 (High)	3/25/13	< 1
Nalle ES	1st Floor Hallway, Opposite to Room 112 (High)	3/25/13	< 1
Nalle ES	1st Floor Hallway, Opposite to Room 112 (Low)	3/25/13	< 1
Nalle ES	1st Floor Hallway, Opposite to Room 112 (Low)	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 118	3/25/13	6.7
Nalle ES	1st Floor, Inside Room 118	3/25/13	4.8
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (High)	3/25/13	< 1
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (High)	3/25/13	< 1
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (Low)	3/25/13	< 1
Nalle ES	Ground Floor Hallway, Opposite to Room 005 (Low)	3/25/13	< 1
Nalle ES	1st Floor, Inside Room 128	3/25/13	3.9
Nalle ES	1st Floor, Inside Room 128	3/25/13	2.8
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Noyes ES	1st Floor, Inside Room 134	3/12/13	4.4
Noyes ES	1st Floor, Inside Room 134	3/12/13	1.1
Noyes ES	1st Floor, Inside Room 132	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 132	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 133	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 133	3/12/13	< 1

Noyes ES	1st Floor, Inside Room 135	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 135	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 131	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 131	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 129	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 129	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 128	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 128	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 130	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 130	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 116 (High)	3/12/13	2.2
Noyes ES	1st Floor Hallway, Next to Room 116 (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 116 (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 116 (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Auditorium (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Auditorium (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Auditorium (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Auditorium (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 108 (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 108 (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 108 (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Room 108 (Low)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Elevator (High)	3/12/13	< 1
Noyes ES	1st Floor Hallway, Next to Elevator (High)	3/12/13	1
Noyes ES	1st Floor Hallway, Next to Elevator (Low)	3/12/13	3.6
Noyes ES	1st Floor Hallway, Next to Elevator (Low)	3/12/13	< 1
Noyes ES	2nd Floor Hallway, Next to Room 202 (High)	3/12/13	< 1
Noyes ES	2nd Floor Hallway, Next to Room 202 (High)	3/12/13	< 1
Noyes ES	2nd Floor Hallway, Next to Room 202 (Low)	3/12/13	< 1
Noyes ES	2nd Floor Hallway, Next to Room 202 (Low)	3/12/13	< 1
Noyes ES	2nd Floor, Inside Ms. Lilly's Room, Next to Room 205	3/12/13	< 1
Noyes ES	2nd Floor, Inside Ms. Lilly's Room, Next to Room 205	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 205	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 205	3/12/13	< 1
Noyes ES	2nd Floor, Inside Ms. Dorth's Room, Next to Room 204	3/12/13	< 1
Noyes ES	2nd Floor, Inside Ms. Dorth's Room, Next to Room 204	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 204	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 204	3/12/13	1.9
Noyes ES	2nd Floor, Inside Room 213	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 213	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 216	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 216	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 214	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 214	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 112	3/12/13	< 1
Noyes ES	1st Floor, Inside Room 112	3/12/13	< 1
Noyes ES	2nd Floor, Inside Room 212	3/12/13	1.1
Noyes ES	2nd Floor, Inside Room 212	3/12/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Orr ES	4th Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	4th Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	4th Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	4th Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	3rd Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	3rd Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	3rd Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	3rd Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	2nd Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	2nd Floor Hallway, Next to Boys Restroom	1/31/13	< 1
Orr ES	2nd Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	2nd Floor Hallway, Next to Girls Restroom	1/31/13	< 1
Orr ES	1st Floor Hallway, Next to Parents' Resource Room	1/31/13	< 1
Orr ES	1st Floor Hallway, Next to Parents' Resource Room	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Supply Room	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Supply Room	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Girls Restroom	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Girls Restroom	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Kitchen	1/31/13	< 1
Orr ES	1st Floor, Inside Gym, Next to Kitchen	1/31/13	< 1
Orr ES	1st Floor Hallway, Next to Teachers' Lounge	1/31/13	< 1
Orr ES	1st Floor Hallway, Next to Teachers' Lounge	1/31/13	< 1
Orr ES	1st Floor, Inside Kindergarten Room 135	1/31/13	< 1
Orr ES	1st Floor, Inside Kindergarten Room 135	1/31/13	< 1
Orr ES	1st Floor, Inside Kindergarten Room 131	1/31/13	< 1
Orr ES	1st Floor, Inside Kindergarten Room 131	1/31/13	< 1
Orr ES	1st Floor, Inside Pre-K Room 124	1/31/13	1.5
Orr ES	1st Floor, Inside Pre-K Room 124	1/31/13	1.6
Orr ES	1st Floor, Inside Pre-K Room 121	1/31/13	< 1
Orr ES	1st Floor, Inside Pre-K Room 121	1/31/13	< 1
Orr ES	1st Floor, Across from Main Office	1/31/13	< 1
Orr ES	1st Floor, Across from Main Office	1/31/13	< 1
Orr ES	1st Floor, Inside Health Suite	1/31/13	< 1
Orr ES	1st Floor, Inside Health Suite	1/31/13	< 1

			Percentage of Passed Samples
			Percentage of Failed Samples

Oyster ES	4th Floor, Inside Room 415	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 415	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 412	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 412	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 410	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 410	3/12/13	< 1
Oyster ES	4th Floor, by Room 409 (Low)	3/12/13	< 1
Oyster ES	4th Floor, by Room 409 (Low)	3/12/13	< 1
Oyster ES	4th Floor, by Room 409 (High)	3/12/13	< 1
Oyster ES	4th Floor, by Room 409 (High)	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 407	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 407	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 405	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 405	3/12/13	< 1

Oyster ES	4th Floor, Inside Room 401	3/12/13	< 1
Oyster ES	4th Floor, Inside Room 401	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 316	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 316	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 313	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 313	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 309	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 309	3/12/13	< 1
Oyster ES	3rd Floor, by Room 309 (Low)	3/12/13	< 1
Oyster ES	3rd Floor, by Room 309 (Low)	3/12/13	< 1
Oyster ES	3rd Floor, by Room 309 (High)	3/12/13	< 1
Oyster ES	3rd Floor, by Room 309 (High)	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 308	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 308	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 304	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 304	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 301	3/12/13	< 1
Oyster ES	3rd Floor, Inside Room 301	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 211	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 211	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 210	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 210	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 202	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 202	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 201	3/12/13	< 1
Oyster ES	2nd Floor, Inside Room 201	3/12/13	< 1
Oyster ES	2nd Floor, by Room 206 (Low)	3/12/13	< 1
Oyster ES	2nd Floor, by Room 206 (Low)	3/12/13	< 1
Oyster ES	2nd Floor, by Room 206 (High)	3/12/13	< 1
Oyster ES	2nd Floor, by Room 206 (High)	3/12/13	< 1
Oyster ES	2nd Floor, Inside Gymnasium (Low)	3/12/13	< 1
Oyster ES	2nd Floor, Inside Gymnasium (Low)	3/12/13	< 1
Oyster ES	2nd Floor, Inside Gymnasium (High)	3/12/13	< 1
Oyster ES	2nd Floor, Inside Gymnasium (High)	3/12/13	< 1
Oyster ES	1st Floor, Inside Room 104	3/12/13	< 1
Oyster ES	1st Floor, Inside Room 104	3/12/13	< 1
Oyster ES	1st Floor, by Room 105 (Low)	3/12/13	< 1
Oyster ES	1st Floor, by Room 105 (Low)	3/12/13	< 1
Oyster ES	1st Floor, by Room 105 (High)	3/12/13	< 1
Oyster ES	1st Floor, by Room 105 (High)	3/12/13	< 1
Oyster ES	1st Floor, Inside Room 107	3/12/13	< 1
Oyster ES	1st Floor, Inside Room 107	3/12/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Parkview ES	2nd Floor, by Room 213	3/15/13	< 1
Parkview ES	2nd Floor, by Room 213	3/15/13	< 1
Parkview ES	2nd Floor, by Room 201	3/15/13	< 1
Parkview ES	2nd Floor, by Room 201	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 121	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 121	3/15/13	< 1
Parkview ES	1st Floor, by Main Office	3/15/13	< 1
Parkview ES	1st Floor, by Main Office	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 122	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 122	3/15/13	< 1

Parkview ES	1st Floor, Inside Room 123	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 123	3/15/13	< 1
Parkview ES	1st Floor, by Room 127	3/15/13	< 1
Parkview ES	1st Floor, by Room 127	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 126	3/15/13	< 1
Parkview ES	1st Floor, Inside Room 126	3/15/13	< 1
Parkview ES	1st Floor, by Room 134	3/15/13	< 1
Parkview ES	1st Floor, by Room 134	3/15/13	< 1
Parkview ES	2nd Floor, Inside Room 221	3/15/13	< 1
Parkview ES	2nd Floor, Inside Room 221	3/15/13	< 1
Parkview ES	Basement Floor, by Gymnasium	3/15/13	< 1
Parkview ES	Basement Floor, by Gymnasium	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 21	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 21	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 22	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 22	3/15/13	< 1
Parkview ES	Basement Floor, by Room 21	3/15/13	< 1
Parkview ES	Basement Floor, by Room 21	3/15/13	1.1
Parkview ES	Basement Floor, Inside Room 24	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 24	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 06	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 06	3/15/13	< 1
Parkview ES	Basement Floor, by Room 06	3/15/13	< 1
Parkview ES	Basement Floor, by Room 06	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 07	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 07	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 08	3/15/13	< 1
Parkview ES	Basement Floor, Inside Room 08	3/15/13	< 1
Parkview ES	Basement Floor, by Lunch Room	3/15/13	< 1
Parkview ES	Basement Floor, by Lunch Room	3/15/13	< 1
			Percentage of Passed Samples
			Percentage of Failed Samples
Patterson MS	3rd Floor, Inside Room 323	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 323	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 324	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 324	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 317	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 317	2/21/13	< 1
Patterson MS	3rd Floor, Inside Room 316	2/21/13	5.9
Patterson MS	3rd Floor, Inside Room 316	2/21/13	7.3
Patterson MS	3rd Floor, Inside Room 307	2/21/13	2.4
Patterson MS	3rd Floor, Inside Room 307	2/21/13	1.5
Patterson MS	3rd Floor, Inside Room 312	2/21/13	1.7
Patterson MS	3rd Floor, Inside Room 312	2/21/13	1.9
Patterson MS	3rd Floor, Inside Room 311	2/21/13	3
Patterson MS	3rd Floor, Inside Room 311	2/21/13	
Patterson MS	<i>3rd Floor, Inside Room 311 - Retest</i>	2/27/13	< 1
Patterson MS	<i>3rd Floor, Inside Room 311 - Retest</i>	2/27/13	< 1
Patterson MS	3rd Floor, by Room 302 (High)	2/21/13	< 1
Patterson MS	3rd Floor, by Room 302 (High)	2/21/13	< 1
Patterson MS	3rd Floor, by Room 302 (Low)	2/21/13	< 1
Patterson MS	3rd Floor, by Room 302 (Low)	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 222	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 222	2/21/13	< 1

Patterson MS	2nd Floor, Inside Room 223	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 223	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 221	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 221	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 224	2/21/13	1.1
Patterson MS	2nd Floor, Inside Room 224	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 225	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 225	2/21/13	1.3
Patterson MS	2nd Floor, Inside Room 230	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 230	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 232	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 232	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 213	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 213	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 216	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 216	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 214	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 214	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 215	2/21/13	< 1
Patterson MS	2nd Floor, Inside Room 215	2/21/13	< 1
Patterson MS	2nd Floor, Opposite to Room 208B (High)	2/21/13	< 1
Patterson MS	2nd Floor, Opposite to Room 208B (High)	2/21/13	< 1
Patterson MS	2nd Floor, Opposite to Room 208B (Low)	2/21/13	< 1
Patterson MS	2nd Floor, Opposite to Room 208B (Low)	2/21/13	< 1
Patterson MS	1st Floor, inside Room 119	2/21/13	< 1
Patterson MS	1st Floor, inside Room 119	2/21/13	< 1
Patterson MS	1st Floor, inside Room 120	2/21/13	< 1
Patterson MS	1st Floor, inside Room 120	2/21/13	< 1
Patterson MS	1st Floor, inside Room 123	2/21/13	< 1
Patterson MS	1st Floor, inside Room 123	2/21/13	< 1
Patterson MS	1st Floor, inside Room 115	2/21/13	< 1
Patterson MS	1st Floor, inside Room 115	2/21/13	< 1
Patterson MS	1st Floor, inside Room 125	2/21/13	< 1
Patterson MS	1st Floor, inside Room 125	2/21/13	< 1
Patterson MS	1st Floor, inside Room 132	2/21/13	< 1
Patterson MS	1st Floor, inside Room 132	2/21/13	< 1
Patterson MS	1st Floor, inside Room 131	2/21/13	< 1
Patterson MS	1st Floor, inside Room 131	2/21/13	< 1
Patterson MS	1st Floor, inside Room 127	2/21/13	< 1
Patterson MS	1st Floor, inside Room 127	2/21/13	< 1
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1
Patterson MS	1st Floor Hallway, by Room 110	2/21/13	< 1

		Percentage of Passed Samples	
--	--	------------------------------	--

		Percentage of Failed Samples	
--	--	------------------------------	--

Payne ES	1st Floor Hallway, Next to Room 27	3/21/13	< 1
Payne ES	1st Floor Hallway, Next to Room 27	3/21/13	< 1
Payne ES	1st Floor, Inside Room 12	3/21/13	1.2
Payne ES	1st Floor, Inside Room 12	3/21/13	1.8
Payne ES	1st Floor, Inside Lunch Room	3/21/13	< 1
Payne ES	1st Floor, Inside Lunch Room	3/21/13	< 1
Payne ES	1st Floor, Inside Room 64	3/21/13	4.1
Payne ES	1st Floor, Inside Room 64	3/21/13	1.9

Payne ES	1st Floor, Inside Room 110	3/21/13	1.4
Payne ES	1st Floor, Inside Room 110	3/21/13	1.6
Payne ES	1st Floor, Inside Room 104	3/21/13	2.4
Payne ES	1st Floor, Inside Room 104	3/21/13	1.9
Payne ES	2nd Floor, Next to Room 132	3/21/13	< 1
Payne ES	2nd Floor, Next to Room 132	3/21/13	< 1
Payne ES	2nd Floor, Next to Room 142	3/21/13	< 1
Payne ES	2nd Floor, Next to Room 142	3/21/13	< 1
Payne ES	1st Floor, Next to Room 90	3/21/13	< 1
Payne ES	1st Floor, Next to Room 90	3/21/13	< 1
Payne ES	1st Floor, Next to Room 114	3/21/13	< 1
Payne ES	1st Floor, Next to Room 114	3/21/13	< 1
Payne ES	3rd Floor, Next to Room 169	3/21/13	< 1
Payne ES	3rd Floor, Next to Room 169	3/21/13	< 1
Payne ES	3rd Floor, Next to Room 174	3/21/13	< 1
Payne ES	3rd Floor, Next to Room 174	3/21/13	< 1
Payne ES	2nd Floor, Next to Room 129	3/21/13	< 1
Payne ES	2nd Floor, Next to Room 129	3/21/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Peabody ES	3rd Floor Hallway, Outside Room 10	3/5/13	< 1
Peabody ES	3rd Floor Hallway, Outside Room 10	3/5/13	< 1
Peabody ES	2nd Floor Hallway, Outside Teachers' Lounge	3/5/13	< 1
Peabody ES	2nd Floor Hallway, Outside Teachers' Lounge	3/5/13	< 1
Peabody ES	1st Floor Hallway, Outside Main Office	3/5/13	< 1
Peabody ES	1st Floor Hallway, Outside Main Office	3/5/13	< 1
Peabody ES	Basement Floor, at Entrance to Boys Restroom	3/5/13	< 1
Peabody ES	Basement Floor, at Entrance to Boys Restroom	3/5/13	< 1
Peabody ES	Basement Floor, at Entrance to Girls Restroom	3/5/13	< 1
Peabody ES	Basement Floor, at Entrance to Girls Restroom	3/5/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Phelps HS	1st Floor Hallway, by Room C108	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room C108	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room C110	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room C110	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C211	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C211	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C207	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C207	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C206	6/5/13	< 1
Phelps HS	2nd Floor Hallway, by Room C206	6/5/13	< 1
Phelps HS	Basement Floor Hallway, by Room S005	6/5/13	< 1
Phelps HS	Basement Floor Hallway, by Room S005	6/5/13	< 1
Phelps HS	Basement Floor Hallway, by Room S001	6/5/13	< 1
Phelps HS	Basement Floor Hallway, by Room S001	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room T104	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room T104	6/5/13	< 1

Phelps HS	1st Floor Hallway, by Room T106	6/5/13	< 1
Phelps HS	1st Floor Hallway, by Room T106	6/5/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Plummer ES	1st Floor Hallway, Outside Main Office	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Main Office	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Room 134	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Room 134	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Girls Restroom	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Girls Restroom	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Room 139	5/13/13	< 1
Plummer ES	1st Floor Hallway, Outside Room 139	5/13/13	< 1
Plummer ES	3rd Floor Hallway, by Room 219	5/13/13	< 1
Plummer ES	3rd Floor Hallway, by Room 219	5/13/13	3.5
Plummer ES	3rd Floor Hallway, by Teachers' Restroom	5/13/13	1.8
Plummer ES	3rd Floor Hallway, by Teachers' Restroom	5/13/13	2.4
Plummer ES	3rd Floor Hallway, by Boys Restroom	5/13/13	1.2
Plummer ES	3rd Floor Hallway, by Boys Restroom	5/13/13	2.4
Plummer ES	3rd Floor Hallway, by Room 212	5/13/13	< 1
Plummer ES	3rd Floor Hallway, by Room 212	5/13/13	< 1
Plummer ES	2nd Floor Hallway, Outside Library	5/13/13	< 1
Plummer ES	2nd Floor Hallway, Outside Library	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Room 127	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Room 127	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Boys Restroom	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Boys Restroom	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Room 132	5/13/13	< 1
Plummer ES	2nd Floor Hallway, by Room 132	5/13/13	< 1
Plummer ES	2nd Floor, Inside Pre-K Room 116	5/13/13	6.1
Plummer ES	2nd Floor, Inside Pre-K Room 116	5/13/13	1.6
Plummer ES	2nd Floor, Inside Pre-K Room 109	5/13/13	< 1
Plummer ES	2nd Floor, Inside Pre-K Room 109	5/13/13	< 1
Plummer ES	2nd Floor, Inside Lunch Room	5/13/13	< 1
Plummer ES	2nd Floor, Inside Lunch Room	5/13/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Powell ES	1st Floor, Inside Room 108	4/17/13	< 1
Powell ES	1st Floor, Inside Room 108	4/17/13	< 1
Powell ES	1st Floor Hallway, by Janitor's Closet	4/17/13	< 1
Powell ES	1st Floor Hallway, by Janitor's Closet	4/17/13	< 1
Powell ES	2nd Floor, Hallway, by Janitor's Closet	4/17/13	< 1
Powell ES	2nd Floor, Hallway, by Janitor's Closet	4/17/13	< 1
Powell ES	2nd Floor Hallway, by Room 219	4/17/13	< 1
Powell ES	2nd Floor Hallway, by Room 219	4/17/13	< 1
Powell ES	2nd Floor Hallway, by Room 203	4/17/13	< 1
Powell ES	2nd Floor Hallway, by Room 203	4/17/13	< 1
Powell ES	1st Floor, Inside Cafeteria	4/17/13	< 1
Powell ES	1st Floor, Inside Cafeteria	4/17/13	< 1
Powell ES	1st Floor, Inside Health Suite	4/17/13	< 1
Powell ES	1st Floor, Inside Health Suite	4/17/13	< 1
Powell ES	1st Floor Hallway, Outside Room 108	4/17/13	< 1
Powell ES	1st Floor Hallway, Outside Room 108	4/17/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	

Prospect LC	Basement Floor Hallway, Next to Custodian's Closet	5/15/13	< 1
Prospect LC	Basement Floor Hallway, Next to Custodian's Closet	5/15/13	< 1
Prospect LC	Basement Floor, Inside Cafeteria	5/15/13	< 1
Prospect LC	Basement Floor, Inside Cafeteria	5/15/13	< 1
Prospect LC	4th Floor Hallway, Next to Room 403	5/15/13	< 1
Prospect LC	4th Floor Hallway, Next to Room 403	5/15/13	< 1
Prospect LC	4th Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1
Prospect LC	4th Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1
Prospect LC	3rd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1
Prospect LC	3rd Floor Hallway, Next to Teachers' Restroom	5/15/13	2
Prospect LC	4th Floor Hallway, Next to Room 303	5/15/13	< 1
Prospect LC	4th Floor Hallway, Next to Room 303	5/15/13	< 1
Prospect LC	2nd Floor Hallway, Next to Room 203	5/15/13	< 1
Prospect LC	2nd Floor Hallway, Next to Room 203	5/15/13	< 1
Prospect LC	2nd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1
Prospect LC	2nd Floor Hallway, Next to Teachers' Restroom	5/15/13	< 1
Prospect LC	1st Floor Hallway, Next to Custodian's Closet	5/15/13	< 1
Prospect LC	1st Floor Hallway, Next to Custodian's Closet	5/15/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Randle Highlands ES	2nd Floor Hallway, by Elevator (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor Hallway, by Elevator (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor Hallway, by Elevator (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor Hallway, by Elevator (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2231 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2231 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2231 (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2231 (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2226 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2226 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2226 (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2226 (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2224 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2224 (High)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2224 (Low)	5/22/13	< 1
Randle Highlands ES	2nd Floor, In Vestibule 2224 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (High)	5/22/13	< 1
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (High)	5/22/13	< 1
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor Hallway, by Room 2114 & Elevator (Low)	5/22/13	< 1

Randle Highlands ES	1st Floor, In Vestibule 2131 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2131 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2131 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2131 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2126 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2126 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2126 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2126 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2121 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2121 (High)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2121 (Low)	5/22/13	< 1
Randle Highlands ES	1st Floor, In Vestibule 2121 (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2031 (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2031 (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2031 (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2031 (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor Hallway, by Room 2014 & Elevator (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2026 (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2026 (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2026 (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule 2026 (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (High)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (Low)	5/22/13	< 1
Randle Highlands ES	Ground Floor, In Vestibule Next to Main Office (Low)	5/22/13	< 1
Randle Highlands ES	Gym Hallway, by Room 3001 Music Room	5/22/13	< 1
Randle Highlands ES	Gym Hallway, by Room 3001 Music Room	5/22/13	< 1
Randle Highlands ES	Basement Hallway, by Elevator (High)	5/22/13	< 1
Randle Highlands ES	Basement Hallway, by Elevator (High)	5/22/13	< 1
Randle Highlands ES	Basement Hallway, by Elevator (Low)	5/22/13	< 1
Randle Highlands ES	Basement Hallway, by Elevator (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B31 (High)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B31 (High)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B31 (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B31 (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B26 (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B26 (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B21 (High)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B21 (High)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B21 (Low)	5/22/13	< 1
Randle Highlands ES	Basement, In Vestibule 2B21 (Low)	5/22/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Raymond ES	1st Floor Hallway, Across from Kitchen	1/25/13	< 1
Raymond ES	1st Floor Hallway, Across from Kitchen	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Health Suite	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Health Suite	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Room 110	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Room 116	1/25/13	< 1
Raymond ES	1st Floor Hallway, Next to Room 116	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 110	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 110	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 111	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 111	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 113	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 113	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 115	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 115	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 117	1/25/13	1
Raymond ES	1st Floor, Inside Room 117	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 116	1/25/13	< 1
Raymond ES	1st Floor, Inside Room 116	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Across from Room 209	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Across from Room 209	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Across from Room 217	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Across from Room 217	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Next to Room 26	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Next to Room 26	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Next to Room 22	1/25/13	< 1
Raymond ES	2nd Floor Hallway, Next to Room 22	1/25/13	< 1
Raymond ES	3rd Floor Hallway, Next to Room 30	1/25/13	< 1
Raymond ES	3rd Floor Hallway, Next to Room 30	1/25/13	< 1
Raymond ES	3rd Floor Hallway, Next to Room 36	1/25/13	< 1
Raymond ES	3rd Floor Hallway, Next to Room 36	1/25/13	< 1

Percentage of Passed Samples			
------------------------------	--	--	--

Percentage of Failed Samples			
------------------------------	--	--	--

Ron Brown MS	1st Floor Hallway, Across from Room 1124	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Across from Room 1124	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Across from Room 1126	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Across from Room 1126	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Across from Incinerator, Room 1137	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Across from Incinerator, Room 1137	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Next to Room 1175	5/10/13	< 1
Ron Brown MS	1st Floor Hallway, Next to Room 1175	5/10/13	< 1
Ron Brown MS	1st Floor, Cafeteria, Next to Room 2133D	5/10/13	< 1
Ron Brown MS	1st Floor, Cafeteria, Next to Room 2133D	5/10/13	< 1
Ron Brown MS	1st Floor, Cafeteria, Next to Supply/Storage Room 2131	5/10/13	< 1
Ron Brown MS	1st Floor, Cafeteria, Next to Supply/Storage Room 2131	5/10/13	< 1
Ron Brown MS	1st Floor, Multi-Purpose Room, Next to Supply Room 2127	5/10/13	< 1
Ron Brown MS	1st Floor, Multi-Purpose Room, Next to Supply Room 2127	5/10/13	< 1

Ron Brown MS	2nd Floor, Gym Hallway, Next to Girls Restroom 2208	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym Hallway, Next to Girls Restroom 2208	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym Hallway, Next to Boys Restroom 2223	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym Hallway, Next to Boys Restroom 2223	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym, Next to Supply Room 2209	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym, Next to Supply Room 2209	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym, In Wall B Area	5/10/13	< 1
Ron Brown MS	2nd Floor, Gym, In Wall B Area	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Near Room 1206	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Near Room 1206	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Next to Teachers' Lounge 1247	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Next to Teachers' Lounge 1247	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Near Room 1218	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Near Room 1218	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Across from Room 1222	5/10/13	< 1
Ron Brown MS	2nd Floor Hallway, Across from Room 1222	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Across from Room 1320	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Across from Room 1320	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Near Room 1316	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Near Room 1316	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Across from Room 1309	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Across from Room 1309	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Near Room 1306	5/10/13	< 1
Ron Brown MS	3rd Floor Hallway, Near Room 1306	5/10/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Roosevelt SHS	3rd Floor Hallway, Across from 301 (Main Office)	6/10/13	< 1
Roosevelt SHS	3rd Floor Hallway, Across from 301 (Main Office)	6/10/13	< 1
Roosevelt SHS	3rd Floor Hallway, Next to Room 331	6/10/13	< 1
Roosevelt SHS	3rd Floor Hallway, Next to Room 331	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 230	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 230	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 236	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 236	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 200	6/10/13	< 1
Roosevelt SHS	2nd Floor Hallway, Next to Room 200	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, at Entrance to Auditorium	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, at Entrance to Auditorium	6/10/13	< 1
Roosevelt SHS	Inside Library	6/10/13	1.1
Roosevelt SHS	Inside Library	6/10/13	2.5
Roosevelt SHS	1st Floor Hallway, Across from Room 194	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, Across from Room 194	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, Next to Room 132	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, Next to Room 132	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, Next to Room 138	6/10/13	< 1
Roosevelt SHS	1st Floor Hallway, Next to Room 138	6/10/13	< 1

Roosevelt SHS	1st Floor Hallway, at Entrance to Gym	6/10/13	< 1	
Roosevelt SHS	1st Floor Hallway, at Entrance to Gym	6/10/13	< 1	
Roosevelt SHS	Basement Hallway, Across from Old Elevator	6/10/13	< 1	
Roosevelt SHS	Basement Hallway, Across from Old Elevator	6/10/13	< 1	
Roosevelt SHS	Basement Hallway, Across from Cafeteria	6/10/13	< 1	
Roosevelt SHS	Basement Hallway, Across from Cafeteria	6/10/13	< 1	
Roosevelt SHS	Inside Kitchen	6/10/13	1.1	
Roosevelt SHS	Inside Kitchen	6/10/13	1.9	
Roosevelt SHS	Inside Kitchen, Near Office 12-A	6/10/13		99
Roosevelt SHS	Inside Kitchen, Near Office 12-A	6/10/13		810
Roosevelt SHS	<i>Inside Kitchen, Near Office 12-A - Retest</i>	6/26/13	1.3	
Roosevelt SHS	<i>Inside Kitchen, Near Office 12-A - Retest</i>	6/26/13	1.5	
Roosevelt SHS	Basement Hallway, Next to Room B-16	6/10/13	1	
Roosevelt SHS	Basement Hallway, Next to Room B-16	6/10/13		19
Roosevelt SHS	<i>Basement Hallway, Next to Room B-16 - Retest</i>	6/26/13	1.2	
Roosevelt SHS	<i>Basement Hallway, Next to Room B-16 - Retest</i>	6/26/13	1.6	

Percentage of Passed Samples			
Percentage of Failed Samples			

Ross ES	Basement Hallway, Outside Adult Restroom (High)	4/26/13	< 1	
Ross ES	Basement Hallway, Outside Adult Restroom (High)	4/26/13	< 1	
Ross ES	Basement Hallway, Outside Adult Restroom (Low)	4/26/13	< 1	
Ross ES	Basement Hallway, Outside Adult Restroom (Low)	4/26/13	< 1	
Ross ES	Basement Floor, Inside Lunch Room (High)	4/26/13	< 1	
Ross ES	Basement Floor, Inside Lunch Room (High)	4/26/13	< 1	
Ross ES	Basement Floor, Inside Lunch Room (Low)	4/26/13	< 1	
Ross ES	Basement Floor, Inside Lunch Room (Low)	4/26/13	< 1	
Ross ES	1st Floor Hallway, Outside Room 105 (High)	4/26/13	< 1	
Ross ES	1st Floor Hallway, Outside Room 105 (High)	4/26/13	< 1	
Ross ES	1st Floor Hallway, Outside Room 105 (Low)	4/26/13	< 1	
Ross ES	1st Floor Hallway, Outside Room 105 (Low)	4/26/13	< 1	
Ross ES	2nd Floor Hallway, (High)	4/26/13	< 1	
Ross ES	2nd Floor Hallway, (High)	4/26/13	< 1	
Ross ES	2nd Floor Hallway, (Low)	4/26/13	< 1	
Ross ES	2nd Floor Hallway, (Low)	4/26/13	< 1	
Ross ES	Bubbler, Outside by Playground/School Entrance	4/26/13	< 1	
Ross ES	Bubbler, Outside by Playground/School Entrance	4/26/13	< 1	

Percentage of Passed Samples			
Percentage of Failed Samples			

Savoy ES	3rd Floor Hallway, Across from Room 300 (High)	5/23/13	< 1	
Savoy ES	3rd Floor Hallway, Across from Room 300 (High)	5/23/13	< 1	
Savoy ES	3rd Floor Hallway, Across from Room 300 (Low)	5/23/13	< 1	

Savoy ES	3rd Floor Hallway, Across from Room 300 (Low)	5/23/13	< 1
Savoy ES	3rd Floor Hallway, Across from Girls Room (High)	5/23/13	< 1
Savoy ES	3rd Floor Hallway, Across from Girls Room (High)	5/23/13	< 1
Savoy ES	3rd Floor Hallway, Across from Girls Room (Low)	5/23/13	< 1
Savoy ES	3rd Floor Hallway, Across from Girls Room (Low)	5/23/13	< 1
Savoy ES	1st Floor Hallway, at Entrance to Gym (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, at Entrance to Gym (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, at Entrance to Gym (Low)	5/23/13	< 1
Savoy ES	1st Floor Hallway, at Entrance to Gym (Low)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (Low)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Between Boys and Girls Restroom (Low)	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 113	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 113	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 115	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 115	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 120	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 120	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 122	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 122	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 109	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 109	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 111	5/23/13	< 1
Savoy ES	1st Floor, Inside Room 111	5/23/13	< 1
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (High)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (Low)	5/23/13	< 1
Savoy ES	1st Floor Hallway, Across from Fitness Room 123 (Low)	5/23/13	< 1
Savoy ES	Inside Library (High)	5/23/13	< 1
Savoy ES	Inside Library (High)	5/23/13	< 1
Savoy ES	Inside Library (Low)	5/23/13	< 1
Savoy ES	Inside Library (Low)	5/23/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
School without Walls	3rd Floor, by Elevator (High)	6/4/13	< 1
School without Walls	3rd Floor, by Elevator (High)	6/4/13	< 1
School without Walls	3rd Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	3rd Floor, by Elevator (Low)	6/4/13	< 1

School without Walls	2nd Floor, by Elevator (High)	6/4/13	< 1
School without Walls	2nd Floor, by Elevator (High)	6/4/13	< 1
School without Walls	2nd Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	2nd Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	1st Floor, by Elevator (High)	6/4/13	< 1
School without Walls	1st Floor, by Elevator (High)	6/4/13	< 1
School without Walls	1st Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	1st Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	Basement Floor, by Elevator (High)	6/4/13	< 1
School without Walls	Basement Floor, by Elevator (High)	6/4/13	< 1
School without Walls	Basement Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	Basement Floor, by Elevator (Low)	6/4/13	< 1
School without Walls	Lower Level, by Elevator (High)	6/4/13	< 1
School without Walls	Lower Level, by Elevator (High)	6/4/13	< 1
School without Walls	Lower Level, by Elevator (Low)	6/4/13	< 1
School without Walls	Lower Level, by Elevator (Low)	6/4/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Seaton ES	3rd Floor, Inside Room 309	5/1/13	< 1
Seaton ES	3rd Floor, Inside Room 309	5/1/13	< 1
Seaton ES	3rd Floor Hallway, by Girls Restroom	5/1/13	1.6
Seaton ES	3rd Floor Hallway, by Girls Restroom	5/1/13	< 1
Seaton ES	3rd Floor Hallway, by Boys Restroom	5/1/13	< 1
Seaton ES	3rd Floor Hallway, by Boys Restroom	5/1/13	< 1
Seaton ES	2nd Floor Hallway, by Girls Restroom	5/1/13	< 1
Seaton ES	2nd Floor Hallway, by Girls Restroom	5/1/13	< 1
Seaton ES	3rd Floor Hallway, by Room 206	5/1/13	< 1
Seaton ES	3rd Floor Hallway, by Room 206	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 122	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 122	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 125	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 125	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 124	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 124	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 127	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 127	5/1/13	< 1
Seaton ES	1st Floor, Inside Multi-Purpose Room	5/1/13	< 1
Seaton ES	1st Floor, Inside Multi-Purpose Room	5/1/13	< 1
Seaton ES	1st Floor Hallway, by Room 106	5/1/13	< 1
Seaton ES	1st Floor Hallway, by Room 106	5/1/13	2
Seaton ES	1st Floor, Inside Room 109	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 109	5/1/13	1.3
Seaton ES	1st Floor, Inside Room 111	5/1/13	< 1
Seaton ES	1st Floor, Inside Room 111	5/1/13	< 1
Seaton ES	3rd Floor, Inside Room 307	5/1/13	< 1
Seaton ES	3rd Floor, Inside Room 307	5/1/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Shadd ES	1st Floor Hallway, Across from Room 108	6/14/13	< 1
Shadd ES	1st Floor Hallway, Across from Room 108	6/14/13	< 1
Shadd ES	1st Floor Hallway, Across from Lunch Room	6/14/13	< 1
Shadd ES	1st Floor Hallway, Across from Lunch Room	6/14/13	< 1
Shadd ES	1st Floor Hallway, Across from Room 105	6/14/13	< 1
Shadd ES	1st Floor Hallway, Across from Room 105	6/14/13	< 1

Shadd ES	2nd Floor Hallway, Next to Main Office	6/14/13	< 1
Shadd ES	2nd Floor Hallway, Next to Main Office	6/14/13	< 1
Shadd ES	2nd Floor Hallway, Across from Main Office	6/14/13	< 1
Shadd ES	2nd Floor Hallway, Across from Main Office	6/14/13	< 1
Shadd ES	2nd Floor Hallway, Next to Library	6/14/13	< 1
Shadd ES	2nd Floor Hallway, Next to Library	6/14/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Sharpe Health School	1st Floor Hallway, Across from Room 201	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Room 201	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Play Room	5/6/13	1.5
Sharpe Health School	1st Floor Hallway, Next to Play Room	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 207	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 207	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Dining Room	5/6/13	1.8
Sharpe Health School	1st Floor Hallway, Across from Dining Room	5/6/13	< 1
Sharpe Health School	1st Floor, Inside Dining Room	5/6/13	< 1
Sharpe Health School	1st Floor, Inside Dining Room	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 108	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 108	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Men's Locker		
Sharpe Health School	Room	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Men's Locker		
Sharpe Health School	Room	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 102	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Next to Room 102	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Kitchen	5/6/13	< 1
Sharpe Health School	1st Floor Hallway, Across from Kitchen	5/6/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Shepherd ES	1st Floor, Inside Room 132	4/8/13	< 1
Shepherd ES	1st Floor, Inside Room 132	4/8/13	< 1
Shepherd ES	1st Floor, Inside Room 101	4/8/13	< 1
Shepherd ES	1st Floor, Inside Room 101	4/8/13	< 1
Shepherd ES	Basement Floor, Inside Lunch Room	4/8/13	< 1
Shepherd ES	Basement Floor, Inside Lunch Room	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 214	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 214	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 220	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 220	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Counselor's Office	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Counselor's Office	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 122	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 122	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 204	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 204	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 200	4/8/13	< 1
Shepherd ES	2nd Floor Hallway, Next to Room 200	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 100	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 100	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 102	4/8/13	< 1
Shepherd ES	1st Floor Hallway, Next to Room 102	4/8/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Simon ES	1st Floor Hallway, by Room 116	3/1/13	< 1
Simon ES	1st Floor Hallway, by Room 116	3/1/13	< 1
Simon ES	1st Floor Hallway, by Room 106	3/1/13	< 1
Simon ES	1st Floor Hallway, by Room 106	3/1/13	< 1
Simon ES	2nd Floor Hallway, by Room 206	3/1/13	< 1
Simon ES	2nd Floor Hallway, by Room 206	3/1/13	< 1
Simon ES	2nd Floor Hallway, by Room 211	3/1/13	< 1
Simon ES	2nd Floor Hallway, by Room 211	3/1/13	< 1
Simon ES	3rd Floor Hallway, by Room 307	3/1/13	< 1
Simon ES	3rd Floor Hallway, by Room 307	3/1/13	< 1
Simon ES	3rd Floor Hallway, by Room 304	3/1/13	< 1
Simon ES	3rd Floor Hallway, by Room 304	3/1/13	< 1
Simon ES	Ground Floor Hallway, by Room 005	3/1/13	< 1
Simon ES	Ground Floor Hallway, by Room 005	3/1/13	< 1
Simon ES	Ground Floor Hallway, by Room 013	3/1/13	< 1
Simon ES	Ground Floor Hallway, by Room 013	3/1/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Smothers ES	3rd Floor Hallway, Next to Room 310	5/14/13	< 1
Smothers ES	3rd Floor Hallway, Next to Room 310	5/14/13	< 1
Smothers ES	3rd Floor Hallway, Next to Room 301	5/14/13	< 1
Smothers ES	3rd Floor Hallway, Next to Room 301	5/14/13	< 1
Smothers ES	2nd Floor Hallway, Next to Room 202	5/14/13	< 1
Smothers ES	2nd Floor Hallway, Next to Room 202	5/14/13	< 1
Smothers ES	2nd Floor Hallway, Next to Room 212	5/14/13	< 1
Smothers ES	2nd Floor Hallway, Next to Room 212	5/14/13	< 1
Smothers ES	1st Floor Hallway, Next to Room 111	5/14/13	< 1
Smothers ES	1st Floor Hallway, Next to Room 111	5/14/13	< 1
Smothers ES	1st Floor Hallway, Next to Room 104	5/14/13	< 1
Smothers ES	1st Floor Hallway, Next to Room 104	5/14/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	
Sousa ES	1st Floor Corridor, Next to Room B122 (High)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room B122 (High)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room B122 (Low)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room B122 (Low)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room A102 (High)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room A102 (High)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room A102 (Low)	2/5/13	< 1
Sousa ES	1st Floor Corridor, Next to Room A102 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (1st unit, from right hand side)	2/5/13	2.7
Sousa ES	1st Floor, Inside Room B104 (1st unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (2nd unit, from right hand side)	2/5/13	< 1

Sousa ES	1st Floor, Inside Room B104 (3rd unit, from right hand side)	2/5/13	4.7
Sousa ES	1st Floor, Inside Room B104 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (4th unit, from right hand side)	2/5/13	1.6
Sousa ES	1st Floor, Inside Room B104 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room B104 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (1st unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (1st unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (2nd unit, from right hand side)	2/5/13	1.4
Sousa ES	1st Floor, Inside Room A109 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (6th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Inside Room A109 (6th unit, from right hand side)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room C101 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room C101 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room C101 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room C101 (Low)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (1st unit, from right hand side)	2/5/13	1.9
Sousa ES	3rd Floor, Inside Room B304 (1st unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	3rd Floor, Inside Room B304 (4th unit, from right hand side)	2/5/13	< 1

Sousa ES	3rd Floor, Inside Room B304 (4th unit, from right hand side)	2/5/13	2	
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side)	2/5/13		16
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side)	2/5/13	1.1	
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side) - Retest	2/20/13	< 1	
Sousa ES	3rd Floor, Inside Room B304 (5th unit, from right hand side) - Retest	2/20/13	< 1	
Sousa ES	3rd Floor, Inside Room B304 (6th unit, from right hand side)	2/5/13	3	
Sousa ES	3rd Floor, Inside Room B304 (6th unit, from right hand side)	2/5/13	3	
Sousa ES	3rd Floor, Inside Room B309 (1st unit, from right hand side)	2/5/13	1.9	
Sousa ES	3rd Floor, Inside Room B309 (1st unit, from right hand side)	2/5/13	2.6	
Sousa ES	3rd Floor, Inside Room B309 (2nd unit, from right hand side)	2/5/13	1	
Sousa ES	3rd Floor, Inside Room B309 (2nd unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor, Inside Room B309 (3rd unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor, Inside Room B309 (3rd unit, from right hand side)	2/5/13	1	
Sousa ES	3rd Floor, Inside Room B309 (4th unit, from right hand side)	2/5/13	2.5	
Sousa ES	3rd Floor, Inside Room B309 (4th unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor, Inside Room B309 (5th unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor, Inside Room B309 (5th unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor, Inside Room B309 (6th unit, from right hand side)	2/5/13	1.3	
Sousa ES	3rd Floor, Inside Room B309 (6th unit, from right hand side)	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room C301	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room C301	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room A301 (High)	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room A301 (High)	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room A301 (Low)	2/5/13	< 1	
Sousa ES	3rd Floor Corridor, Next to Room A301 (Low)	2/5/13	< 1	
Sousa ES	2nd Floor, Inside Room A204 (1st unit, from right hand side)	2/5/13	< 1	
Sousa ES	2nd Floor, Inside Room A204 (1st unit, from right hand side)	2/5/13	< 1	
Sousa ES	2nd Floor, Inside Room A204 (2nd unit, from right hand side)	2/5/13	< 1	
Sousa ES	2nd Floor, Inside Room A204 (2nd unit, from right hand side)	2/5/13	< 1	

Sousa ES	2nd Floor, Inside Room A204 (3rd unit, from right hand side)	2/5/13	2
Sousa ES	2nd Floor, Inside Room A204 (3rd unit, from right hand side)	2/5/13	1.4
Sousa ES	2nd Floor, Inside Room A204 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A204 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A204 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A204 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A204 (6th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A204 (6th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (1st unit, from right hand side)	2/5/13	1.9
Sousa ES	2nd Floor, Inside Room A209 (1st unit, from right hand side)	2/5/13	1.7
Sousa ES	2nd Floor, Inside Room A209 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (2nd unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (3rd unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (4th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (5th unit, from right hand side)	2/5/13	< 1
Sousa ES	2nd Floor, Inside Room A209 (6th unit, from right hand side)	2/5/13	3.2
Sousa ES	2nd Floor, Inside Room A209 (6th unit, from right hand side)	2/5/13	1.5
Sousa ES	2nd Floor Corridor, Next to Room A201 (High)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room A201 (High)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room A201 (Low)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room A201 (Low)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room C201 (High)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room C201 (High)	2/5/13	< 1
Sousa ES	2nd Floor Corridor, Next to Room C201 (Low)	2/5/13	< 1

Sousa ES	2nd Floor Corridor, Next to Room C201 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Inside Boys Locker Room (High)	2/5/13	< 1
Sousa ES	1st Floor, Inside Boys Locker Room (High)	2/5/13	< 1
Sousa ES	1st Floor, Inside Boys Locker Room (Low)	2/5/13	< 1
Sousa ES	1st Floor, Inside Boys Locker Room (Low)	2/5/13	< 1
Sousa ES	1st Floor, Inside Girls Locker Room (High)	2/5/13	< 1
Sousa ES	1st Floor, Inside Girls Locker Room (High)	2/5/13	< 1
Sousa ES	1st Floor, Inside Girls Locker Room (Low)	2/5/13	< 1
Sousa ES	1st Floor, Inside Girls Locker Room (Low)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D101 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D101 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D101 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D101 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D104 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D104 (High)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D104 (Low)	2/5/13	< 1
Sousa ES	1st Floor, Next to Room D104 (Low)	2/5/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Spingarn SHS	3rd Floor Hallway, Outside Room 307	5/9/13	< 1
Spingarn SHS	3rd Floor Hallway, Outside Room 307	5/9/13	< 1
Spingarn SHS	3rd Floor Hallway, Outside Room 308	5/9/13	2.7
Spingarn SHS	3rd Floor Hallway, Outside Room 308	5/9/13	2.8
Spingarn SHS	2nd Floor, Outside Room 207	5/9/13	< 1
Spingarn SHS	2nd Floor, Outside Room 207	5/9/13	< 1
Spingarn SHS	2nd Floor, Outside Room 208	5/9/13	< 1
Spingarn SHS	2nd Floor, Outside Room 208	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 111	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 111	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 123	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 123	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 126	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 126	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 108	5/9/13	< 1
Spingarn SHS	1st Floor Hallway, Outside Room 108	5/9/13	< 1
Spingarn SHS	Basement Floor, Inside Cafeteria	5/9/13	< 1
Spingarn SHS	Basement Floor, Inside Cafeteria	5/9/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1
Stoddert ES	2nd Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (1)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (1)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (2)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (2)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (3)	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 227 (3)	2/21/13	< 1

Stoddert ES	2nd Floor, Inside Room 244	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 244	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 245	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 245	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 246	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 246	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 247	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 247	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 230	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 230	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 231	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 231	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 232	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 232	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 233	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 233	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 234	2/21/13	< 1
Stoddert ES	2nd Floor, Inside Room 234	2/21/13	< 1
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (High)	2/21/13	< 1
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1
Stoddert ES	1st Floor Hallway, Next to Boys and Girls Restroom (Low)	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 142	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 142	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 144	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 144	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 145	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 145	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 146	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 146	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 147	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 147	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 131	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 131	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 132	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 132	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 133	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 133	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 134	2/21/13	< 1
Stoddert ES	1st Floor, Inside Room 134	2/21/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	

Stuart Hobson MS	3rd Floor Hallway, Next to Room 303	5/1/13	< 1
Stuart Hobson MS	3rd Floor Hallway, Next to Room 303	5/1/13	< 1
Stuart Hobson MS	2nd Floor Hallway, Next to Room 203	5/1/13	< 1
Stuart Hobson MS	2nd Floor Hallway, Next to Room 203	5/1/13	< 1
Stuart Hobson MS	2nd Floor Hallway, Next to Room 204	5/1/13	< 1
Stuart Hobson MS	2nd Floor Hallway, Next to Room 204	5/1/13	< 1
Stuart Hobson MS	1st Floor Hallway, Next to Room 104	5/1/13	< 1
Stuart Hobson MS	1st Floor Hallway, Next to Room 104	5/1/13	< 1

Stuart Hobson MS	1st Floor Hallway, Next to Room 103	5/1/13	< 1
Stuart Hobson MS	1st Floor Hallway, Next to Room 103	5/1/13	< 1
Stuart Hobson MS	Basement Floor, Inside Cafeteria	5/1/13	< 1
Stuart Hobson MS	Basement Floor, Inside Cafeteria	5/1/13	< 1
	Basement Floor Hallway, Next to Boys		
Stuart Hobson MS	Restroom	5/1/13	< 1
	Basement Floor Hallway, Next to Boys		
Stuart Hobson MS	Restroom	5/1/13	< 1
	Basement Floor Hallway, Next to Custodian's		
Stuart Hobson MS	Office	5/1/13	< 1
	Basement Floor Hallway, Next to Custodian's		
Stuart Hobson MS	Office	5/1/13	< 1
Stuart Hobson MS	3rd Floor Hallway, Next to Room 304	5/1/13	< 1
Stuart Hobson MS	3rd Floor Hallway, Next to Room 304	5/1/13	< 1

			Percentage of Passed Samples
			Percentage of Failed Samples

Takoma EC	3rd Floor Hallway, Next to Elevator (High)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Elevator (High)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Room 327 (High)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Room 327 (High)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Room 327 (Low)	5/28/13	< 1
Takoma EC	3rd Floor Hallway, Next to Room 327 (Low)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Elevator (High)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Elevator (High)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Elevator (Low)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Room 234 (High)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Room 234 (High)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Room 234 (Low)	5/28/13	< 1
Takoma EC	2nd Floor Hallway, Next to Room 234 (Low)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Next to Room 133 (High)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Next to Room 133 (High)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Next to Room 133 (Low)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Next to Room 133 (Low)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Across from Elevator (High)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Across from Elevator (High)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Across from Elevator (Low)	5/28/13	< 1
Takoma EC	1st Floor Hallway, Across from Elevator (Low)	5/28/13	< 1
Takoma EC	In Gym Area, Next to Boys Locker Room	5/28/13	2.6
Takoma EC	In Gym Area, Next to Boys Locker Room	5/28/13	< 1
Takoma EC	In Gym Area, Next to Girls Locker Room	5/28/13	< 1
Takoma EC	In Gym Area, Next to Girls Locker Room	5/28/13	< 1

			Percentage of Passed Samples
			Percentage of Failed Samples

	1st Floor, Main Lobby, Next to Multi-Purpose		
Thomas ES	Room	2/7/13	< 1
	1st Floor, Main Lobby, Next to Multi-Purpose		
Thomas ES	Room	2/7/13	< 1

Thomas ES	1st Floor Hallway, Outside Multi-Purpose Room	2/7/13	< 1
Thomas ES	1st Floor Hallway, Outside Multi-Purpose Room	2/7/13	< 1
Thomas ES	1st Floor, Inside Multi-Purpose Room	2/7/13	< 1
Thomas ES	1st Floor, Inside Multi-Purpose Room	2/7/13	< 1
Thomas ES	1st Floor, Inside Cafeteria	2/7/13	< 1
Thomas ES	1st Floor, Inside Cafeteria	2/7/13	< 1
Thomas ES	1st Floor, Next to Room 109 (Low)	2/7/13	< 1
Thomas ES	1st Floor, Next to Room 109 (Low)	2/7/13	< 1
Thomas ES	1st Floor, Next to Room 109 (High)	2/7/13	< 1
Thomas ES	1st Floor, Next to Room 109 (High)	2/7/13	< 1
Thomas ES	1st Floor, Next to Health Suite (Low)	2/7/13	< 1
Thomas ES	1st Floor, Next to Health Suite (Low)	2/7/13	< 1
Thomas ES	1st Floor, Next to Health Suite (High)	2/7/13	< 1
Thomas ES	1st Floor, Next to Health Suite (High)	2/7/13	2.4
Thomas ES	1st Floor, Inside Health Suite	2/7/13	< 1
Thomas ES	1st Floor, Inside Health Suite	2/7/13	< 1
Thomas ES	2nd Floor, Next to Room 215	2/7/13	< 1
Thomas ES	2nd Floor, Next to Room 215	2/7/13	< 1
Thomas ES	2nd Floor Hallway, Between Boys and Girls Restroom	2/7/13	< 1
Thomas ES	2nd Floor Hallway, Between Boys and Girls Restroom	2/7/13	< 1
Thomas ES	2nd Floor, Across from Room 209 (Low)	2/7/13	< 1
Thomas ES	2nd Floor, Across from Room 209 (Low)	2/7/13	< 1
Thomas ES	2nd Floor, Across from Room 209 (High)	2/7/13	< 1
Thomas ES	2nd Floor, Across from Room 209 (High)	2/7/13	< 1

Percentage of Passed Samples		
Percentage of Failed Samples		

Thomson ES	3rd Floor Hallway, Next to Room 316	4/15/13	< 1
Thomson ES	3rd Floor Hallway, Next to Room 316	4/15/13	< 1
Thomson ES	2nd Floor Hallway, Next to Room 227	4/15/13	< 1
Thomson ES	2nd Floor Hallway, Next to Room 227	4/15/13	< 1
Thomson ES	1st Floor Hallway, Next to Room 130	4/15/13	< 1
Thomson ES	1st Floor Hallway, Next to Room 130	4/15/13	< 1
Thomson ES	1st Floor Hallway, Next to Room 129	4/15/13	< 1
Thomson ES	1st Floor Hallway, Next to Room 129	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 127	4/15/13	2.8
Thomson ES	1st Floor, Inside Room 127	4/15/13	1.8
Thomson ES	1st Floor, Inside Room 123	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 123	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 124	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 124	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 126	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 126	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 112	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 112	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 115	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 115	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 113	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 113	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 114	4/15/13	< 1
Thomson ES	1st Floor, Inside Room 114	4/15/13	< 1

Thomson ES	Inside Cafeteria (High)	4/15/13	< 1
Thomson ES	Inside Cafeteria (High)	4/15/13	< 1
Thomson ES	Inside Cafeteria (Low)	4/15/13	< 1
Thomson ES	Inside Cafeteria (Low)	4/15/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Truesdell ES	Basement Floor, Inside Health Suite	3/13/13	< 1
Truesdell ES	Basement Floor, Inside Health Suite	3/13/13	< 1
Truesdell ES	Basement Hallway, by Room 012	3/13/13	< 1
Truesdell ES	Basement Hallway, by Room 012	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Staff Restroom	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Staff Restroom	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Stairwell, Opposite to Room 218	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Stairwell, Opposite to Room 218	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, Opposite to Library	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, Opposite to Library	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Staff Restroom	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Staff Restroom	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Roof Door	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Roof Door	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Room 300	3/13/13	< 1
Truesdell ES	3rd Floor Hallway, by Room 300	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 216	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 216	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 217	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 217	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Room 212	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, by Room 212	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, Outside Room 200	3/13/13	< 1
Truesdell ES	2nd Floor Hallway, Outside Room 200	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 201	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 201	3/13/13	< 1
Truesdell ES	2nd Floor, Inside Room 200	3/13/13	1.7
Truesdell ES	2nd Floor, Inside Room 200	3/13/13	1.3
Truesdell ES	1st Floor, Inside Room 100	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 100	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 101	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 101	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 106	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 106	3/13/13	< 1
Truesdell ES	1st Floor, Outside Parents' Center	3/13/13	< 1
Truesdell ES	1st Floor, Outside Parents' Center	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 114	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 114	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 113	3/13/13	< 1
Truesdell ES	1st Floor, Inside Room 113	3/13/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Tubman ES	3rd Floor Hallway, Across from Room 311	2/4/13	< 1
Tubman ES	3rd Floor Hallway, Across from Room 311	2/4/13	< 1
Tubman ES	3rd Floor Hallway, Across from Room 306	2/4/13	< 1
Tubman ES	3rd Floor Hallway, Across from Room 306	2/4/13	< 1

Tubman ES	3rd Floor Hallway, Across from Room 301	2/4/13	< 1	
Tubman ES	3rd Floor Hallway, Across from Room 301	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 211	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 211	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 206	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 206	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 201	2/4/13	< 1	
Tubman ES	2nd Floor Hallway, Across from Room 201	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Across from Room 115	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Across from Room 115	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 115	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 115	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Next to Room 110	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Next to Room 110	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 110	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 110	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 113	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 113	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 111	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 111	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 108	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 108	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Across from Room 101	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Across from Room 101	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Next to Room 132	2/4/13	< 1	
Tubman ES	1st Floor Hallway, Next to Room 132	2/4/13	< 1	
Tubman ES	1st Floor, Across from Cafeteria	2/4/13	< 1	
Tubman ES	1st Floor, Across from Cafeteria	2/4/13	< 1	
Tubman ES	1st Floor, Inside Cafeteria	2/4/13	< 1	
Tubman ES	1st Floor, Inside Cafeteria	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 122	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 122	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 121	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 121	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 120	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 120	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 119	2/4/13	< 1	
Tubman ES	1st Floor, Inside Room 119	2/4/13	< 1	
Tubman ES	1st Floor, Inside Health Suite	2/4/13	5.2	
Tubman ES	1st Floor, Inside Health Suite	2/4/13	6.4	
Tubman ES	1st Floor, Inside Room 114	2/4/13	7.6	
Tubman ES	1st Floor, Inside Room 114	2/4/13		30
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>	<i>2/20/13</i>		<i>16</i>
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>	<i>2/20/13</i>		<i>68</i>
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>	<i>4/10/13</i>	< 1	
Tubman ES	<i>1st Floor, Inside Room 114 - Retest</i>	<i>4/10/13</i>	< 1	

		Percentage of Passed Samples		
		Percentage of Failed Samples		
Turner ES	3rd Floor Hallway, by Room 316 (High)	5/3/13	< 1	
Turner ES	3rd Floor Hallway, by Room 316 (High)	5/3/13	< 1	
Turner ES	3rd Floor Hallway, by Room 316 (Low)	5/3/13	< 1	
Turner ES	3rd Floor Hallway, by Room 316 (Low)	5/3/13	< 1	
Turner ES	3rd Floor Hallway, by Room 324 (High)	5/3/13	< 1	
Turner ES	3rd Floor Hallway, by Room 324 (High)	5/3/13	< 1	

Turner ES	1st Floor, Inside Room 112	5/3/13	1.3
Turner ES	1st Floor, Inside Room 112	5/3/13	< 1
Turner ES	1st Floor, Inside Room 109	5/3/13	< 1
Turner ES	1st Floor, Inside Room 109	5/3/13	< 1
Turner ES	1st Floor, Inside Room 108	5/3/13	< 1
Turner ES	1st Floor, Inside Room 108	5/3/13	< 1
Turner ES	1st Floor, Inside Room 107	5/3/13	< 1
Turner ES	1st Floor, Inside Room 107	5/3/13	< 1
Turner ES	1st Floor, Inside Room 106	5/3/13	< 1
Turner ES	1st Floor, Inside Room 106	5/3/13	< 1
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance		
Turner ES	Door (High)	5/3/13	< 1
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance		
Turner ES	Door (High)	5/3/13	< 1
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance		
Turner ES	Door (Low)	5/3/13	< 1
Turner ES	1st Floor Hallway, by Room 133, Gym Entrance		
Turner ES	Door (Low)	5/3/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Tyler ES	3rd Floor Hallway, by Room 303	5/20/13	< 1
Tyler ES	3rd Floor Hallway, by Room 303	5/20/13	< 1
Tyler ES	3rd Floor Hallway, by Room 306	5/20/13	< 1
Tyler ES	3rd Floor Hallway, by Room 306	5/20/13	< 1
Tyler ES	2nd Floor Hallway, by Restroom	5/20/13	< 1
Tyler ES	2nd Floor Hallway, by Restroom	5/20/13	< 1
Tyler ES	2nd Floor Hallway, by Media Center	5/20/13	< 1
Tyler ES	2nd Floor Hallway, by Media Center	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 138 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 138 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 138 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 138 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 142 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 142 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 142 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 142 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 103 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 103 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 103 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 103 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 120 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 120 (High)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 120 (Low)	5/20/13	< 1
Tyler ES	1st Floor Hallway, by Room 120 (Low)	5/20/13	< 1
Tyler ES	Basement Floor, Inside Cafeteria	5/20/13	< 1
Tyler ES	Basement Floor, Inside Cafeteria	5/20/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

Van Ness ES	3rd Floor Hallway, Across from Room 302	6/4/13	< 1
Van Ness ES	3rd Floor Hallway, Across from Room 302	6/4/13	< 1
Van Ness ES	2nd Floor Hallway, Across from Room 202	6/4/13	< 1
Van Ness ES	2nd Floor Hallway, Across from Room 202	6/4/13	< 1
Van Ness ES	2nd Floor Hallway, Next to Room 207	6/4/13	< 1
Van Ness ES	2nd Floor Hallway, Next to Room 207	6/4/13	< 1

Van Ness ES	1st Floor Hallway, Across from Room 3	6/4/13	< 1
Van Ness ES	1st Floor Hallway, Across from Room 3	6/4/13	< 1
Van Ness ES	1st Floor Hallway, Across from Assembly Room	6/4/13	< 1
Van Ness ES	1st Floor Hallway, Across from Assembly Room	6/4/13	< 1
Van Ness ES	1st Floor Hallway, Across from Room 13	6/4/13	< 1
Van Ness ES	1st Floor Hallway, Across from Room 13	6/4/13	< 1

Percentage of Passed Samples			
Percentage of Failed Samples			

Walker Jones ES	Basement Floor, Inside Room 036	1/23/13	2.2
Walker Jones ES	Basement Floor, Inside Room 036	1/23/13	1.6
Walker Jones ES	Basement Floor, Therapy Room	1/23/13	< 1
Walker Jones ES	Basement Floor, Therapy Room	1/23/13	< 1
Walker Jones ES	Basement Floor, Inside Room 032	1/23/13	< 1
Walker Jones ES	Basement Floor, Inside Room 032	1/23/13	< 1
Walker Jones ES	Basement Hallway, Across from Room 032 (High)	1/23/13	< 1
Walker Jones ES	Basement Hallway, Across from Room 032 (High)	1/23/13	< 1
Walker Jones ES	Basement Hallway, Across from Room 032 (Low)	1/23/13	< 1
Walker Jones ES	Basement Hallway, Across from Room 032 (Low)	1/23/13	< 1
Walker Jones ES	Basement Floor, Athletic Room	1/23/13	< 1
Walker Jones ES	Basement Floor, Athletic Room	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 123	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 123	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 128	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 128	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 126	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 126	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 119	1/23/13	1.1
Walker Jones ES	1st Floor, Inside Room 119	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 117	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 117	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 122	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 122	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 120	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 120	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 115	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 115	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Teachers' Lounge	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Teachers' Lounge	1/23/13	< 1
Walker Jones ES	1st Floor Hallway, Across from Room 110 (High)	1/23/13	< 1
Walker Jones ES	1st Floor Hallway, Across from Room 110 (High)	1/23/13	< 1
Walker Jones ES	1st Floor Hallway, Across from Room 110 (Low)	1/23/13	< 1
Walker Jones ES	1st Floor Hallway, Across from Room 110 (Low)	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 106	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 106	1/23/13	< 1

Walker Jones ES	1st Floor, Inside Room 108	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 108	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 105	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 105	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 103	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 103	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 104	1/23/13	< 1
Walker Jones ES	1st Floor, Inside Room 104	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 227 (Left Bubbler)	1/23/13	4.8
Walker Jones ES	2nd Floor, Inside Room 227 (Left Bubbler)	1/23/13	3.5
Walker Jones ES	2nd Floor, Inside Room 227 (Right Bubbler)	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 227 (Right Bubbler)	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 228	1/23/13	1.1
Walker Jones ES	2nd Floor, Inside Room 228	1/23/13	1.5
Walker Jones ES	2nd Floor, Inside Room 226	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 226	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 219	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 219	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 221	1/23/13	1.6
Walker Jones ES	2nd Floor, Inside Room 221	1/23/13	1.4
Walker Jones ES	2nd Floor, Inside Room 224	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 224	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 222	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 222	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 217	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 217	1/23/13	< 1
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (High)	1/23/13	< 1
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (High)	1/23/13	< 1
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (Low)	1/23/13	< 1
Walker Jones ES	2nd Floor Hallway, Across from Room 214 (Low)	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 212	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 212	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 210	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 210	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 205	1/23/13	5.2
Walker Jones ES	2nd Floor, Inside Room 205	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 203	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 203	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 208	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 208	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 206	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 206	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 201	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 201	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 220	1/23/13	< 1
Walker Jones ES	2nd Floor, Inside Room 220	1/23/13	< 1
Walker Jones ES	3rd Floor, Inside Room 300	1/23/13	< 1
Walker Jones ES	3rd Floor, Inside Room 300	1/23/13	< 1
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (High)	1/23/13	< 1

Walker Jones ES	3rd Floor Hallway, Across from Room 314 (High)	1/23/13	< 1	
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (Low)	1/23/13	< 1	
Walker Jones ES	3rd Floor Hallway, Across from Room 314 (Low)	1/23/13	< 1	
Walker Jones ES	3rd Floor, Inside Room 320 (1st Bubbler)	1/23/13	2.4	
Walker Jones ES	3rd Floor, Inside Room 320 (1st Bubbler)	1/23/13	1.7	
Walker Jones ES	3rd Floor, Inside Room 320 (2nd Bubbler)	1/23/13	1.1	
Walker Jones ES	3rd Floor, Inside Room 320 (2nd Bubbler)	1/23/13	6.6	
Walker Jones ES	3rd Floor, Inside Room 320 (3rd Bubbler)	1/23/13	5.5	
Walker Jones ES	3rd Floor, Inside Room 320 (3rd Bubbler)	1/23/13	4.8	
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler)	1/23/13	7.6	
Walker Jones ES	3rd Floor, Inside Room 320 (4th Bubbler)	1/23/13		15
Walker Jones ES	<i>3rd Floor, Inside Room 320 (4th Bubbler) - Retest</i>	<i>2/7/13</i>	<i>13</i>	
Walker Jones ES	<i>3rd Floor, Inside Room 320 (4th Bubbler) - Retest</i>	<i>2/7/13</i>	<i>4.5</i>	
Walker Jones ES	3rd Floor, Inside Room 324 (1st Bubbler)	1/23/13	< 1	
Walker Jones ES	3rd Floor, Inside Room 324 (1st Bubbler)	1/23/13	5.8	
Walker Jones ES	3rd Floor, Inside Room 324 (2nd Bubbler)	1/23/13	8.1	
Walker Jones ES	3rd Floor, Inside Room 324 (2nd Bubbler)	1/23/13	3.9	
Walker Jones ES	3rd Floor, Inside Room 324 (3rd Bubbler)	1/23/13	< 1	
Walker Jones ES	3rd Floor, Inside Room 324 (3rd Bubbler)	1/23/13	14	
Walker Jones ES	3rd Floor, Inside Room 324 (4th Bubbler)	1/23/13	< 1	
Walker Jones ES	3rd Floor, Inside Room 324 (4th Bubbler)	1/23/13	1.3	

				Percentage of Passed Samples
				Percentage of Failed Samples
Watkins ES	4th Floor Hallway, Across from Elevator	5/17/13	< 1	
Watkins ES	4th Floor Hallway, Across from Elevator	5/17/13	< 1	
Watkins ES	4th Floor Hallway, Across from Room 403	5/17/13	< 1	
Watkins ES	4th Floor Hallway, Across from Room 403	5/17/13	< 1	
Watkins ES	4th Floor Hallway, Next to Room 407	5/17/13	< 1	
Watkins ES	4th Floor Hallway, Next to Room 407	5/17/13	< 1	
Watkins ES	3rd Floor Hallway, Next to Room 307	5/17/13	< 1	
Watkins ES	3rd Floor Hallway, Next to Room 307	5/17/13	< 1	
Watkins ES	3rd Floor Hallway, Across from Room 303	5/17/13	< 1	
Watkins ES	3rd Floor Hallway, Across from Room 303	5/17/13	< 1	
Watkins ES	3rd Floor Hallway, Across from Elevator	5/17/13	< 1	

Watkins ES	3rd Floor Hallway, Across from Elevator	5/17/13	< 1
Watkins ES	2nd Floor Hallway, Across from Elevator	5/17/13	< 1
Watkins ES	2nd Floor Hallway, Across from Elevator	5/17/13	< 1
Watkins ES	2nd Floor Hallway. Across from Room 203	5/17/13	< 1
Watkins ES	2nd Floor Hallway. Across from Room 203	5/17/13	< 1
Watkins ES	2nd Floor Hallway, Next to Library Room 205	5/17/13	< 1
Watkins ES	2nd Floor Hallway, Next to Library Room 205	5/17/13	< 1
Watkins ES	1st Floor Hallway, Next to Room 112	5/17/13	< 1
Watkins ES	1st Floor Hallway, Next to Room 112	5/17/13	< 1
Watkins ES	1st Floor Hallway, Across from Room 108	5/17/13	< 1
Watkins ES	1st Floor Hallway, Across from Room 108	5/17/13	< 1
Watkins ES	1st Floor Hallway, Across from Elevator	5/17/13	< 1
Watkins ES	1st Floor Hallway, Across from Elevator	5/17/13	< 1
Watkins ES	1st Floor Hallway, Next to Recreation Center		
Watkins ES	Office	5/17/13	< 1
Watkins ES	1st Floor Hallway, Next to Recreation Center		
Watkins ES	Office	5/17/13	< 1

Percentage of Passed Samples

Percentage of Failed Samples

West ES	1st Floor Hallway, Between Women's and Men's Restroom	3/28/13	< 1
West ES	1st Floor Hallway, Between Women's and Men's Restroom	3/28/13	< 1
West ES	1st Floor, Kindergarten, Next to Boys Restroom	3/28/13	< 1
West ES	1st Floor, Kindergarten, Next to Boys Restroom	3/28/13	< 1
West ES	1st Floor, Pre-K, Next to Uni-Sex Restroom	3/28/13	< 1
West ES	1st Floor, Pre-K, Next to Uni-Sex Restroom	3/28/13	< 1
West ES	1st Floor Hallway, Outside Main Office	3/28/13	< 1
West ES	1st Floor Hallway, Outside Main Office	3/28/13	< 1
West ES	1st Floor, Inside Health Suite	3/28/13	< 1
West ES	1st Floor, Inside Health Suite	3/28/13	< 1
West ES	1st Floor Hallway, Next to Trash Chute	3/28/13	< 1
West ES	1st Floor Hallway, Next to Trash Chute	3/28/13	< 1
West ES	1st Floor, Inside Daycare, Next to Restroom	3/28/13	< 1
West ES	1st Floor, Inside Daycare, Next to Restroom	3/28/13	< 1
West ES	2nd Floor, Inside Gym on South Wall (Right)	3/28/13	< 1
West ES	2nd Floor, Inside Gym on South Wall (Right)	3/28/13	< 1
West ES	2nd Floor, Inside Gym on South Wall (Left)	3/28/13	< 1
West ES	2nd Floor, Inside Gym on South Wall (Left)	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Gym (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Gym (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Gym (Left)	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Gym (Left)	3/28/13	< 1
West ES	2nd Floor, Inside Cafeteria, Next to Kitchen	3/28/13	< 1
West ES	2nd Floor, Inside Cafeteria, Next to Kitchen	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Teachers' Lounge	3/28/13	< 1
West ES	2nd Floor Hallway, Outside Teachers' Lounge	3/28/13	< 1
West ES	2nd Floor, Inside Teachers' Lounge	3/28/13	< 1

West ES	2nd Floor, Inside Teachers' Lounge	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Book Storage Room (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Book Storage Room (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Book Storage Room (Left)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Book Storage Room (Left)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Computer Lab (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Computer Lab (Right)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Computer Lab (Left)	3/28/13	< 1
West ES	2nd Floor Hallway, Next to Computer Lab (Left)	3/28/13	< 1
West ES	Mezzanine Level, Inside Library	3/28/13	< 1
West ES	Mezzanine Level, Inside Library	3/28/13	< 1

				Percentage of Passed Samples
				Percentage of Failed Samples
Wheatley ES	2nd Floor Hallway, by Room 205 (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Room 205 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (High)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor Hallway, by Student's Service Room (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 135 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (High)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (Low)	5/31/13	< 1	
Wheatley ES	1st Floor Hallway, Near Room 103 (Low)	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 213	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 213	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 211	5/31/13	1.7	
Wheatley ES	2nd Floor, Inside Room 211	5/31/13	8.1	
Wheatley ES	2nd Floor, Inside Room 203	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 203	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 215	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 215	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 207	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 207	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 234	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 234	5/31/13	< 1	
Wheatley ES	2nd Floor, Inside Room 229	5/31/13	< 1	

		Percentage of Failed Samples	
Whittier ES	3rd Floor Hallway, Next to Room 311	2/19/13	< 1
Whittier ES	3rd Floor Hallway, Next to Room 311	2/19/13	< 1
Whittier ES	3rd Floor Hallway, Next to Room 308	2/19/13	< 1
Whittier ES	3rd Floor Hallway, Next to Room 308	2/19/13	< 1
Whittier ES	2nd Floor Hallway, Next Health Suite	2/19/13	< 1
Whittier ES	2nd Floor Hallway, Next Health Suite	2/19/13	< 1
Whittier ES	2nd Floor Hallway, Next to Room 211	2/19/13	1.4
Whittier ES	2nd Floor Hallway, Next to Room 211	2/19/13	1.4
Whittier ES	2nd Floor Hallway, Across from Room 201	2/19/13	< 1
Whittier ES	2nd Floor Hallway, Across from Room 201	2/19/13	< 1
Whittier ES	1st Floor Hallway, Between Custodial Closet and Main Office	2/19/13	< 1
Whittier ES	1st Floor Hallway, Between Custodial Closet and Main Office	2/19/13	< 1
Whittier ES	2nd Floor Hallway, Across from Room 115	2/19/13	1.9
Whittier ES	2nd Floor Hallway, Across from Room 115	2/19/13	< 1
Whittier ES	Basement Floor Hallway, Across from Room 15	2/19/13	< 1
Whittier ES	Basement Floor Hallway, Across from Room 15	2/19/13	< 1

		Percentage of Passed Samples	
		Percentage of Failed Samples	

Wilson SHS	3rd Floor Hallway, Next to Room 331	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 331	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 303	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 303	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 321	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 321	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 322	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 322	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 314 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 314 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 312	6/5/13	< 1
Wilson SHS	3rd Floor Hallway, Next to Room 312	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 421	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 421	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 422	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 422	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 414 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	4th Floor Hallway, Next to Room 414 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 412	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 412	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 403	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 403	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 431	6/5/13	< 1
Wilson SHS	4st Floor Hallway, Next to Room 431	6/5/13	< 1
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-308 (Electrical Closet)	6/5/13	< 1

Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-308 (Electrical Closet)	6/5/13	< 1
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-301 (Storage Room)	6/5/13	< 1
Wilson SHS	3rd Floor, B Wing Hallway, Next to Room B-301 (Storage Room)	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 202	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 202	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 232	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 232	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 223	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 223	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 222	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 222	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 213 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 213 (Custodian's Closet)	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 211	6/5/13	< 1
Wilson SHS	2nd Floor Hallway, Next to Room 211	6/5/13	< 1
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-202 (Storage Room)	6/5/13	< 1
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-202 (Storage Room)	6/5/13	< 1
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-209 (Electrical Closet)	6/5/13	< 1
Wilson SHS	2nd Floor, B Wing Hallway, Next to Room B-209 (Electrical Closet)	6/5/13	< 1
Wilson SHS	1st Floor Hallway, Next to Room 119 (Staff Lounge)	6/5/13	< 1
Wilson SHS	1st Floor Hallway, Next to Room 119 (Staff Lounge)	6/5/13	< 1
Wilson SHS	2nd Floor, A Wing Hallway, Next to Room A-203B (Custodian's Closet)	6/5/13	< 1
Wilson SHS	2nd Floor, A Wing Hallway, Next to Room A-203B (Custodian's Closet)	6/5/13	< 1
Wilson SHS	Inside Gym (High)	6/5/13	< 1
Wilson SHS	Inside Gym (High)	6/5/13	< 1
Wilson SHS	Inside Gym (Low)	6/5/13	< 1
Wilson SHS	Inside Gym (Low)	6/5/13	< 1
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-102 (Book Distribution)	6/5/13	< 1
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-102 (Book Distribution)	6/5/13	< 1
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-109 (Storage Room)	6/5/13	< 1
Wilson SHS	1st Floor, B Wing Hallway, Next to Room B-109 (Storage Room)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (High)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (High)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (Low)	6/5/13	< 1

Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-207 (Low)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (High)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (High)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (Low)	6/5/13	< 1
Wilson SHS	2nd Floor, C Wing Hallway, Next to Room C-204 (Low)	6/5/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	
Winston ES	3rd Floor, Next to Men's and Women's Restroom	1/28/13	< 1
Winston ES	3rd Floor, Next to Men's and Women's Restroom	1/28/13	< 1
Winston ES	3rd Floor, by Room 368	1/28/13	< 1
Winston ES	3rd Floor, by Room 368	1/28/13	< 1
Winston ES	3rd Floor, Inside Health Suite	1/28/13	1.1
Winston ES	3rd Floor, Inside Health Suite	1/28/13	1.4
Winston ES	3rd Floor, by Storage Room 359	1/28/13	< 1
Winston ES	3rd Floor, by Storage Room 359	1/28/13	< 1
Winston ES	3rd Floor, by Storage Room 353	1/28/13	< 1
Winston ES	3rd Floor, by Storage Room 353	1/28/13	< 1
Winston ES	2nd Floor, by Room 86	1/28/13	< 1
Winston ES	2nd Floor, by Room 86	1/28/13	< 1
Winston ES	2nd Floor, by Room 74	1/28/13	1.9
Winston ES	2nd Floor, by Room 74	1/28/13	1.3
Winston ES	2nd Floor, by Room 78	1/28/13	< 1
Winston ES	2nd Floor, by Room 78	1/28/13	< 1
Winston ES	2nd Floor, by Room 102	1/28/13	< 1
Winston ES	2nd Floor, by Room 102	1/28/13	< 1
Winston ES	2nd Floor, by Room 107	1/28/13	< 1
Winston ES	2nd Floor, by Room 107	1/28/13	< 1
Winston ES	2nd Floor, by Room 111	1/28/13	< 1
Winston ES	2nd Floor, by Room 111	1/28/13	< 1
Winston ES	2nd Floor, by Room 114	1/28/13	< 1
Winston ES	2nd Floor, by Room 114	1/28/13	< 1
Winston ES	1st Floor, by Room 64	1/28/13	< 1
Winston ES	1st Floor, by Room 64	1/28/13	< 1
Winston ES	1st Floor, by Room 60	1/28/13	< 1
Winston ES	1st Floor, by Room 60	1/28/13	< 1
Winston ES	1st Floor, by Room 58	1/28/13	< 1
Winston ES	1st Floor, by Room 58	1/28/13	< 1
Winston ES	1st Floor, by Room 25	1/28/13	< 1
Winston ES	1st Floor, by Room 25	1/28/13	< 1
Winston ES	1st Floor, by Room 21	1/28/13	< 1
Winston ES	1st Floor, by Room 21	1/28/13	< 1
Winston ES	1st Floor, by Room 38	1/28/13	< 1
Winston ES	1st Floor, by Room 38	1/28/13	< 1
Winston ES	1st Floor, by Room 34	1/28/13	< 1
Winston ES	1st Floor, by Room 34	1/28/13	< 1
		Percentage of Passed Samples	
		Percentage of Failed Samples	

Woodson SHS	3rd Floor, Next to Room 342	4/29/13	1
Woodson SHS	3rd Floor, Next to Room 342	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 333	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 333	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 307 (High)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 307 (High)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 307 (Low)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 307 (Low)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 315 (High)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 315 (High)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 315 (Low)	4/29/13	< 1
Woodson SHS	3rd Floor, Next to Room 315 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 238 (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 238 (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 238 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 238 (Low)	4/29/13	2.5
Woodson SHS	2nd Floor, Next to Room 237 (High)	4/29/13	1.7
Woodson SHS	2nd Floor, Next to Room 237 (High)	4/29/13	2
Woodson SHS	2nd Floor, Next to Room 237 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 237 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 209B (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 209B (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 209B (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 209B (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 222 (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 222 (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 222 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Room 222 (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Main Office (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Main Office (High)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Main Office (Low)	4/29/13	< 1
Woodson SHS	2nd Floor, Next to Main Office (Low)	4/29/13	< 1
Woodson SHS	1st Floor, Inside Cafeteria (High)	4/29/13	< 1
Woodson SHS	1st Floor, Inside Cafeteria (High)	4/29/13	< 1
Woodson SHS	1st Floor, Inside Cafeteria (Low)	4/29/13	< 1
Woodson SHS	1st Floor, Inside Cafeteria (Low)	4/29/13	< 1
Woodson SHS	1st Floor, Next to Room 153 (High)	4/29/13	< 1
Woodson SHS	1st Floor, Next to Room 153 (High)	4/29/13	< 1
Woodson SHS	1st Floor, Next to Room 153 (Low)	4/29/13	< 1
Woodson SHS	1st Floor, Next to Room 153 (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, In Pool Area (High)	4/29/13	< 1
Woodson SHS	Basement Floor, In Pool Area (High)	4/29/13	1.3
Woodson SHS	Basement Floor, In Pool Area (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, In Pool Area (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 002 (High)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 002 (High)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 002 (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 002 (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 011 (High)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 011 (High)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 011 (Low)	4/29/13	< 1
Woodson SHS	Basement Floor, Next to Room 011 (Low)	4/29/13	< 1
Woodson SHS	In Field Locker Room S102 Area (High)	4/29/13	< 1
Woodson SHS	In Field Locker Room S102 Area (High)	4/29/13	< 1

Woodson SHS	In Field Locker Room S102 Area (Low)	4/29/13	< 1
Woodson SHS	In Field Locker Room S102 Area (Low)	4/29/13	< 1
Woodson SHS	In Field Locker Room S102 Area (High)	4/29/13	1.5
Woodson SHS	In Field Locker Room S102 Area (High)	4/29/13	1.1
Woodson SHS	In Field Locker Room S102 Area (Low)	4/29/13	< 1
Woodson SHS	In Field Locker Room S102 Area (Low)	4/29/13	< 1

Percentage of Passed Samples
Percentage of Failed Samples

Totals/Percentages of All Tested Schools
Total Number of Schools Tested
Total Passed Samples
Total Failed Samples
Total Samples Collected
Percentage of Passed Samples
Percentage of Failed Samples

Remediation / Notes

100.00%
0.00%

100.00%
0.00%

Filter was installed.

98.33%
1.67%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

97.06%
2.94%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

98.39%
1.61%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

Filter was installed.
Filter was installed.

97.06%
2.94%

Device was replaced.

85.71%
14.29%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

97.50%
2.50%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

Filter was installed

95.00%
5.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

Filter was installed.

98.61%
1.39%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

Filter was installed.

90.63%
9.38%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

This is a science lab.
Sinks are rarely used,

99.11%
0.89%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

Filter was installed.

Device was replaced.

97.83%
2.17%

Filter was installed.

98.53%
1.47%

100.00%
0.00%

100.00%
0.00%

This is a science lab.
Sinks are rarely used,
and not used for drinking
water.

This is a science lab.
Sinks are rarely used,
and not used for drinking
water.

This is a science lab.
Sinks are rarely used,
and not used for drinking
water.

This is a science lab.
Sinks are rarely used,
and not used for drinking
water.

This is a science lab.
Sinks are rarely used,
and not used for drinking
water.

99.04%
0.96%

100.00%
0.00%

100.00%
0.00%

Filter was installed.

100.00%

0.00%

100.00%

0.00%

100.00%
0.00%

100.00%
0.00%

100.00%
0.00%

118
3999
19
4018
99.53%
0.47%